Ref. Certif. No.

FR_705078/A2

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	**Residual current operated circuit-breakers without integral overcurrent protection for household and similar uses (RCCB's)**
Name and address of the applicant	**LEGRAND FRANCE** 159 RUE JEAN JOANNON ZI DES TROIS MOULINS 06606 ANTIBES - FRANCE
Name and address of the manufacturer	**LEGRAND FRANCE** 159 RUE JEAN JOANNON ZI DES TROIS MOULINS 06606 ANTIBES - FRANCE
Name and address of the factory	See annex
Note: *When more than one factory, please report on page 2*	☒ Additional Information on page 2
Ratings and principal characteristics	See Annex
Trademark / Brand (if any)	legrand
Customer's Testing Facility (CTF) Stage used	CTF3
Model / Type Ref.	RCCB 4P Series TX^3, RX^3, DX^3 References : see annex
Additional information (if necessary may also be reported on page 2)	Supersedes CBTC FR_705078/M3 dated 14/10/2025. New version of the Test Reports ☐ Additional Information on page 2
A sample of the product was tested and found to be in conformity with	IEC 61008-1:2010 +A1:2012 +A2:2013 IEC 61008-2-1:1990
As shown in the Test Report Ref. No. which forms part of this Certificate	TR n° 23777185-805218 rev01 TR n° 23777185-805218/1 rev01 to /6 rev01; 23777185-805210 rev01, 23777185-805210/1 rev01 to /35 rev01

This CB Test Certificate is issued by the National Certification Body

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 10/09/2026

Signature: **Julien GAUTHIER**
Certification Officer

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES
S.A.S. au capital de 15.745.984 €
RCS Nanterre 408 363 174
33 avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSES

ANNEX

Name and address of the factories:

LEGRAND FRANCE
159 RUE JEAN JOANNON
ZI DES TROIS MOULINS
06606 ANTIBES
FRANCE

LEGRAND FRANCE
290 AVENUE DE COLMAR
67100 STRASBOURG
FRANCE

LEGRAND ELEKTRIK SANAYI A.S
GOSB GEBZE ORGANIZE SANAYI BOLGESI
IHSAN DEDE CADDESI N°112
41480 GEBZE KOCAELI
TURKEY

ANNEX

REFERENCES, RATINGS AND MAIN CHARACTERISTICS

Reference TX³ Germanic series	In	Un	Neutral position	IΔn	Type	Im	IΔm	Inc	IΔc
4117 07	25 A	400V~	right	30 mA	AC	500 A	1000 A	10000A	10000A
4117 08	40 A	400V~	right	30 mA	AC	500 A	1000 A	10000A	10000A
4117 09	63 A	400V~	right	30 mA	AC	630 A	1000 A	10000A	10000A
4117 10	80 A	400V~	right	30 mA	AC	800 A	1000 A	10000A	10000A
LG1293	100 A	400V~	right	30 mA	AC	1000 A	1000 A	10000A	10000A
4117 17	25 A	400V~	right	100 mA	AC	500 A	1000 A	10000A	10000A
4117 18	40 A	400V~	right	100 mA	AC	500 A	1000 A	10000A	10000A
4117 19	63 A	400V~	right	100 mA	AC	630 A	1000 A	10000A	10000A
4117 20	80 A	400V~	right	100 mA	AC	800 A	1000 A	10000A	10000A
LG1294	100 A	400V~	right	100 mA	AC	1000 A	1000 A	10000A	10000A
4117 27	25 A	400V~	right	300 mA	AC	500 A	1000 A	10000A	10000A
4117 28	40 A	400V~	right	300 mA	AC	500 A	1000 A	10000A	10000A
4117 29	63 A	400V~	right	300 mA	AC	630 A	1000 A	10000A	10000A
4117 30	80 A	400V~	right	300 mA	AC	800 A	1000 A	10000A	10000A
LG1295	100 A	400V~	right	300 mA	AC	1000 A	1000 A	10000A	10000A
4117 37	25 A	400V~	right	500 mA	AC	500 A	1000 A	10000A	10000A
4117 38	40 A	400V~	right	500 mA	AC	500 A	1000 A	10000A	10000A
4117 39	63 A	400V~	right	500 mA	AC	630 A	1000 A	10000A	10000A
4117 40	80 A	400V~	right	500 mA	AC	800 A	1000 A	10000A	10000A
LG1296	100 A	400V~	right	500 mA	AC	1000 A	1000 A	10000A	10000A

Reference TX³ Germanic series	In	Un	Neutral position	IΔn	Type	Im	IΔm	Inc	IΔc
4117 64 4119 31	25 A	400V~	right	30 mA	A	500 A	1000 A	10000A	10000A
4117 65 4119 32	40 A	400V~	right	30 mA	A	500 A	1000 A	10000A	10000A
4117 66 4119 33	63 A	400V~	right	30 mA	A	630 A	1000 A	10000A	10000A
4117 67	80 A	400V~	right	30 mA	A	800 A	1000 A	10000A	10000A
4117 68	100 A	400V~	right	30 mA	A	1000 A	1000 A	10000A	10000A
4117 74 4119 36	25 A	400V~	right	100 mA	A	500 A	1000 A	10000A	10000A
4117 75 4119 37	40 A	400V~	right	100 mA	A	500 A	1000 A	10000A	10000A
4117 76 4119 38	63 A	400V~	right	100 mA	A	630 A	1000 A	10000A	10000A
4117 77	80 A	400V~	right	100 mA	A	800 A	1000 A	10000A	10000A
4117 78	100 A	400V~	right	100 mA	A	1000 A	1000 A	10000A	10000A
4117 84	25 A	400V~	right	300 mA	A	500 A	1000 A	10000A	10000A
4117 85 4119 42	40 A	400V~	right	300 mA	A	500 A	1000 A	10000A	10000A
4117 86 4119 43	63 A	400V~	right	300 mA	A	630 A	1000 A	10000A	10000A
4117 87	80 A	400V~	right	300 mA	A	800 A	1000 A	10000A	10000A
4117 88	100 A	400V~	right	300 mA	A	1000 A	1000 A	10000A	10000A
4117 94	25 A	400V~	right	500 mA	A	500 A	1000 A	10000A	10000A
4117 95	40 A	400V~	right	500 mA	A	500 A	1000 A	10000A	10000A
4117 96	63 A	400V~	right	500 mA	A	630 A	1000 A	10000A	10000A
4117 97	80 A	400V~	right	500 mA	A	800 A	1000 A	10000A	10000A
4117 98	100 A	400V~	right	500 mA	A	1000 A	1000 A	10000A	10000A

Reference TX³ Germanic series	In	Un	Neutral position	IΔn	Type	Im	IΔm	Inc	IΔc
LG1309	25 A	400V~	right	100 mA	AC-S	500 A	1000 A	10000A	10000A
4117 42	40 A	400V~	right	100 mA	AC-S	500 A	1000 A	10000A	10000A
4117 43	63 A	400V~	right	100 mA	AC-S	630 A	1000 A	10000A	10000A
LG1310	80 A	400V~	right	100 mA	AC-S	800 A	1000 A	10000A	10000A
LG1311	100 A	400V~	right	100 mA	AC-S	1000 A	1000 A	10000A	10000A
LG1312	25 A	400V~	right	300 mA	AC-S	500 A	1000 A	10000A	10000A
4117 48	40 A	400V~	right	300 mA	AC-S	500 A	1000 A	10000A	10000A
4117 49	63 A	400V~	right	300 mA	AC-S	630 A	1000 A	10000A	10000A
LG1313	80 A	400V~	right	300 mA	AC-S	800 A	1000 A	10000A	10000A
LG1314	100 A	400V~	right	300 mA	AC-S	1000 A	1000 A	10000A	10000A
LG1315	25 A	400V~	right	500 mA	AC-S	500 A	1000 A	10000A	10000A
LG1316	40 A	400V~	right	500 mA	AC-S	500 A	1000 A	10000A	10000A
LG1317	63 A	400V~	right	500 mA	AC-S	630 A	1000 A	10000A	10000A
LG1318	80 A	400V~	right	500 mA	AC-S	800 A	1000 A	10000A	10000A
LG1319	100 A	400V~	right	500 mA	AC-S	1000 A	1000 A	10000A	10000A

Reference TX³ Germanic series	In	Un	Neutral position	IΔn	Type	Im	IΔm	Inc	IΔc
4119 51	25 A	400V~	right	100 mA	A-S	500 A	1000 A	10000A	10000A
4119 52	40 A	400V~	right	100 mA	A-S	500 A	1000 A	10000A	10000A
4119 53	63 A	400V~	right	100 mA	A-S	630 A	1000 A	10000A	10000A
LG1304	80 A	400V~	right	100 mA	A-S	800 A	1000 A	10000A	10000A
LG1305	100 A	400V~	right	100 mA	A-S	1000 A	1000 A	10000A	10000A
4118 03	25 A	400V~	right	300 mA	A-S	500 A	1000 A	10000A	10000A
4118 04 4119 47	40 A	400V~	right	300 mA	A-S	500 A	1000 A	10000A	10000A
4118 05 4119 48	63 A	400V~	right	300 mA	A-S	630 A	1000 A	10000A	10000A
4118 06	80 A	400V~	right	300 mA	A-S	800 A	1000 A	10000A	10000A
LG1306	100 A	400V~	right	300 mA	A-S	1000 A	1000 A	10000A	10000A
LG1307	25 A	400V~	right	500 mA	A-S	500 A	1000 A	10000A	10000A
4118 07	40 A	400V~	right	500 mA	A-S	500 A	1000 A	10000A	10000A
4118 08	63 A	400V~	right	500 mA	A-S	630 A	1000 A	10000A	10000A
4118 09	80 A	400V~	right	500 mA	A-S	800 A	1000 A	10000A	10000A
LG1308	100 A	400V~	right	500 mA	A-S	1000 A	1000 A	10000A	10000A

Reference TX³ Germanic series	In	Un	Neutral position	IΔn	Type	Im	IΔm	Inc	IΔc
LG1297	25 A	400V~	right	30 mA	AC*	500 A	1000 A	10000A	10000A
4117 52	40 A	400V~	right	30 mA	AC*	500 A	1000 A	10000A	10000A
4117 53	63 A	400V~	right	30 mA	AC*	630 A	1000 A	10000A	10000A
LG1298	80 A	400V~	right	30 mA	AC*	800 A	1000 A	10000A	10000A
LG2732	100 A	400V~	right	30 mA	AC*	1000 A	1000 A	10000A	10000A
LG1299	25 A	400V~	right	100 mA	AC*	500 A	1000 A	10000A	10000A
4117 56	40 A	400V~	right	100 mA	AC*	500 A	1000 A	10000A	10000A
4117 57	63 A	400V~	right	100 mA	AC*	630 A	1000 A	10000A	10000A
LG1300	80 A	400V~	right	100 mA	AC*	800 A	1000 A	10000A	10000A
LG2734	100 A	400V~	right	100 mA	AC*	1000 A	1000 A	10000A	10000A
LG2736	25 A	400V~	right	300 mA	AC*	500 A	1000 A	10000A	10000A
LG2737	40 A	400V~	right	300 mA	AC*	500 A	1000 A	10000A	10000A
LG2738	63 A	400V~	right	300 mA	AC*	630 A	1000 A	10000A	10000A
LG2739	80 A	400V~	right	300 mA	AC*	800 A	1000 A	10000A	10000A
LG2740	100 A	400V~	right	300 mA	AC*	1000 A	1000 A	10000A	10000A
LG7245	25 A	400V~	left	30 mA	AC	500 A	1000 A	10000A	10000A
LG7246	40 A	400V~	left	30 mA	AC	500 A	1000 A	10000A	10000A
LG7247	63 A	400V~	left	30 mA	AC	630 A	1000 A	10000A	10000A
LG7248	80 A	400V~	left	30 mA	AC	800 A	1000 A	10000A	10000A
LG7249	100 A	400V~	left	30 mA	AC	1000 A	1000 A	10000A	10000A

* RCCB's dedicated to Austria market

Reference TX³ Germanic series	In	Un	Neutral position	IΔn	Type	Im	IΔm	Inc	IΔc
LG7250	25 A	400V~	left	100 mA	AC	500 A	1000 A	10000A	10000A
LG7251	40 A	400V~	left	100 mA	AC	500 A	1000 A	10000A	10000A
LG7252	63 A	400V~	left	100 mA	AC	630 A	1000 A	10000A	10000A
LG7253	80 A	400V~	left	100 mA	AC	800 A	1000 A	10000A	10000A
LG7254	100 A	400V~	left	100 mA	AC	1000 A	1000 A	10000A	10000A
LG7255	25 A	400V~	left	300 mA	AC	500 A	1000 A	10000A	10000A
LG7256	40 A	400V~	left	300 mA	AC	500 A	1000 A	10000A	10000A
LG7257	63 A	400V~	left	300 mA	AC	630 A	1000 A	10000A	10000A
LG7258	80 A	400V~	left	300 mA	AC	800 A	1000 A	10000A	10000A
LG7259	100 A	400V~	left	300 mA	AC	1000 A	1000 A	10000A	10000A
LG7260	25 A	400V~	left	500 mA	AC	500 A	1000 A	10000A	10000A
LG7261	40 A	400V~	left	500 mA	AC	500 A	1000 A	10000A	10000A
LG7262	63 A	400V~	left	500 mA	AC	630 A	1000 A	10000A	10000A
LG7263	80 A	400V~	left	500 mA	AC	800 A	1000 A	10000A	10000A
LG7264	100 A	400V~	left	500 mA	AC	1000 A	1000 A	10000A	10000A
LG2701	25 A	400V~	left	30 mA	A	500 A	1000 A	10000A	10000A
LG2702	40 A	400V~	left	30 mA	A	500 A	1000 A	10000A	10000A
LG2703	63 A	400V~	left	30 mA	A	630 A	1000 A	10000A	10000A
LG2704	80 A	400V~	left	30 mA	A	800 A	1000 A	10000A	10000A
LG2705	100 A	400V~	left	30 mA	A	1000 A	1000 A	10000A	10000A

Reference TX³ Germanic series	In	Un	Neutral position	IΔn	Type	Im	IΔm	Inc	IΔc
LG2707	25 A	400V~	left	100 mA	A	500 A	1000 A	10000A	10000A
LG2708	40 A	400V~	left	100 mA	A	500 A	1000 A	10000A	10000A
LG2709	63 A	400V~	left	100 mA	A	630 A	1000 A	10000A	10000A
LG2710	80 A	400V~	left	100 mA	A	800 A	1000 A	10000A	10000A
LG2711	100 A	400V~	left	100 mA	A	1000 A	1000 A	10000A	10000A
LG2713	25 A	400V~	left	300 mA	A	500 A	1000 A	10000A	10000A
LG2714	40 A	400V~	left	300 mA	A	500 A	1000 A	10000A	10000A
LG2715	63 A	400V~	left	300 mA	A	630 A	1000 A	10000A	10000A
LG2716	80 A	400V~	left	300 mA	A	800 A	1000 A	10000A	10000A
LG2717	100 A	400V~	left	300 mA	A	1000 A	1000 A	10000A	10000A
LG2719	25 A	400V~	left	500 mA	A	500 A	1000 A	10000A	10000A
LG2720	40 A	400V~	left	500 mA	A	500 A	1000 A	10000A	10000A
LG2721	63 A	400V~	left	500 mA	A	630 A	1000 A	10000A	10000A
LG2722	80 A	400V~	left	500 mA	A	800 A	1000 A	10000A	10000A
LG2723	100 A	400V~	left	500 mA	A	1000 A	1000 A	10000A	10000A
LG7265	25 A	400V~	left	100 mA	AC-S	500 A	1000 A	10000A	10000A
LG7266	40 A	400V~	left	100 mA	AC-S	500 A	1000 A	10000A	10000A
LG7267	63 A	400V~	left	100 mA	AC-S	630 A	1000 A	10000A	10000A
LG7268	80 A	400V~	left	100 mA	AC-S	800 A	1000 A	10000A	10000A
LG7269	100 A	400V~	left	100 mA	AC-S	1000 A	1000 A	10000A	10000A
LG7270	25 A	400V~	left	300 mA	AC-S	500 A	1000 A	10000A	10000A
LG7271	40 A	400V~	left	300 mA	AC-S	500 A	1000 A	10000A	10000A
LG7272	63 A	400V~	left	300 mA	AC-S	630 A	1000 A	10000A	10000A
LG7273	80 A	400V~	left	300 mA	AC-S	800 A	1000 A	10000A	10000A
LG7274	100 A	400V~	left	300 mA	AC-S	1000 A	1000 A	10000A	10000A

Reference TX³ Germanic series	In	Un	Neutral position	IΔn	Type	Im	IΔm	Inc	IΔc
LG7275	25 A	400V~	left	500 mA	AC-S	500 A	1000 A	10000A	10000A
LG7276	40 A	400V~	left	500 mA	AC-S	500 A	1000 A	10000A	10000A
LG7277	63 A	400V~	left	500 mA	AC-S	630 A	1000 A	10000A	10000A
LG7278	80 A	400V~	left	500 mA	AC-S	800 A	1000 A	10000A	10000A
LG7279	100 A	400V~	left	500 mA	AC-S	1000 A	1000 A	10000A	10000A
LG7295	25 A	220/380V~	left	30 mA	AC	500 A	1000 A	10000A	10000A
LG7296	40 A	220/380V~	left	30 mA	AC	500 A	1000 A	10000A	10000A
LG7297	63 A	220/380V~	left	30 mA	AC	630 A	1000 A	10000A	10000A
LG7298	80 A	220/380V~	left	30 mA	AC	800 A	1000 A	10000A	10000A
LG7299	100 A	220/380V~	left	30 mA	AC	1000 A	1000 A	10000A	10000A
LG7300	25 A	220/380V~	left	300 mA	AC	500 A	1000 A	10000A	10000A
LG7301	40 A	220/380V~	left	300 mA	AC	500 A	1000 A	10000A	10000A
LG7302	63 A	220/380V~	left	300 mA	AC	630 A	1000 A	10000A	10000A
LG7303	80 A	220/380V~	left	300 mA	AC	800 A	1000 A	10000A	10000A
LG7304	100 A	220/380V~	left	300 mA	AC	1000 A	1000 A	10000A	10000A
LG7305	25 A	220/380V~	left	30 mA	A	500 A	1000 A	10000A	10000A
LG7306	40 A	220/380V~	left	30 mA	A	500 A	1000 A	10000A	10000A
LG7307	63 A	220/380V~	left	30 mA	A	630 A	1000 A	10000A	10000A
LG7308	80 A	220/380V~	left	30 mA	A	800 A	1000 A	10000A	10000A
LG7309	100 A	220/380V~	left	30 mA	A	1000 A	1000 A	10000A	10000A
LG7310	25 A	220/380V~	left	300 mA	A	500 A	1000 A	10000A	10000A
LG7311	40 A	220/380V~	left	300 mA	A	500 A	1000 A	10000A	10000A
LG7312	63 A	220/380V~	left	300 mA	A	630 A	1000 A	10000A	10000A
LG7313	80 A	220/380V~	left	300 mA	A	800 A	1000 A	10000A	10000A
LG7314	100 A	220/380V~	left	300 mA	A	1000 A	1000 A	10000A	10000A

reference TX3 Germanic other range series	In	Un	Neutral position	IΔn	Type	Im	IΔm	Inc	IΔc
LG7614	25 A	400V~	right	30 mA	AC	500 A	1000 A	10000A	10000A
LG7615	40 A	400V~	right	30 mA	AC	500 A	1000 A	10000A	10000A
LG7616	63 A	400V~	right	30 mA	AC	630 A	1000 A	10000A	10000A
LG7617	80 A	400V~	right	30 mA	AC	800 A	1000 A	10000A	10000A
LG7618	100 A	400V~	right	30 mA	AC	1000 A	1000 A	10000A	10000A
8LG0304	25 A	400V~	Right	100 mA	AC	500 A	1000 A	10000A	10000A
8LG0305	40 A	400V~	Right	100 mA	AC	500 A	1000 A	10000A	10000A
8LG0306	63 A	400V~	Right	100 mA	AC	630 A	1000 A	10000A	10000A
8LG0307	80 A	400V~	Right	100 mA	AC	800 A	1000 A	10000A	10000A
8LG0308	100 A	400V~	Right	100 mA	AC	1000 A	1000 A	10000A	10000A
LG7619	25 A	400V~	right	300 mA	AC	500 A	1000 A	10000A	10000A
LG7620	40 A	400V~	right	300 mA	AC	500 A	1000 A	10000A	10000A
LG7621	63 A	400V~	right	300 mA	AC	630 A	1000 A	10000A	10000A
LG7622	80 A	400V~	right	300 mA	AC	800 A	1000 A	10000A	10000A
LG7623	100 A	400V~	right	300 mA	AC	1000 A	1000 A	10000A	10000A
8LG0309	25 A	400V~	Right	500 mA	AC	500 A	1000 A	10000A	10000A
8LG0310	40 A	400V~	Right	500 mA	AC	500 A	1000 A	10000A	10000A
8LG0311	63 A	400V~	Right	500 mA	AC	630 A	1000 A	10000A	10000A
8LG0312	80 A	400V~	Right	500 mA	AC	800 A	1000 A	10000A	10000A
8LG0313	100 A	400V~	Right	500 mA	AC	1000 A	1000 A	10000A	10000A
LG7624	25 A	400V~	right	30 mA	A	500 A	1000 A	10000A	10000A
LG7625	40 A	400V~	right	30 mA	A	500 A	1000 A	10000A	10000A
LG7626	63 A	400V~	right	30 mA	A	630 A	1000 A	10000A	10000A
LG7627	80 A	400V~	right	30 mA	A	800 A	1000 A	10000A	10000A
LG7628	100 A	400V~	right	30 mA	A	1000 A	1000 A	10000A	10000A
8LG0314	25 A	400V~	Right	100 mA	A	500 A	1000 A	10000A	10000A
8LG0315	40 A	400V~	Right	100 mA	A	500 A	1000 A	10000A	10000A
8LG0316	63 A	400V~	Right	100 mA	A	630 A	1000 A	10000A	10000A
8LG0317	80 A	400V~	Right	100 mA	A	800 A	1000 A	10000A	10000A
8LG0318	100 A	400V~	Right	100 mA	A	1000A	1000 A	10000A	10000A

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 10/09/2026

Signature: **Julien GAUTHIER**
Certification Officer

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES
S.A.R.L. au capital de 15.745.984 €
RCS Nanterre B 408 363 174
33 avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSES

reference TX3 Germanic other range series	In	Un	Neutral position	IΔn	Type	Im	IΔm	Inc	IΔc
LG7629	25 A	400V~	right	300 mA	A	500 A	1000 A	10000A	10000A
LG7630	40 A	400V~	right	300 mA	A	500 A	1000 A	10000A	10000A
LG7631	63 A	400V~	right	300 mA	A	630 A	1000 A	10000A	10000A
LG7632	80 A	400V~	right	300 mA	A	800 A	1000 A	10000A	10000A
LG7633	100 A	400V~	right	300 mA	A	1000 A	1000 A	10000A	10000A
8LG0319	25 A	400V~	Right	500 mA	A	500 A	1000 A	10000A	10000A
8LG0320	40 A	400V~	Right	500 mA	A	500 A	1000 A	10000A	10000A
8LG0321	63 A	400V~	Right	500 mA	A	630 A	1000 A	10000A	10000A
8LG0322	80 A	400V~	Right	500 mA	A	800 A	1000 A	10000A	10000A
8LG0323	100 A	400V~	Right	500 mA	A	1000A	1000 A	10000A	10000A
LG7634	25 A	400V~	left	30 mA	AC	500 A	1000 A	10000A	10000A
LG7635	40 A	400V~	left	30 mA	AC	500 A	1000 A	10000A	10000A
LG7636	63 A	400V~	left	30 mA	AC	630 A	1000 A	10000A	10000A
LG7637	80 A	400V~	left	30 mA	AC	800 A	1000 A	10000A	10000A
LG7638	100 A	400V~	left	30 mA	AC	1000 A	1000 A	10000A	10000A
8LG0324	25 A	400V~	Left	100 mA	AC	500 A	1000 A	10000A	10000A
8LG0325	40 A	400V~	Left	100 mA	AC	500 A	1000 A	10000A	10000A
8LG0326	63 A	400V~	Left	100 mA	AC	630 A	1000 A	10000A	10000A
8LG0327	80 A	400V~	Left	100 mA	AC	800 A	1000 A	10000A	10000A
8LG0328	100 A	400V~	Left	100 mA	AC	1000 A	1000 A	10000A	10000A
LG7639	25 A	400V~	left	300 mA	AC	500 A	1000 A	10000A	10000A
LG7640	40 A	400V~	left	300 mA	AC	500 A	1000 A	10000A	10000A
LG7641	63 A	400V~	left	300 mA	AC	630 A	1000 A	10000A	10000A
LG7642	80 A	400V~	left	300 mA	AC	800 A	1000 A	10000A	10000A
LG7643	100 A	400V~	left	300 mA	AC	1000 A	1000 A	10000A	10000A
8LG0329	25 A	400V~	Left	500 mA	AC	500 A	1000 A	10000A	10000A
8LG0330	40 A	400V~	Left	500 mA	AC	500 A	1000 A	10000A	10000A
8LG0331	63 A	400V~	Left	500 mA	AC	630 A	1000 A	10000A	10000A
8LG0332	80 A	400V~	Left	500 mA	AC	800 A	1000 A	10000A	10000A
8LG0333	100 A	400V~	Left	500 mA	AC	1000 A	1000 A	10000A	10000A

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 10/09/2026

Signature: **Julien GAUTHIER**
Certification Officer

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES
SAS au capital de 15.745.984 €
RCS Nanterre B 408 363 174
33 avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSES

Reference TX³ Germanic other range series	In	Un	Neutral position	IΔn	Type	Im	IΔm	Inc	IΔc
LG7644	25 A	400V~	left	30 mA	A	500 A	1000 A	10000A	10000A
LG7645	40 A	400V~	left	30 mA	A	500 A	1000 A	10000A	10000A
LG7646	63 A	400V~	left	30 mA	A	630 A	1000 A	10000A	10000A
LG7647	80 A	400V~	left	30 mA	A	800 A	1000 A	10000A	10000A
LG7648	100 A	400V~	left	30 mA	A	1000 A	1000 A	10000A	10000A
8LG0334	25 A	400V~	Left	100 mA	A	500 A	1000 A	10000A	10000A
8LG0335	40 A	400V~	Left	100 mA	A	500 A	1000 A	10000A	10000A
8LG0336	63 A	400V~	Left	100 mA	A	630 A	1000 A	10000A	10000A
8LG0337	80 A	400V~	Left	100 mA	A	800 A	1000 A	10000A	10000A
8LG0338	100 A	400V~	Left	100 mA	A	1000A	1000 A	10000A	10000A
LG7649	25 A	400V~	left	300 mA	A	500 A	1000 A	10000A	10000A
LG7650	40 A	400V~	left	300 mA	A	500 A	1000 A	10000A	10000A
LG7651	63 A	400V~	left	300 mA	A	630 A	1000 A	10000A	10000A
LG7652	80 A	400V~	left	300 mA	A	800 A	1000 A	10000A	10000A
LG7653	100 A	400V~	left	300 mA	A	1000 A	1000 A	10000A	10000A
8LG0339	25 A	400V~	Left	500 mA	A	500 A	1000 A	10000A	10000A
8LG0340	40 A	400V~	Left	500 mA	A	500 A	1000 A	10000A	10000A
8LG0341	63 A	400V~	Left	500 mA	A	630 A	1000 A	10000A	10000A
8LG0342	80 A	400V~	Left	500 mA	A	800 A	1000 A	10000A	10000A
8LG0343	100 A	400V~	Left	500 mA	A	1000A	1000 A	10000A	10000A

Reference TX3 Germanic other range series	In	Un	Neutral position	IΔn	Type	Im	IΔm	Inc	IΔc
8LG0749	25 A	400V~	Right	100 mA	AC-S	500 A	1000 A	10000A	10000A
8LG0750	40 A	400V~	Right	100 mA	AC-S	500 A	1000 A	10000A	10000A
8LG0751	63 A	400V~	Right	100 mA	AC-S	630 A	1000 A	10000A	10000A
8LG0752	80 A	400V~	Right	100 mA	AC-S	800 A	1000 A	10000A	10000A
8LG0753	100 A	400V~	Right	100 mA	AC-S	1000 A	1000 A	10000A	10000A
8LG0754	25 A	400V~	Right	300 mA	AC-S	500 A	1000 A	10000A	10000A
8LG0755	40 A	400V~	Right	300 mA	AC-S	500 A	1000 A	10000A	10000A
8LG0756	63 A	400V~	Right	300 mA	AC-S	630 A	1000 A	10000A	10000A
8LG0757	80 A	400V~	Right	300 mA	AC-S	800 A	1000 A	10000A	10000A
8LG0758	100 A	400V~	Right	300 mA	AC-S	1000 A	1000 A	10000A	10000A
8LG0759	25 A	400V~	Right	500 mA	AC-S	500 A	1000 A	10000A	10000A
8LG0760	40 A	400V~	Right	500 mA	AC-S	500 A	1000 A	10000A	10000A
8LG0761	63 A	400V~	Right	500 mA	AC-S	630 A	1000 A	10000A	10000A
8LG0762	80 A	400V~	Right	500 mA	AC-S	800 A	1000 A	10000A	10000A
8LG0763	100 A	400V~	Right	500 mA	AC-S	1000 A	1000 A	10000A	10000A
8LG0764	25 A	400V~	Right	30 mA	AC *	500 A	1000 A	10000A	10000A
8LG0765	40 A	400V~	Right	30 mA	AC *	500 A	1000 A	10000A	10000A
8LG0766	63 A	400V~	Right	30 mA	AC *	630 A	1000 A	10000A	10000A
8LG0767	80 A	400V~	Right	30 mA	AC *	800 A	1000 A	10000A	10000A
8LG0768	100 A	400V~	Right	30 mA	AC *	1000 A	1000 A	10000A	10000A

* RCCB's dedicated to Austria market

Reference TX3 Germanic other range series	In	Un	Neutral position	IΔn	Type	Im	IΔm	Inc	IΔc
8LG0769	25 A	400V~	Right	100 mA	AC *	500 A	1000 A	10000A	10000A
8LG0770	40 A	400V~	Right	100 mA	AC *	500 A	1000 A	10000A	10000A
8LG0771	63 A	400V~	Right	100 mA	AC *	630 A	1000 A	10000A	10000A
8LG0772	80 A	400V~	Right	100 mA	AC *	800 A	1000 A	10000A	10000A
8LG0773	100 A	400V~	Right	100 mA	AC *	1000 A	1000 A	10000A	10000A
8LG0774	25 A	400V~	Right	300 mA	AC *	500 A	1000 A	10000A	10000A
8LG0775	40 A	400V~	Right	300 mA	AC *	500 A	1000 A	10000A	10000A
8LG0776	63 A	400V~	Right	300 mA	AC *	630 A	1000 A	10000A	10000A
8LG0777	80 A	400V~	Right	300 mA	AC *	800 A	1000 A	10000A	10000A
8LG0778	100 A	400V~	Right	300 mA	AC *	1000 A	1000 A	10000A	10000A
8LG0779	25 A	400V~	Right	100 mA	A-S	500 A	1000 A	10000A	10000A
8LG0780	40 A	400V~	Right	100 mA	A-S	500 A	1000 A	10000A	10000A
8LG0781	63 A	400V~	Right	100 mA	A-S	630 A	1000 A	10000A	10000A
8LG0782	80 A	400V~	Right	100 mA	A-S	800 A	1000 A	10000A	10000A
8LG0783	100 A	400V~	Right	100 mA	A-S	1000A	1000 A	10000A	10000A
8LG0784	25 A	400V~	Right	300 mA	A-S	500 A	1000 A	10000A	10000A
8LG0785	40 A	400V~	Right	300 mA	A-S	500 A	1000 A	10000A	10000A
8LG0786	63 A	400V~	Right	300 mA	A-S	630 A	1000 A	10000A	10000A
8LG0787	80 A	400V~	Right	300 mA	A-S	800 A	1000 A	10000A	10000A
8LG0788	100 A	400V~	Right	300 mA	A-S	1000A	1000 A	10000A	10000A

* RCCB's dedicated to Austria market

Reference TX3 Germanic other range series	In	Un	Neutral position	IΔn	Type	Im	IΔm	Inc	IΔc
8LG0789	25 A	400V~	Right	500 mA	A-S	500 A	1000 A	10000A	10000A
8LG0790	40 A	400V~	Right	500 mA	A-S	500 A	1000 A	10000A	10000A
8LG0791	63 A	400V~	Right	500 mA	A-S	630 A	1000 A	10000A	10000A
8LG0792	80 A	400V~	Right	500 mA	A-S	800 A	1000 A	10000A	10000A
8LG0793	100 A	400V~	Right	500 mA	A-S	1000A	1000 A	10000A	10000A
8LG0920	25 A	400V~	Left	100 mA	AC-S	500 A	1000 A	10000A	10000A
8LG0921	40 A	400V~	Left	100 mA	AC-S	500 A	1000 A	10000A	10000A
8LG0922	63 A	400V~	Left	100 mA	AC-S	630 A	1000 A	10000A	10000A
8LG0923	80 A	400V~	Left	100 mA	AC-S	800 A	1000 A	10000A	10000A
8LG0924	100 A	400V~	Left	100 mA	AC-S	1000 A	1000 A	10000A	10000A
8LG0925	25 A	400V~	Left	300 mA	AC-S	500 A	1000 A	10000A	10000A
8LG0926	40 A	400V~	Left	300 mA	AC-S	500 A	1000 A	10000A	10000A
8LG0927	63 A	400V~	Left	300 mA	AC-S	630 A	1000 A	10000A	10000A
8LG0928	80 A	400V~	Left	300 mA	AC-S	800 A	1000 A	10000A	10000A
8LG0929	100 A	400V~	Left	300 mA	AC-S	1000 A	1000 A	10000A	10000A
8LG0930	25 A	400V~	Left	500 mA	AC-S	500 A	1000 A	10000A	10000A
8LG0931	40 A	400V~	Left	500 mA	AC-S	500 A	1000 A	10000A	10000A
8LG0932	63 A	400V~	Left	500 mA	AC-S	630 A	1000 A	10000A	10000A
8LG0933	80 A	400V~	Left	500 mA	AC-S	800 A	1000 A	10000A	10000A
8LG0934	100 A	400V~	Left	500 mA	AC-S	1000 A	1000 A	10000A	10000A
LG7654	25 A	220/380V~	left	30 mA	AC	500 A	1000 A	10000A	10000A
LG7655	40 A	220/380V~	left	30 mA	AC	500 A	1000 A	10000A	10000A
LG7656	63 A	220/380V~	left	30 mA	AC	630 A	1000 A	10000A	10000A
LG7657	80 A	220/380V~	left	30 mA	AC	800 A	1000 A	10000A	10000A
LG7658	100 A	220/380V~	left	30 mA	AC	1000 A	1000 A	10000A	10000A
8LG0344	25 A	220/380V~	Left	300 mA	AC	500 A	1000 A	10000A	10000A
8LG0345	40 A	220/380V~	Left	300 mA	AC	500 A	1000 A	10000A	10000A
8LG0346	63 A	220/380V~	Left	300 mA	AC	630 A	1000 A	10000A	10000A
8LG0347	80 A	220/380V~	Left	300 mA	AC	800 A	1000 A	10000A	10000A
8LG0348	100 A	220/380V~	Left	300 mA	AC	1000 A	1000 A	10000A	10000A

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 10/09/2026

Signature: **Julien GAUTHIER**
Certification Officer

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES
S.A.S. au capital de 15.745.984 €
RCS Nanterre B 408 363 174
33 avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSES

reference TX3 Germanic other range series	In	Un	Neutral position	IΔn	Type	Im	IΔm	Inc	IΔc
LG7659	25 A	220/380V~	left	30 mA	A	500 A	1000 A	10000A	10000A
LG7660	40 A	220/380V~	left	30 mA	A	500 A	1000 A	10000A	10000A
LG7661	63 A	220/380V~	left	30 mA	A	630 A	1000 A	10000A	10000A
LG7662	80 A	220/380V~	left	30 mA	A	800 A	1000 A	10000A	10000A
LG7663	100 A	220/380V~	left	30 mA	A	1000 A	1000 A	10000A	10000A
8LG0349	25 A	220/380V~	Left	300 mA	A	500 A	1000 A	10000A	10000A
8LG0350	40 A	220/380V~	Left	300 mA	A	500 A	1000 A	10000A	10000A
8LG0351	63 A	220/380V~	Left	300 mA	A	630 A	1000 A	10000A	10000A
8LG0352	80 A	220/380V~	Left	300 mA	A	800 A	1000 A	10000A	10000A
8LG0353	100 A	220/380V~	Left	300 mA	A	1000A	1000 A	10000A	10000A

References TX³ Latin series	In	Un	Neutral position	IΔn	Type	Im	IΔm	Inc	IΔc
4030 08	25 A	400V~	right	30 mA	AC	500 A	1000 A	10000A	10000A
4030 09	40 A	400V~	right	30 mA	AC	500 A	1000 A	10000A	10000A
4030 10	63 A	400V~	right	30 mA	AC	630 A	1000 A	10000A	10000A
LG1266	80 A	400V~	right	30 mA	AC	800 A	1000 A	10000A	10000A
LG1267	100 A	400V~	right	30 mA	AC	1000 A	1000 A	10000A	10000A
LG2621	25 A	400V~	right	100 mA	AC	500 A	1000 A	10000A	10000A
LG2622	40 A	400V~	right	100 mA	AC	500 A	1000 A	10000A	10000A
LG2623	63 A	400V~	right	100 mA	AC	630 A	1000 A	10000A	10000A
LG2624	80 A	400V~	right	100 mA	AC	800 A	1000 A	10000A	10000A
LG2625	100 A	400V~	right	100 mA	AC	1000 A	1000 A	10000A	10000A
4030 42	25 A	400V~	right	300 mA	AC	500 A	1000 A	10000A	10000A
4030 43	40 A	400V~	right	300 mA	AC	500 A	1000 A	10000A	10000A
4030 44	63 A	400V~	right	300 mA	AC	630 A	1000 A	10000A	10000A
LG2627	80 A	400V~	right	300 mA	AC	800 A	1000 A	10000A	10000A
LG2628	100 A	400V~	right	300 mA	AC	1000 A	1000 A	10000A	10000A
LG2630	25 A	400V~	right	500 mA	AC	500 A	1000 A	10000A	10000A
LG2631	40 A	400V~	right	500 mA	AC	500 A	1000 A	10000A	10000A
LG2632	63 A	400V~	right	500 mA	AC	630 A	1000 A	10000A	10000A
LG2633	80 A	400V~	right	500 mA	AC	800 A	1000 A	10000A	10000A
LG2634	100 A	400V~	right	500 mA	AC	1000 A	1000 A	10000A	10000A

References TX³ Latin series	In	Un	Neutral position	IΔn	Type	Im	IΔm	Inc	IΔc
LG1260	25 A	400V~	right	30 mA	A	500 A	1000 A	10000A	10000A
LG1261	40 A	400V~	right	30 mA	A	500 A	1000 A	10000A	10000A
LG1262	63 A	400V~	right	30 mA	A	630 A	1000 A	10000A	10000A
LG1263	80 A	400V~	right	30 mA	A	800 A	1000 A	10000A	10000A
LG1264	100 A	400V~	right	30 mA	A	1000 A	1000 A	10000A	10000A
LG2637	25 A	400V~	right	100 mA	A	500 A	1000 A	10000A	10000A
LG2638	40 A	400V~	right	100 mA	A	500 A	1000 A	10000A	10000A
LG2639	63 A	400V~	right	100 mA	A	630 A	1000 A	10000A	10000A
LG2640	80 A	400V~	right	100 mA	A	800 A	1000 A	10000A	10000A
LG2641	100 A	400V~	right	100 mA	A	1000 A	1000 A	10000A	10000A
LG2643	25 A	400V~	right	300 mA	A	500 A	1000 A	10000A	10000A
LG2644	40 A	400V~	right	300 mA	A	500 A	1000 A	10000A	10000A
LG2645	63 A	400V~	right	300 mA	A	630 A	1000 A	10000A	10000A
LG2646	80 A	400V~	right	300 mA	A	800 A	1000 A	10000A	10000A
LG2647	100 A	400V~	right	300 mA	A	1000 A	1000 A	10000A	10000A
LG2649	25 A	400V~	right	500 mA	A	500 A	1000 A	10000A	10000A
LG2650	40 A	400V~	right	500 mA	A	500 A	1000 A	10000A	10000A
LG2651	63 A	400V~	right	500 mA	A	630 A	1000 A	10000A	10000A
LG2652	80 A	400V~	right	500 mA	A	800 A	1000 A	10000A	10000A
LG2653	100 A	400V~	right	500 mA	A	1000 A	1000 A	10000A	10000A
4030 04	25 A	400V~	left	30 mA	AC	500 A	1000 A	10000A	10000A
4030 05	40 A	400V~	left	30 mA	AC	500 A	1000 A	10000A	10000A
4030 06	63 A	400V~	left	30 mA	AC	630 A	1000 A	10000A	10000A
LG1268	80 A	400V~	left	30 mA	AC	800 A	1000 A	10000A	10000A
LG1269	100 A	400V~	left	30 mA	AC	1000 A	1000 A	10000A	10000A

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 10/09/2026

Signature: **Julien GAUTHIER**
Certification Officer

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES
SAS au Capital de 15.745.984 €
RCS Nanterre B 408 363 174
33 avenue du General Leclerc
F - 92266 FONTENAY AUX ROSES

Reference TX³ Latin series	In	Un	Neutral position	IΔn	Type	Im	IΔm	Inc	IΔc
LG2602	25 A	400V~	left	100 mA	AC	500 A	1000 A	10000A	10000A
LG2603	40 A	400V~	left	100 mA	AC	500 A	1000 A	10000A	10000A
LG2604	63 A	400V~	left	100 mA	AC	630 A	1000 A	10000A	10000A
LG2605	80 A	400V~	left	100 mA	AC	800 A	1000 A	10000A	10000A
LG2606	100 A	400V~	left	100 mA	AC	1000 A	1000 A	10000A	10000A
LG2608	25 A	400V~	left	300 mA	AC	500 A	1000 A	10000A	10000A
LG2609	40 A	400V~	left	300 mA	AC	500 A	1000 A	10000A	10000A
LG2610	63 A	400V~	left	300 mA	AC	630 A	1000 A	10000A	10000A
LG2611	80 A	400V~	left	300 mA	AC	800 A	1000 A	10000A	10000A
LG2612	100 A	400V~	left	300 mA	AC	1000 A	1000 A	10000A	10000A
LG2614	25 A	400V~	left	500 mA	AC	500 A	1000 A	10000A	10000A
LG2615	40 A	400V~	left	500 mA	AC	500 A	1000 A	10000A	10000A
LG2616	63 A	400V~	left	500 mA	AC	630 A	1000 A	10000A	10000A
LG2617	80 A	400V~	left	500 mA	AC	800 A	1000 A	10000A	10000A
LG2618	100 A	400V~	left	500 mA	AC	1000 A	1000 A	10000A	10000A

References RX³ series	In	Un	Neutral position	IΔn	Type	Im	IΔm	Inc	IΔc
4020 62	25 A	400V~	right	30 mA	AC	500 A	1000 A	10000A	10000A
4020 63	40 A	400V~	right	30 mA	AC	500 A	1000A	10000A	10000A
4020 64	63 A	400V~	right	30 mA	AC	630 A	1000 A	10000A	10000A
LG1282	80 A	400V~	right	30 mA	AC	800 A	1000 A	10000A	10000A
LG1283	100 A	400V~	right	30 mA	AC	1000 A	1000 A	10000A	10000A
4020 66	25 A	400V~	right	100 mA	AC	500 A	1000 A	10000A	10000A
4020 67	40 A	400V~	right	100 mA	AC	500 A	1000 A	10000A	10000A
4020 68	63 A	400V~	right	100 mA	AC	630 A	1000 A	10000A	10000A
LG1284	80 A	400V~	right	100 mA	AC	800 A	1000 A	10000A	10000A
LG1285	100 A	400V~	right	100 mA	AC	1000 A	1000 A	10000A	10000A
4020 70	25 A	400V~	right	300 mA	AC	500 A	1000 A	10000A	10000A
4020 71	40 A	400V~	right	300 mA	AC	500 A	1000 A	10000A	10000A
4020 72	63 A	400V~	right	300 mA	AC	630 A	1000 A	10000A	10000A
LG1286	80 A	400V~	right	300 mA	AC	800 A	1000 A	10000A	10000A
LG1287	100 A	400V~	right	300 mA	AC	1000 A	1000 A	10000A	10000A
LG2804	25 A	400V~	right	500 mA	AC	500 A	1000 A	10000A	10000A
LG2805	40 A	400V~	right	500 mA	AC	500 A	1000 A	10000A	10000A
LG2806	63 A	400V~	right	500 mA	AC	630 A	1000 A	10000A	10000A
LG2807	80 A	400V~	right	500 mA	AC	800 A	1000 A	10000A	10000A
LG2808	100 A	400V~	right	500 mA	AC	1000 A	1000 A	10000A	10000A
4020 74	25 A	400V~	right	30 mA	A	500 A	1000 A	10000A	10000A
4020 75 4025 39	40 A	400V~	right	30 mA	A	500 A	1000 A	10000A	10000A
4020 76 4025 40	63 A	400V~	right	30 mA	A	630 A	1000 A	10000A	10000A
LG1270	80 A	400V~	right	30 mA	A	800 A	1000 A	10000A	10000A
LG1271	100 A	400V~	right	30 mA	A	1000 A	1000 A	10000A	10000A
LG1272	25 A	400V~	right	100 mA	A	500 A	1000 A	10000A	10000A
LG1273	40 A	400V~	right	100 mA	A	500 A	1000 A	10000A	10000A
LG1274	63 A	400V~	right	100 mA	A	630 A	1000 A	10000A	10000A
LG1275	80 A	400V~	right	100 mA	A	800 A	1000 A	10000A	10000A
LG1276	100 A	400V~	right	100 mA	A	1000 A	1000 A	10000A	10000A

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 10/09/2026

Signature: **Julien GAUTHIER**
Certification Officer

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES
Capital de 15.745.984 €
RCS Nanterre B 408 363 174
33 avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSES

References RX³ series	In	Un	Neutral position	IΔn	Type	Im	IΔm	Inc	IΔc
LG1277	25 A	400V~	right	300 mA	A	500 A	1000 A	10000A	10000A
LG1278 4025 41	40 A	400V~	right	300 mA	A	500 A	1000 A	10000A	10000A
LG1279 4025 42	63 A	400V~	right	300 mA	A	630 A	1000 A	10000A	10000A
LG1280	80 A	400V~	right	300 mA	A	800 A	1000 A	10000A	10000A
LG1281	100 A	400V~	right	300 mA	A	1000 A	1000 A	10000A	10000A
LG2814	25 A	400V~	right	500 mA	A	500 A	1000 A	10000A	10000A
LG2815	40 A	400V~	right	500 mA	A	500 A	1000 A	10000A	10000A
LG2816	63 A	400V~	right	500 mA	A	630 A	1000 A	10000A	10000A
LG2817	80 A	400V~	right	500 mA	A	800 A	1000 A	10000A	10000A
LG2818	100 A	400V~	right	500 mA	A	1000 A	1000 A	10000A	10000A
4020 90	25 A	220/380V~	left	30 mA	AC	500 A	1000 A	10000A	10000A
4020 91	40 A	220/380V~	left	30 mA	AC	500 A	1000 A	10000A	10000A
4020 92	63 A	220/380V~	left	30 mA	AC	630 A	1000 A	10000A	10000A
LG1288	80 A	220/380V~	left	30 mA	AC	800 A	1000 A	10000A	10000A
LG1289	100 A	220/380V~	left	30 mA	AC	1000 A	1000 A	10000A	10000A

References DX³ series	In	Un	Neutral position	IΔn	Type	Im	IΔm	Inc	IΔc
4117 02	25 A	400V~	right	30 mA	AC	500 A	1000 A	10000A	10000A
4117 03	40 A	400V~	right	30 mA	AC	500 A	1000 A	10000A	10000A
4117 04	63 A	400V~	right	30 mA	AC	630 A	1000 A	10000A	10000A
4117 05	80 A	400V~	right	30 mA	AC	800 A	1000 A	10000A	10000A
LG992	100 A	400V~	right	30 mA	AC	1000 A	1000 A	10000A	10000A
4117 12	25 A	400V~	right	100 mA	AC	500 A	1000 A	10000A	10000A
4117 13	40 A	400V~	right	100 mA	AC	500 A	1000 A	10000A	10000A
4117 14	63 A	400V~	right	100 mA	AC	630 A	1000 A	10000A	10000A
4117 15	80 A	400V~	right	100 mA	AC	800 A	1000 A	10000A	10000A
LG993	100 A	400V~	right	100 mA	AC	1000 A	1000 A	10000A	10000A
4117 22	25 A	400V~	right	300 mA	AC	500 A	1000 A	10000A	10000A
4117 23	40 A	400V~	right	300 mA	AC	500 A	1000 A	10000A	10000A
4117 24	63 A	400V~	right	300 mA	AC	630 A	1000 A	10000A	10000A
4117 25	80 A	400V~	right	300 mA	AC	800 A	1000 A	10000A	10000A
LG994	100 A	400V~	right	300 mA	AC	1000 A	1000 A	10000A	10000A

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 10/09/2026

Signature: **Julien COUTHER**
Certification Officer

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES
S.A. au Capital de 15.745.984 €
RCS Nanterre B 408 363 174
33 avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSES

References DX³ series	In	Un	Neutral position	IΔn	Type	Im	IΔm	Inc	IΔc
4117 32	25 A	400V~	right	500 mA	AC	500 A	1000 A	10000A	10000A
4117 33	40 A	400V~	right	500 mA	AC	500 A	1000 A	10000A	10000A
4117 34	63 A	400V~	right	500 mA	AC	630 A	1000 A	10000A	10000A
4117 35	80 A	400V~	right	500 mA	AC	800 A	1000 A	10000A	10000A
LG995	100 A	400V~	right	500 mA	AC	1000 A	1000 A	10000A	10000A
4117 59	25 A	400V~	right	30 mA	A	500 A	1000 A	10000A	10000A
4117 60	40 A	400V~	right	30 mA	A	500 A	1000 A	10000A	10000A
4117 61	63 A	400V~	right	30 mA	A	630 A	1000 A	10000A	10000A
4117 62	80 A	400V~	right	30 mA	A	800 A	1000 A	10000A	10000A
4117 63	100 A	400V~	right	30 mA	A	1000 A	1000 A	10000A	10000A
4117 69	25 A	400V~	right	100 mA	A	500 A	1000 A	10000A	10000A
4117 70	40 A	400V~	right	100 mA	A	500 A	1000 A	10000A	10000A
4117 71	63 A	400V~	right	100 mA	A	630 A	1000 A	10000A	10000A
4117 72	80 A	400V~	right	100 mA	A	800 A	1000 A	10000A	10000A
4117 73	100 A	400V~	right	100 mA	A	1000 A	1000 A	10000A	10000A
4117 79	25 A	400V~	right	300 mA	A	500 A	1000 A	10000A	10000A
4117 80	40 A	400V~	right	300 mA	A	500 A	1000 A	10000A	10000A
4117 81	63 A	400V~	right	300 mA	A	630 A	1000 A	10000A	10000A
4117 82	80 A	400V~	right	300 mA	A	800 A	1000 A	10000A	10000A
4117 83	100 A	400V~	right	300 mA	A	1000 A	1000 A	10000A	10000A
4117 89	25 A	400V~	right	500 mA	A	500 A	1000 A	10000A	10000A
4117 90	40 A	400V~	right	500 mA	A	500 A	1000 A	10000A	10000A
4117 91	63 A	400V~	right	500 mA	A	630 A	1000 A	10000A	10000A
4117 92	80 A	400V~	right	500 mA	A	800 A	1000 A	10000A	10000A
4117 93	100 A	400V~	right	500 mA	A	1000 A	1000 A	10000A	10000A

References DX³ series	In	Un	Neutral position	IΔn	Type	Im	IΔm	Inc	IΔc
LG1118	25 A	400V~	right	100 mA	AC-S	500 A	1000 A	10000A	10000A
LG996	40 A	400V~	right	100 mA	AC-S	500 A	1000 A	10000A	10000A
LG997	63 A	400V~	right	100 mA	AC-S	630 A	1000 A	10000A	10000A
LG1119	80 A	400V~	right	100 mA	AC-S	800 A	1000 A	10000A	10000A
LG1120	100 A	400V~	right	100 mA	AC-S	1000 A	1000 A	10000A	10000A
LG1121	25 A	400V~	right	300 mA	AC-S	500 A	1000 A	10000A	10000A
4117 45	40 A	400V~	right	300 mA	AC-S	500 A	1000 A	10000A	10000A
4117 46	63 A	400V~	right	300 mA	AC-S	630 A	1000 A	10000A	10000A
LG1122	80 A	400V~	right	300 mA	AC-S	800 A	1000 A	10000A	10000A
LG1123	100 A	400V~	right	300 mA	AC-S	1000 A	1000 A	10000A	10000A
LG1124	25 A	400V~	right	500 mA	AC-S	500 A	1000 A	10000A	10000A
LG1125	40 A	400V~	right	500 mA	AC-S	500 A	1000 A	10000A	10000A
LG1126	63 A	400V~	right	500 mA	AC-S	630 A	1000 A	10000A	10000A
LG1127	80 A	400V~	right	500 mA	AC-S	800 A	1000 A	10000A	10000A
LG1128	100 A	400V~	right	500 mA	AC-S	1000 A	1000 A	10000A	10000A
LG1031	25 A	400V~	right	100 mA	A-S	500 A	1000 A	10000A	10000A
LG1032	40 A	400V~	right	100 mA	A-S	500 A	1000 A	10000A	10000A
LG1033	63 A	400V~	right	100 mA	A-S	630 A	1000 A	10000A	10000A
LG1034	80 A	400V~	right	100 mA	A-S	800 A	1000 A	10000A	10000A
LG1035	100 A	400V~	right	100 mA	A-S	1000 A	1000 A	10000A	10000A

References DX³ series	In	Un	Neutral position	IΔn	Type	Im	IΔm	Inc	IΔc
LG998	25 A	400V~	right	300 mA	A-S	500 A	1000 A	10000A	10000A
4118 00	40 A	400V~	right	300 mA	A-S	500 A	1000 A	10000A	10000A
4118 01	63 A	400V~	right	300 mA	A-S	630 A	1000 A	10000A	10000A
LG999	80 A	400V~	right	300 mA	A-S	800 A	1000 A	10000A	10000A
LG1000	100 A	400V~	right	300 mA	A-S	1000 A	1000 A	10000A	10000A
LG1001	25 A	400V~	right	500 mA	A-S	500 A	1000 A	10000A	10000A
LG1002	40 A	400V~	right	500 mA	A-S	500 A	1000 A	10000A	10000A
LG1003	63 A	400V~	right	500 mA	A-S	630 A	1000 A	10000A	10000A
LG1004	80 A	400V~	right	500 mA	A-S	800 A	1000 A	10000A	10000A
LG1005	100 A	400V~	right	500 mA	A-S	1000 A	1000 A	10000A	10000A
LG3181	25 A	400V~	right	30 mA	AC*	500 A	1000 A	10000A	10000A
LG3182	40 A	400V~	right	30 mA	AC*	500 A	1000 A	10000A	10000A
LG3183	63 A	400V~	right	30 mA	AC*	630 A	1000 A	10000A	10000A
LG3184	80 A	400V~	right	30 mA	AC*	800 A	1000 A	10000A	10000A
LG3185	100 A	400V~	right	30 mA	AC*	1000 A	1000 A	10000A	10000A
LG3187	25 A	400V~	right	100 mA	AC*	500 A	1000 A	10000A	10000A
LG3188	40 A	400V~	right	100 mA	AC*	500 A	1000 A	10000A	10000A
LG3189	63 A	400V~	right	100 mA	AC*	630 A	1000 A	10000A	10000A
LG3190	80 A	400V~	right	100 mA	AC*	800 A	1000 A	10000A	10000A
LG3191	100 A	400V~	right	100 mA	AC*	1000 A	1000 A	10000A	10000A
LG3193	25 A	400V~	right	300 mA	AC*	500 A	1000 A	10000A	10000A
LG3194	40 A	400V~	right	300 mA	AC*	500 A	1000 A	10000A	10000A
LG3195	63 A	400V~	right	300 mA	AC*	630 A	1000 A	10000A	10000A
LG3196	80 A	400V~	right	300 mA	AC*	800 A	1000 A	10000A	10000A
LG3197	100 A	400V~	right	300 mA	AC*	1000 A	1000 A	10000A	10000A

* RCCB's dedicated to Austria market

References DX³ series	In	Un	Neutral position	IΔn	Type	Im	IΔm	Inc	IΔc
4116 60	25 A	400V~	left	30 mA	AC	500 A	1000 A	10000A	10000A
4116 61	40 A	400V~	left	30 mA	AC	500 A	1000 A	10000A	10000A
4116 62	63 A	400V~	left	30 mA	AC	630 A	1000 A	10000A	10000A
4116 63	80 A	400V~	left	30 mA	AC	800 A	1000 A	10000A	10000A
LG1021	100 A	400V~	left	30 mA	AC	1000 A	1000 A	10000A	10000A
LG3102	25 A	400V~	left	100 mA	AC	500 A	1000 A	10000A	10000A
LG3103	40 A	400V~	left	100 mA	AC	500 A	1000 A	10000A	10000A
LG3104	63 A	400V~	left	100 mA	AC	630 A	1000 A	10000A	10000A
LG3105	80 A	400V~	left	100 mA	AC	800 A	1000 A	10000A	10000A
LG3106	100 A	400V~	left	100 mA	AC	1000 A	1000 A	10000A	10000A
4116 64	25 A	400V~	left	300 mA	AC	500 A	1000 A	10000A	10000A
4116 65	40 A	400V~	left	300 mA	AC	500 A	1000 A	10000A	10000A
4116 66	63 A	400V~	left	300 mA	AC	630 A	1000 A	10000A	10000A
4116 67	80 A	400V~	left	300 mA	AC	800 A	1000 A	10000A	10000A
LG1022	100 A	400V~	left	300 mA	AC	1000 A	1000 A	10000A	10000A
LG3109	25 A	400V~	left	500 mA	AC	500 A	1000 A	10000A	10000A
LG3110	40 A	400V~	left	500 mA	AC	500 A	1000 A	10000A	10000A
LG3111	63 A	400V~	left	500 mA	AC	630 A	1000 A	10000A	10000A
LG3112	80 A	400V~	left	500 mA	AC	800 A	1000 A	10000A	10000A
LG3113	100 A	400V~	left	500 mA	AC	1000 A	1000 A	10000A	10000A
4116 74	25 A	400V~	left	30 mA	A	500 A	1000 A	10000A	10000A
4116 75	40 A	400V~	left	30 mA	A	500 A	1000 A	10000A	10000A
4116 76	63 A	400V~	left	30 mA	A	630 A	1000 A	10000A	10000A
4116 77	80 A	400V~	left	30 mA	A	800 A	1000 A	10000A	10000A
4116 78	100 A	400V~	left	30 mA	A	1000 A	1000 A	10000A	10000A
LG3129	25 A	400V~	left	100 mA	A	500 A	1000 A	10000A	10000A
LG3130	40 A	400V~	left	100 mA	A	500 A	1000 A	10000A	10000A
LG3131	63 A	400V~	left	100 mA	A	630 A	1000 A	10000A	10000A
LG3132	80 A	400V~	left	100 mA	A	800 A	1000 A	10000A	10000A
LG3133	100 A	400V~	left	100 mA	A	1000 A	1000 A	10000A	10000A

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 10/09/2026

Signature: **Julien GAUTHIER**
Certification Officer

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES
SARL au capital de 15.745.984 €
RCS Nanterre B 408 363 174
33 avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSES

References DX³ series	In	Un	Neutral position	IΔn	Type	Im	IΔm	Inc	IΔc
4116 84	25 A	400V~	left	300 mA	A	500 A	1000 A	10000A	10000A
4116 85	40 A	400V~	left	300 mA	A	500 A	1000 A	10000A	10000A
4116 86	63 A	400V~	left	300 mA	A	630 A	1000 A	10000A	10000A
4116 87	80 A	400V~	left	300 mA	A	800 A	1000 A	10000A	10000A
4116 88	100 A	400V~	left	300 mA	A	1000 A	1000 A	10000A	10000A
LG3136	25 A	400V~	left	500 mA	A	500 A	1000 A	10000A	10000A
LG3137	40 A	400V~	left	500 mA	A	500 A	1000 A	10000A	10000A
LG3138	63 A	400V~	left	500 mA	A	630 A	1000 A	10000A	10000A
LG3139	80 A	400V~	left	500 mA	A	800 A	1000 A	10000A	10000A
LG3140	100 A	400V~	left	500 mA	A	1000 A	1000 A	10000A	10000A
LG3115	25 A	400V~	left	100 mA	AC-S	500 A	1000 A	10000A	10000A
LG3116	40 A	400V~	left	100 mA	AC-S	500 A	1000 A	10000A	10000A
LG3117	63 A	400V~	left	100 mA	AC-S	630 A	1000 A	10000A	10000A
LG3118	80 A	400V~	left	100 mA	AC-S	800 A	1000 A	10000A	10000A
LG3119	100 A	400V~	left	100 mA	AC-S	1000 A	1000 A	10000A	10000A
LG1129	25 A	400V~	left	300 mA	AC-S	500 A	1000 A	10000A	10000A
4116 68	40 A	400V~	left	300 mA	AC-S	500 A	1000 A	10000A	10000A
4116 69	63 A	400V~	left	300 mA	AC-S	630 A	1000 A	10000A	10000A
LG1130	80 A	400V~	left	300 mA	AC-S	800 A	1000 A	10000A	10000A
LG1131	100 A	400V~	left	300 mA	AC-S	1000 A	1000 A	10000A	10000A
LG3122	25 A	400V~	left	500 mA	AC-S	500 A	1000 A	10000A	10000A
LG3123	40 A	400V~	left	500 mA	AC-S	500 A	1000 A	10000A	10000A
LG3124	63 A	400V~	left	500 mA	AC-S	630 A	1000 A	10000A	10000A
LG3125	80 A	400V~	left	500 mA	AC-S	800 A	1000 A	10000A	10000A
LG3126	100 A	400V~	left	500 mA	AC-S	1000 A	1000 A	10000A	10000A
LG3252	25 A	220/380V~	left	30 mA	AC	500 A	1000 A	10000A	10000A
LG3253	40 A	220/380V~	left	30 mA	AC	500 A	1000 A	10000A	10000A
LG3254	63 A	220/380V~	left	30 mA	AC	630 A	1000 A	10000A	10000A
LG3255	80 A	220/380V~	left	30 mA	AC	800 A	1000 A	10000A	10000A
LG3256	100 A	220/380V~	left	30 mA	AC	1000 A	1000 A	10000A	10000A

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 10/09/2026

Signature: **Julien GAUTHIER**
Certification officer

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES
S.A.S. au capital de 15.745.984 €
RCS Nanterre B 408 363 174
33 avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSES

References DX³ series	In	Un	Neutral position	IΔn	Type	Im	IΔm	Inc	IΔc
LG3258	25 A	220/380V~	left	300 mA	AC	500 A	1000 A	10000A	10000A
LG3259	40 A	220/380V~	left	300 mA	AC	500 A	1000 A	10000A	10000A
LG3260	63 A	220/380V~	left	300 mA	AC	630 A	1000 A	10000A	10000A
LG3261	80 A	220/380V~	left	300 mA	AC	800 A	1000 A	10000A	10000A
LG3262	100 A	220/380V~	left	300 mA	AC	1000 A	1000 A	10000A	10000A

References DX³ series	In	Un	Neutral position	IΔn	Type	Im	IΔm	Inc	IΔc
4118 32	25 A	220/380V~	left	30 mA	A	500 A	1000 A	10000A	10000A
4118 33	40 A	220/380V~	left	30 mA	A	500 A	1000 A	10000A	10000A
4118 34	63 A	220/380V~	left	30 mA	A	630 A	1000 A	10000A	10000A
4118 35	80 A	220/380V~	left	30 mA	A	800 A	1000 A	10000A	10000A
4118 36	100 A	220/380V~	left	30 mA	A	1000 A	1000 A	10000A	10000A
4118 37	25 A	220/380V~	left	300 mA	A	500 A	1000 A	10000A	10000A
4118 38	40 A	220/380V~	left	300 mA	A	500 A	1000 A	10000A	10000A
4118 39	63 A	220/380V~	left	300 mA	A	630 A	1000 A	10000A	10000A
4118 40	80 A	220/380V~	left	300 mA	A	800 A	1000 A	10000A	10000A
4118 41	100 A	220/380V~	left	300 mA	A	1000 A	1000 A	10000A	10000A

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 10/09/2026

Signature: **Julien GAUTHIER**
Certification Officer

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre B 408 363 174
33 Avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSES

Independent of line voltage :	yes
Rated voltage (V)	400 V and 220/380V (for dual voltage products)
Rated current (A)	25A – 40A – 63A – 80A – 100A
Rated frequency : (Hz)	50 Hz
Delay time	without or with S
Nature of supply :	~
Total number of poles :	4
Rated residual operating current (A)	0.030A, 0.100A, 0.300A, 0.500A
Rated insulation voltage Ui : (V)	500 V~
Rated impulse withstand voltage Uimp : (V)	4 000 V
Utilisation range temperature : (°C)	-25 °C à/to +40 °C
Rated residual making and breaking capacity IΔm : (A)	1 000 A
Rated conditional short-circuit current Inc : (A)	10 000 A
Rated conditional residual short-circuit current IΔc : (A)	10 000 A
Short-circuit tests :	35mm
Protection against external influences :	enclosed
Protection degree :	IP20
Material group :	II
Method of mounting :	panel board – on rail
Not associated with the mechanical-mounting	
Type of terminals :	pillar terminals