

产品认证证书

II型自愿认证

证书编号: CQC2013010307650261

发证日期: 2021 年 11 月 23 日

有效期至: 2031 年 11 月 23 日

委托人名称 ABB 新会低压开关有限公司
及注册地址 广东省江门市新会区今古洲工业开发区

制造商名称 ABB 新会低压开关有限公司
及注册地址 广东省江门市新会区今古洲工业开发区

生产企业名称 ABB 新会低压开关有限公司
及生产地址 广东省江门市新会区今古洲工业开发区

产品名称和系列、规格、型号 塑料外壳式断路器
XT3C 250,XT3N 250,XT3S 250,UT3C 250,UT3N 250,UT3S 250; 规格参数详见附件

产品标准和技术要求 GB/T 14048.2-2020

认证模式 产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。

本证书为变更证书, 证书首次颁发日期: 2020 年 08 月 14 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站 (www.cnca.gov.cn) 查验证书信息



授权签字人

刘江

签发

谢肇煦

中国质量认证中心



<http://www.cqc.com.cn>

中国·北京·南四环西路188号9区 100070

电话: +86 10 83886666

C(2) 0121356

CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2013010307650261

Valid from: Nov.23,2021

Valid until:Nov.23,2031

**NAME AND REGISTERED
ADDRESS OF THE APPLICANT**

ABB Xinhui Low Voltage Switchgear Co.,Ltd.
Jinguzhou Industrial Development Zone, Xinhui District, Jiangmen City, Guangdong Province,
P.R.China

**NAME AND REGISTERED
ADDRESS OF THE
MANUFACTURER**

ABB Xinhui Low Voltage Switchgear Co.,Ltd.
Jinguzhou Industrial Development Zone, Xinhui District, Jiangmen City, Guangdong Province,
P.R.China

**NAME AND LOCATION
OF THE FACTORY**

ABB Xinhui Low Voltage Switchgear Co.,Ltd.
Jinguzhou Industrial Development Zone Xinhui Region, Jiangmen City, Guangdong Province,
P.R.China

**PRODUCT NAME, MODEL
AND SPECIFICATION**

Moulded Case Circuit-breaker
XT3C 250, XT3N 250, XT3S 250, UT3C 250, UT3N 250, UT3S 250; See the Appendix

**THE STANDARDS AND
TECHNICAL REQUIREMENTS
FOR THE PRODUCTS**

GB/T 14048.2-2020

**TYPE OF CERTIFICATION
SCHEMES**

Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

Date of original issued: Aug.14,2020

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

刘江

SIGNATURE

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE



产品认证证书

II型自愿认证

证书编号: CQC2013010307650261

第 1 页 共 2 页

本证书及附件应同时使用, 信息查验说明见证书页

纸号: 121356

上报参数:

XT3C, XT3N, XT3S, XT3H, UT3C, UT3N, UT3S, UT3H

Uimp : 8kV ;

Ui : 800V ;

Ue : XT3: 220/230/240VAC, 380VAC, 415VAC, 660/690VAC, 250VDC, 500VDC;

UT3: 220/230/240VAC, 380VAC, 415VAC, 660/690VAC ;

In : 100A , 125A , 160A , 200A(MA) ;

63A , 80A , 100A , 125A , 160A , 200A , 250A(TMD , TMG) ;

XT3C :

415VAC , 250VDC , 500VDC : Ics=Icu=25kA ; 660/690VAC : Ics=3Ka, Icu=4kA ;

XT3N :

220/230/240VAC : Ics=Icu=50kA ; 380VAC , 415VAC , 250VDC , 500VDC : Ics=Icu=36kA ;

660/690VAC : Ics=3kA , Icu=5kA ;

XT3S :

220/230/240VAC : Ics=50kA, Icu=85kA ; 380VAC : Ics=Icu=50kA ;

415VAC : Ics=36kA, Icu=50kA ; 250VDC , 500VDC : Ics=38kA , Icu=50kA ;

660/690VAC : Ics=3kA , Icu=6kA ;

XT3H :

220/230/240VAC : Ics=50kA, Icu=100kA ;

380VAC, 415VAC, 250ADC : Ics=36kA , Icu=70kA ;

UT3C :

415VAC : Ics=Icu=25kA ; 660/690VAC : Ics=3kA, Icu=4kA ;

UT3N :

220/230/240VAC : Ics=Icu=50kA ; 380VAC , 415VAC : Ics=Icu=36kA ;

660/690VAC : Ics=3kA , Icu=5kA ;

UT3S :

220/230/240VAC : Ics=50kA, Icu=85kA ; 380VAC : Ics=Icu=50kA ;

415VAC : Ics=36kA , Icu=50kA ; 660/690VAC : Ics=3kA , Icu=6kA ;


UT3H :

220/230/240VAC : Ics=50kA , Icu=100kA ; 380VAC, 415VAC : Ics=36kA , Icu=70kA ;

使用类别: A ;



中国质量认证中心



产品认证证书

II型自愿认证

证书编号: CQC2013010307650261

第 2 页 共 2 页

本证书及附件应同时使用, 信息查验说明见证书页

纸号: 121356

过电流脱扣器类型: 热磁式, 单磁式;

适用隔离;

适用频率: 50/60Hz;

极数: 3P, 4P;

符合附录 N 的电子附件: 带电子电路的辅助元件名称: 欠压脱扣器;

带电子电路的辅助元件额定电源电压: 24-30VAC/DC, 48VAC/DC, 60VAC/DC,

110-127VAC/110-125VDC, 220-240VAC/220-250VDC, 380-440VAC, 480-525VAC

型号解释:

Tmax 系列塑壳断路器

XT3 □ 250

1 2 3

1、断路器设计序号 Frame size: XT3

2、额定极限短路分断能力代号 Breaking level: C, N, S, H

3、框架电流 (A) Rated current: 250

UT3 □ 250

1 2 3

1、断路器设计序号 Frame size: UT3

2、额定极限短路分断能力代号 Breaking level: C, N, S, H

3、框架电流 (A) Rated current: 250



中国质量认证中心

