

# ATTESTATION OF CONFORMITY

Issued to: EATON; CEAG Notlichtsysteme GmbH  
Senator-Schwartz-Ring 26  
59494 Soest  
Germany

For the product: Phase monitoring unit

Type/Model: 3-PM; 3-PM-IO; 3-PM-IO-INV

Trade name: EATON; EATON CEAG; EATON JSB; EATON Menvier

Ratings: 3-PM-IO (3-PM-IO-INV): 24Vdc, 20mA  
3-PM: 230 Vac, 50/60Hz, 10 mA

Manufactured by: EATON; CEAG Notlichtsysteme GmbH  
Senator-Schwartz-Ring 26  
59494 Soest  
Germany

Requirements: IEC 62368-1:2014

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in a test report no 2230796.50.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Arnhem, 20 September 2019

Number: 2230796.01-AOC

DEKRA Certification B.V.



A.C. Slingerland  
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed