

CERTIFICATE

Issued to:
Applicant:
Niko N.V.
Industriepark West 40
9100 Sint-Niklaas, Belgium

Licensee:
Niko N.V.
Industriepark West 40
9100 Sint-Niklaas, Belgium

Product : two-pole socket-outlets with side earthing contacts
Trade name(s) : NIKO
Type(s)/model(s) : -3.1+7XX-368XX-IP44 and -3.3+7XX-368XX-IP44

The product and any acceptable variation thereof as specified in the Annex to this certificate and the documents referred to therein.

DEKRA hereby declares that the above-mentioned product has been certified based on:

- a type test according to IEC 60884-1:2022, DIN VDE 0620-1:2021-02 and OVE E 8684-1:2021-12
- an inspection of the factory location according to CENELEC Operational Document CIG 021
- a DEKRA certification agreement with the number 6069948


DEKRA hereby grants the right to use the DEKRA Mark.

The DEKRA Mark may be applied to the product as specified in this certificate for the duration and under the conditions of the DEKRA Mark certification agreement.

This certificate is issued on 5 November 2025 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 71-166704

DEKRA Certification B.V.



B.T.M. Holtus
Managing Director



Miranda Zhou
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



71-166704

DEKRA Mark is the new KEMA-KEUR

The DEKRA Mark certificate for this product is to all intents and purposes equivalent to a KEMA-KEUR certificate, the other certification mark used by DEKRA and should be valued and used as such. DEKRA Mark is gradually replacing KEMA-KEUR.

For more information please check: [Introducing DEKRA Mark](#)

SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: two-pole socket-outlets with side earthing contacts
Trade name(s)	: NIKO
Type(s)/model(s)	: -3.1+7XX-368XX-IP44 and -3.3+7XX-368XX-IP44
Rated current	: 16 A
Rated voltage	: 250 V~
Degree of protection	: IP44
Method of mounting	: surface-type, flush-type
Existence of shutters	: with shutters
Standard sheet	: III of CEE 7
Cover	: made of thermoplastic material
Program	: HYDRO
Markings	: - trade name, series indication and electrical ratings on the base - trade name and suffix for the cover on this part

Product data – type -3.1+7XX-368XX-IP44

Terminals : screw-type terminals

Product data – type -3.3+7XX-368XX-IP44

Terminals : screwless-type terminals

TESTS**Test requirements**

IEC 60884-1:2022

DIN VDE 0620-1:2021-02

OVE E 8684-1:2021-12

Test result

The test results are documented in DEKRA test file 230190000.

Conclusion

The examination has confirmed that all requirements were met.

Factory location

Niko N.V.

Industriepark West 40

9100 Sint-Niklaas, Belgium

Mounting boxes

7XX-83101: surface mounting box for 1 function with membranes
7XX-83201: vertical surface mounting box for 2 functions with membranes
7XX-84101: surface mounting box for 1 function with 1 M20 entry
7XX-84111: surface mounting box for 1 function with 2x1 M20 entries
7XX-84102: surface mounting box for 1 function with 1x2 M20 entries
7XX-84112: surface mounting box for 1 function with 1x2 M20 entries + 1 M20 entry
7XX-84201: vertical surface mounting box for 2 functions with 1 M20 entry
7XX-84211: vertical surface mounting box for 2 functions with 2x1 M20 entries
7XX-84202: vertical surface mounting box for 2 functions with 1x2 M20 entries
7XX-84212: vertical surface mounting box for 2 functions with 1x2 M20 entries+ 1 M20 entry
7XX-84302: vertical surface mounting box for 3 functions with 2x1 M20 entries
7XX-84801: horizontal surface mounting box for 2 functions with 1 M20 entry
7XX-84802: horizontal surface mounting box for 2 functions with 1x2 M20 entries
7XX-84902: horizontal surface mounting box for 3 functions with 1x2 M20 entries
7XX-73000: flush mounting box for 1 function
7XX-74000: vertical flush mounting box for 2 functions
7XX-75000: horizontal flush mounting box for 2 functions

7XX can refer to the following colours:

700: grey
701: white
761: black