



# 产品认证证书

证书编号: CQC2011010304468089

II 型自愿认证

申请人名称及地址

ABB AB, Control Products  
Motorgrand 20, 72161 Vasteras, Sweden

制造商名称及地址

ABB AB, Control Products  
Motorgrand 20, 72161 Vasteras, Sweden

生产企业名称及地址

ABB AB, Control Products (V054504)  
Motorgrand 20, 72161 Vasteras, Sweden

产品名称和系列、规格、型号

软起动器

PSE142-600-70, PSE170-600-70; 详细参数及型号解释见附件

产品标准和技术要求

GB/T 14048.6-2016

认证模式

型式试验+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。

发证日期: 2020 年 12 月 04 日 有效期至: 2030 年 12 月 04 日  
证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2020 年 08 月 28 日

主任: \_\_\_\_\_

陆楠



## 中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

C 0433972



# PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2011010304468089

Type II CQC Certification

## NAME AND ADDRESS OF THE APPLICANT

ABB AB, Control Products  
Motorgrand 20, 72161 Vasteras, Sweden

## NAME AND ADDRESS OF THE MANUFACTURER

ABB AB, Control Products  
Motorgrand 20, 72161 Vasteras, Sweden

## NAME AND ADDRESS OF THE FACTORY

ABB AB, Control Products (V054504)  
Motorgrand 20, 72161 Vasteras, Sweden

## PRODUCT NAME, MODEL AND SPECIFICATION

Soft Starter  
PSE142-600-70, PSE170-600-70; See the appendix

## THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.6-2016

## TYPE OF CERTIFICATION SCHEMES

Type testing+Follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020 .

Valid from: Dec.04,2020

Valid until: Dec.04,2030

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Aug.28,2020

President: \_\_\_\_\_

Lu Mei



## CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China  
<http://www.cqc.com.cn>

C 0433972



# 产品认证证书

附录

第 1 页 共 2 页

证书编号: CQC2011010304468089

纸号: 433972

PSE142-600-70, PSE170-600-70

额定绝缘电压( $U_i$ ): 600V;

约定发热电流( $I_{th}$ ): 171A;

额定工作电压( $U_e$ ): AC220-500V;

额定工作电流( $I_e$ ): 143A, 171A;

额定功率( $P_e$ ):

Type	$I_e$ (A)	Power(kW)			
		220-230V	380-400V	500V	690V
PSE142-600-70	143	40	75	90	-
PSE170-600-70	171	45	90	110	-

使用类别: AC-53a;

极数: 3P

注: 此附录与证书同时使用时有效。

主任: \_\_\_\_\_

陆梅



## 中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>



# 产品认证证书

附录

第 2 页 共 2 页

证书编号: CQC2011010304468089

纸号: 433972

型号解释:

PSE 170 - 600 - 70

1    2    3    4

1 = Softstarter, name of series

2 = Current rating, Ie: 143A, 171A

3 = Operational voltage, Ue: 600V

4 = Control supply voltage, Us: 70 = 100 - 250VAC

注: 此附录与证书同时使用时有效。

主任: \_\_\_\_\_

陆梅



## 中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>