



TYPE APPROVAL CERTIFICATE

Certificate no.:
TAE0000087
Revision No:
3

This is to certify:
that the Motor Starter

with type designation(s)
PSTX

issued to
ABB Electrification Sweden AB, Motor Starting & Safety
Västerås, Sweden

is found to comply with
DNV rules for classification – Ships, offshore units, and high speed and light craft

Application:

Products approved by this certificate are accepted for installation on all vessels classed by DNV.

Rated voltage (V) 690 V AC
Rated current (A) 30 - 1250
Frequency (Hz) 50 - 60

Issued at **Høvik** on **2024-07-04**

This Certificate is valid until **2029-06-29**.

for **DNV**

DNV local unit: **Sweden CMC**

Approval Engineer: **Ivar Bull**

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



Name and place of manufacturer

ABB AB, Control Products Västerås, Sweden	ABB Xinhui Low Voltage Switchgear Co. Ltd Xinhui, China
--	--

Product description

Type	Rated operation voltage Ue (V)	Rated insulation voltage Ui (V)	Rated impulse voltage Uimp (kV)	Rated operation current Ie (A)*	Rated power at 400 V Pe (kW)*	Rated conditionals short-circuit current Iq (kA)
PSTX 30	220 – 690	690 V	8	9 - 30	15	80
PSTX 37				11.1 - 37	18.5	
PSTX 45				13.5 - 45	22	
PSTX 60				18 - 60	30	
PSTX 72				21.6 - 72	37	
PSTX 85				25.5 - 85	45	
PSTX 105				31.8 - 106	55	
PSTX 142				42.9 - 143	75	
PSTX 170				51.3 - 171	90	
PSTX 210				63 - 210	110	
PSTX 250				75 - 250	132	
PSTX 300				90 - 300	160	
PSTX 370				111 - 370	200	
PSTX 470				141 - 470	250	
PSTX 570				171 - 570	315	
PSTX 720				216 - 720	400	
PSTX 840				252 - 840	450	
PSTX 1050	315 - 1050	560				
PSTX 1250	375 - 1250	710				

* Normal starts, class 10

Application/Limitation

For installations inside switchboards / enclosures onboard ships and offshore units.

Type Approval documentation

Tests carried out

Type tests in accordance with IEC 60947-4-2. EMC Tests, Inclination test, Vibration test, Insulation resistance test, Damp heat test, Dry heat test, Low temperature test and high voltage test

Marking of product

ABB – Type designation – Rated voltage – Rated current - Breaking capacity.

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the type approval is complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Production Sample Tests (PST) and Routines (RT) checked (if not available tests according to PST and RT to be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.



Job ID: **262.1-018459-5**
Certificate no.: **TAE0000087**
Revision No: **3**

Assessment to be performed at 2 and 3.5 year and at renewal.

END OF CERTIFICATE