

Dichiarazione di carico

Declaration of load

Noi:
We:

Ideal Standard International NV
Corporate Village – Gent Building
Da Vincilaan 2,
1935 Zaventem,
Belgium

Dichiariamo sotto la nostra responsabilità:
Declare under our responsibility:

Per il codice prodotto (codice di identificazione):
For product number (identification code):

- R014367 PROSYS FRAME 1100 WC 80 M - Frame OLI74 S90;
- R009067 PROSYS FRAME 820 DRY WC 150 CL1 - Frame 820 Expert;
- R014667 PROSYS LIGHT FRAME WC 80 - Simflex with plastic links;
- R009567 PROSYS FRAME 1100 DRY WC 120 3H FXG CL1

Sono stati testate con un carico di $(4,00 \pm 0,05 \text{ kN})$ secondo il test descritto in EN 997:2012 Art. 5.7.4
Have been tested with a load of $(4,00 \pm 0,05 \text{ kN})$ according to the test described into EN 997:2012 Clause 5.7.4

Come indicato nei test report :
As indicated on test reports :

OLI-Ideal Standard Load Test - Elongated WC Bowl + Frame OLI74 S90 dated 12-04-2019 issued by supplier;
OLI-Ideal Standard Load Test - Elongated WC Bowl + Frame 820 dated 27/03/2019 issued by supplier;
Wet frame load test dated 25-07-2018 issued by supplier;
OLI-Ideal Standard Load Test - Elongated WC Bowl + Three Positions Frame (minimum and maximum height Position) dated 12-04-2019;

12.10.2022

VP Sanitary Ware Category

Emmanuel Veillon



Dichiarazione di carico load test_Toilets Frame



Ideal Standard