

Presence detector
353-651421-1



EN Presence detector P48MR, DALI-2, master, 12-13 m, 360°, for flush mounting (SnapFit), WAGO WINSTA® MIDI 2 m cable with 5-pol. connector

NL Aanwezigheidsmelder P48MR, DALI-2, master, 12-13 m, 360°, voor inbouw (SnapFit), WAGO WINSTA® MIDI 2 m kabel met 5-polige connector

FR Détecteur de présence P48MR, DALI-2, maître, 12-13 m, 360°, à encastrer (SnapFit), câble WAGO WINSTA® MIDI de 2 m avec connecteur à 5 pôles

DE Präsenzmelder P48MR, DALI-2, Master, 12-13 m, 360°, für Deckeneinbau (SnapFit), WAGO WINSTA® MIDI 2 m Kabel mit 5-poligem Stecker

DK Tilstedeværelsessensor P48MR, DALI-2, master, 12-13 m, 360°, planforsænket (SnapFit), WAGO WINSTA® MIDI 2 m kabel med 5-pol stik

SE Närvarosensor P48MR, DALI-2, master, 12-13 m, 360°, för infälld montering (SnapFit), WAGO WINSTA® MIDI 2 m kabel med 5-poliga kontakter

NO Tilstedeværelsessensor P48MR, DALI-2, master, 12-13 m, 360°, til innfelt montering (SnapFit), WAGO WINSTA® MIDI 2 m kabel med 5-polet kontakt

IT Rilevatore di presenza P48MR, DALI-2, master, 12-13 m, 360°, per montaggio a incasso (SnapFit), WAGO WINSTA® MIDI cavo da 2 m con connettore a 5 poli

PL Czujnik obecności P48MR, DALI-2, nadrzędny, 12-13 m, 360°, do montażu podtynkowego (SnapFit), kabel 2 m ze złączami 5-biegunowymi WAGO WINSTA® MIDI

SK Detektor prítomnosti P48MR, DALI-2, master, 12-13 m, 360°, na zapustenú montáž (SnapFit), WAGO WINSTA® MIDI 2 m kábel s 5-pólovým konektorom


Wiring

Aansluitschema / Schéma de raccordement / Verdrahtung / Tilslutningsskema / Kopplingsschema / Ledningstilkopling / Cablaggio / Okablowanie / Instalácia

! This product must be secured with a miniature circuit breaker (MCB) of max. 16 A in the electrical cabinet. The MCB rating is limited by national installation rules.


! DALI power – OFF

- * WAGO WINSTA® mounting plate, 770-625
- ** WAGO WINSTA® distribution connector, 770-618






Installation


Instalatie / Installation / Installation / Installation / Installation / Installasjon / Installazione / Instalacja / Instalácia




NOT REMOVABLE
(fixed ceiling)






OR





REMOVABLE
(suspended ceiling)



OR




4 **!** DALI power – OFF



* optional

Detection area

Detectiebereik / Portée de détection / Erfassungsbereich / Rækkevidde / Detekteringsområde / Overvåkningsområde / Campo di rilevamento / Obszar wykrywania / Oblast' snimania




H	A Walking	B Across	C Towards	D Presence
2.5 m	 $\varnothing$ 13 m	 $\varnothing$ 11 m	 $\varnothing$ 3 m	 $\varnothing$ 5 m
3.0 m	$\varnothing$ 12 m	$\varnothing$ 12 m	$\varnothing$ 3 m	$\varnothing$ 5 m

Measured according to EN/IEC63180



Dimensions

Afmetingen / Dimensions / Abmessungen / Dimensioner / Mått / Dimensioner / Dimensioni / Wymiary / Rozmery



Specifications

Specificaties / Specifications / Spezifikationen / Specifikationer / Specifikationer / Spesifikasjoner / Specifiche /
Specyfikacje / Technické údaje


Installation	DALI-2
Configuration	master / standalone
Mounting height	2 – 3.5 m
Wire capacity	1.5 / 2.5 mm ²
Input voltage	230 Vac ± 10 %, 50 Hz
Operating frequency	2.4 GHz
Maximum power consumption	0.6 W
Maximum voltage on the DALI bus	15 Vdc
Maximum supply current*	250 mA
Maximum guaranteed current on the DALI bus	200 mA
Maximum startup time DALI	< 1200 ms
Maximum PIR detection startup time	70 s
Maximum number of control gear on the DALI bus	64
Maximum number of dimmable zones	4
Maximum radio frequency power	-2 dBm
Ambient temperature	-25 – +40 °C
Protection degree	IP20
Impact resistance	IK02
Halogen free	yes
Marking	CE
Cable specifications	
Cable colour	black
Length	2 m
Wire cross-section	1.5 mm ²
Voltage	400 V
Rated current	16 A
Halogen free	yes
Ambient temperature	-5 – +40 °C
Type of connector	male, 5-pole, blue
Fire class CPR	En

App settings & more info

App-instellingen / Réglages de l'appli / App-Einstellungen / App indstillinger / Appnställningar / App-innstillinger / Impostazioni dell'app / Ustawienia aplikacji / Nastavenia aplikácie



DAI power – ON



The specific hardware manual for this product is available in multiple languages on guide.niko.eu

LED behaviour

Ledgedrag / Comportement des LED / LED-Verhalten / LED funktioner / LED-funktioner / LED-funksjon / Comportamento del LED / Zachowanie LED / LED signalizácia



DAI power – ON

Green LED continuous on		Connection OK	More info**:  detector tool
Green LED breathing		Connection OK, overrule ON	
Green LED flashing		Warming up*	
Red LED continuous on		Error	
Red LED flashing		Warning	
Blue LED flashing		Walk test active	

* When Bluetooth® communication is disabled, the green LED does not flash while warming up.

** More info / Meer informatie / Plus d'info / Mehr Info / Mere info / Mer information / Mer info /
Ulteriori info / Wiecej informacji / Viac informácií

Support & contact

nv Niko sa
Industriepark West 40
9100 Sint-Niklaas, Belgium

www.niko.eu

EN	+32 3 778 90 80	support@niko.eu
NL	België: +32 3 778 90 80	support.be@niko.eu
	Nederland: +31 880 15 96 10	support.nl@niko.eu
FR	Belgique: +32 3 778 90 80	support.be@niko.eu
	France: +33 820 20 66 25	support.fr@niko.eu
	Suisse: +41 44 878 22 22	support.ch@niko.eu
DE	Deutschland: +49 7623 96697-0	support.de@niko.eu
	Schweiz: +41 44 878 22 22	support.ch@niko.eu
	Österreich: +43 1 7965514	support.at@niko.eu
	Belgien: +32 3 778 90 80	support.be@niko.eu
DK	+45 74 42 47 26	support.dk@niko.eu
SE	+46 8 410 200 15	support.se@niko.eu
NO	+47 66 77 57 50	support.no@niko.eu
IT	+41 44 878 22 22	support.ch@niko.eu
PL	+48 509 378 373	support.pl@niko.eu
SK	+421 2 63 825 155	support.sk@niko.eu

Niko prepares its manuals with the greatest care and strives to make them as complete, correct and up to date as possible. Nevertheless, some deficiencies may subsist. Niko cannot be held responsible for this, other than within the legal limits. Please inform us of any deficiencies in the manuals by contacting Niko customer services at support@niko.eu

* It is not permitted to connect additional DALI power supplies to the DALI bus of the DALI-2 master detectors.