



PHOTOMETRIC LIGHT REPORT

**Spot | black | cut out Ø68-
73mm | 6W | 3000K | dim**

Article number: 136-103



Go to the
webshop
of Tronix
Lighting



TRONIX



136-103 Spot | black | cut out Ø68-73mm | 6W | 3000K | dim

Introduction

Purpose of this Document

This document provides accurate and objective photometric data for Tronix Lighting item 136-103. All information is based on actual measurements taken from standard production units. No modifications were made to enhance performance results. In some cases, minor adjustments—such as temporary removal of covers, cables, or mounting features—were necessary for testing purposes. These did not influence product performance.

Test Methodology

Testing was conducted using randomly selected, unopened samples from regular inventory. All tests comply with the LM-79-19 standard, the recognized method for photometric and electrical measurements of LED and OLED luminaires. This standard, an update of IES LM-79-2008, outlines environmental test conditions, stabilization procedures, measurement methods, and approved instruments. It uses absolute photometry, meaning results directly reflect the performance of the tested product, without comparison to rated lamp standards.

Product 136-103 was tested using:

- A photogoniometer to measure luminous intensity distribution at various angles
- An integrating sphere to determine total luminous flux and colour characteristics

Compliance & Certification

Item 136-103 meets the requirements of the following EU directives. Tronix Lighting certifies that all relevant tests were executed in accordance with the applicable standards, and the CE mark is applied accordingly:

- General Product Safety – Directive 2023/988/EC
- Low Voltage Directive (LVD) – Directive 2014/35/EU
- Electromagnetic Compatibility (EMC) – Directive 2004/108/EC
- Ecodesign – Directive 2009/125/EC
- RoHS 3 – Directive 2011/65/EU + Amendment 2015/863/EU

Recycling & Sustainability

Tronix Lighting is affiliated with national recycling systems for electrical and electronic waste. The luminaire is over 90% recyclable when disposed of as electronic waste at end of life. In addition, Tronix Lighting participates in national packaging recycling schemes, ensuring full compliance with both the WEEE and packaging directives.



136-103 Spot | black | cut out Ø68-73mm | 6W | 3000K | dim

Laboratory and equipment

Laboratory owner and location	Tronix Lighting BV. Uden. The Netherlands
Gonio spectrometer system and type	Viso Systems Type C. horizontal
Spectrometer manufacturer and model	(Gonio) Ocean Optics STS VIS (Sphere) Admesy HERA VIS 380–780nm
Flicker meter manufacturer and model	Viso Systems LabFlicker
Oscilloscope manufacturer and model	Tektronix MDO3024 oscilloscope (4 Channels. 200 MHz)
Power meter manufacturer and model	Vitretek PA900 Precision Multi-Channel Harmonic Power Analyzer
Power source manufacturer and model	(DC) Keithley Source Measure Unit SMU-2420 3A DC Source Meter (AC) Chroma 61601 AC Source
Datalogger Manufacturer and Model	Omega 8-Channel Thermocouple Thermometer/Data Logger

Measurement conditions gonio spectrometer

Number of C-planes and Resolution	2 planes – 180°
γ (gamma)-Resolution	1°
Test Distance	1.81 m
Room Temperature and Humidity	22°C +/- 10% – RH 50% +/- 20%
Input Power. Power and Displacement Factors	6.1 W – PF 0.95 – DPF 0.97
Frequency of Input Power	50 Hz
Warm-up Time and Variation	Lamp stabilized in 19 min 48 sec --3.8%

Tested light source

Manufacturer and Order Code	Tronix Lighting – 136-103
Product Description	Spot black cut out Ø68-73mm 6W 3000K dim

Main Light Measurement Results

Output – Total Lumen (Up% / Down%)	426 lm – 0% / 100%
Efficiency	70 lm/W
Energy efficiency class	G
Peak Intensity and Beam Angle	916 cd – 38.5°
Correlated Colour Temperature	CCT = 2970 K
Colour Shift. CIE duv	Duv -0.0030
Colour Rendering Index	CRI 83.0
Colour Rendering TM30-18	R _f 84.9 – R _g 96.0
Television Lighting Consistency Index	TLCI = 67
Flicker	SVM 0.01 – PstLM 0.23



136-103 Spot | black | cut out Ø68-73mm | 6W | 3000K | dim


Electrical measurement details

Input Power

RMS Input voltage feed. V_{RMS}	228 V
RMS Input current feed. I_{RMS}	0.028 A
Total input power	6.1 W
Frequency of input power	50 Hz
Power factor	0.95
Displacement power factor	0.97
Total harmonic distortion of the current	21.39%
Total harmonic distortion of the voltage	2.86%

Input Power Curve

Voltage - Current



Efficiency

Radiated power efficiency: 21.4%




Lumen efficiency: 70 lm/W



Harmonics

3rd Harmonic	18.89%
5th Harmonic	8.38%
7th Harmonic	3.19%
9th Harmonic	2.12%
11th Harmonic	1.64%

Current Harmonics %



Stabilization Details

Warm-up Conditions

Stable period	15 min
Stable change max	2.0%
Minimum warm-up time	15 min

Colour temperature change during warm-up

CCT start	2953 K
CCT shift	+17 K
CCT end	2970 K

Warm-up Results

Total warmup time	Lamp stabilized in 19 min 48 sec
Warmup variation	-3.8%

Output intensity change during warm-up

Output start	442 lm
Output change	-16 lm
Output end	426 lm




136-103 Spot | black | cut out Ø68-73mm | 6W | 3000K | dim

Colour measurement details



Total lumen output 426 lm
 Correlated Colour Temperature 2970 K
 Colour coordinates CIE 1931 (x;y) = (0.435;0.396)
 Colour deviation from BBL Duv = -0.0030

TM30-18 Colour Fidelity Index R_f 84.9
 TM30-18 Colour Gamut Index R_g 96.0
 Colour Rendering Index (Ra) CRI 83.0
 Colour Rendering Index. (red component) $R_9 = 6.6$


Colour Quality Scale CQS = 81.8
 Television Lighting Consistency Index TLCI = 67



Relative spectral power distribution



TM30 details




TM30 Colour vectors per hue bin




TM30 Colour distortion


Hue Bin	R_f	Shifts (%)	
		Chroma	Hue
C1	80	-12%	0%
C2	81	-8%	7%
C3	78	-3%	11%
C4	90	0%	5%
C5	93	2%	3%
C6	93	2%	-3%
C7	87	-4%	-6%
C8	93	-3%	-1%
C9	89	-5%	4%
C10	84	-3%	10%
C11	83	1%	12%
C12	85	7%	2%
C13	87	5%	-8%
C14	79	5%	-17%
C15	84	-4%	-9%
C16	75	-9%	-17%



TM30-18 R_f -values per reference colour




TM30-18 R_f -values per hue bin




TM30 Chroma shift

Colour Quality details



Colour Rendering Index



Colour Quality Scale

Document revision date: 1-7-2025 Measurement serial: VFR-250123-0909-MS



136-103 Spot | black | cut out Ø68-73mm | 6W | 3000K | dim

Flicker / temporal light artefacts details

Measurement conditions

Flicker meter type	Viso Systems LabFlicker
Flicker/TLA sample rate	20000 samples/s
Measurement time	5x 180 seconds (15 minutes) for PstLM. 1.2 sec for all other indices

Flicker indices according to Illuminating Engineering Society (IES)


Flicker frequency	98.52 Hz
Percent flicker	0.79 %
Flicker index	0

TLA indices (according IEC TR 61547-1, EN 61000-3-3 and EN 61000-4-15)

An LED luminaire is considered flicker-free if the SVM value is ≤ 0.4 and if the PstLM value is ≤ 1.0

PstLM value ($F < 80$ Hz)	0.23
SVM value ($80 < F < 2000$ Hz)	0.01


Flicker frame (one flicker period in time domain)



Flicker FFT (flicker curve in frequency domain)



IEEE 1789-2015 Lighting Flicker Risk Zones




Document revision date: 1-7-2025 Measurement serial: VFR-250123-0909-MS



136-103 Spot | black | cut out Ø68-73mm | 6W | 3000K | dim

Beam angle

Luminous Intensity diagram



Main Values

Output (total Lumen)	426 lm
Lumen Up/Down	0% / 100%
Peak Intensity	916 cd
Beam Angle (50%)	38.5°
Beam Angle (90%)	38.5°
Beam Angle (10%)	38.5°

Cut-off Angle

Average 2.5%	74.4°
--------------	-------

Field Angle

Average 10%	66.8°
-------------	-------


Intensity Ratio

In 120° cone	99.6%
In 90° cone	99.2%

C planes

- C000-C180
- C090-C270

Linear distribution diagram - Intensity (candela) vs γ-angle




Document revision date: 1-7-2025 Measurement serial: VFR-250123-0909-MS



136-103 Spot | black | cut out Ø68-73mm | 6W | 3000K | dim

Beam Details



*Measured at center of beam

Beam intensities from 1 – 20 m

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	m
3.3	6.6	9.8	13.1	16.4	19.7	23	26.2	29.5	32.8	36.1	39.4	42.7	45.9	49.2	52.5	55.8	59.1	62.3	65.6	ft
916	229	102	57	37	25	19	14	11	9	8	6	5	5	4	4	3	3	3	2	lux
85.1	21.3	9.5	5.3	3.4	2.4	1.7	1.3	1.1	0.9	0.7	0.6	0.5	0.4	0.4	0.3	0.3	0.3	0.2	0.2	fc

Intensities in 0° c-plane

0°	2°	4°	6°	8°	10°	12°	14°	16°	18°	20°	22°	24°	26°	28°	30°	32°	34°	36°	38°	γ
916	908	883	848	802	745	682	617	554	494	437	383	329	275	234	185	130	76	38	16	cd
100%	99%	96%	93%	88%	81%	74%	67%	60%	54%	48%	42%	36%	30%	25%	20%	14%	8%	4%	2%	of 0°val

Intensities in 90° c-plane

0°	2°	4°	6°	8°	10°	12°	14°	16°	18°	20°	22°	24°	26°	28°	30°	32°	34°	36°	38°	γ
916	908	883	848	802	745	682	617	554	494	437	383	329	275	234	185	130	76	38	16	cd
100%	99%	96%	93%	88%	81%	74%	67%	60%	54%	48%	42%	36%	30%	25%	20%	14%	8%	4%	2%	of 0°val

Intensities in 180° c-plane

0°	2°	4°	6°	8°	10°	12°	14°	16°	18°	20°	22°	24°	26°	28°	30°	32°	34°	36°	38°	γ
916	908	883	848	802	745	682	617	554	494	437	383	329	275	234	185	130	76	38	16	cd
100%	99%	96%	93%	88%	81%	74%	67%	60%	54%	48%	42%	36%	30%	25%	20%	14%	8%	4%	2%	of 0°val

Intensities in 270° c-plane

0°	2°	4°	6°	8°	10°	12°	14°	16°	18°	20°	22°	24°	26°	28°	30°	32°	34°	36°	38°	γ
916	908	883	848	802	745	682	617	554	494	437	383	329	275	234	185	130	76	38	16	cd
100%	99%	96%	93%	88%	81%	74%	67%	60%	54%	48%	42%	36%	30%	25%	20%	14%	8%	4%	2%	of 0°val

Document revision date: 1-7-2025 Measurement serial: VFR-250123-0909-MS





136-103 Spot | black | cut out Ø68-73mm | 6W | 3000K | dim

Light Planning – UGR table

Uncorrected, comprehensive UGR table according to CIE 117-1995

Reflectances		70	70	50	50	30	70	70	50	50	30
ρ Ceiling		70	70	50	50	30	70	70	50	50	30
ρ Walls		50	30	50	30	30	50	30	50	30	30
ρ Floor		20	20	20	20	20	20	20	20	20	20
Room size		Viewed Crosswise					Viewed Endwise				
H = mounting height above eye level		(Viewing direction orthogonal to lamp length axis)					(Viewing direction parallel to lamp length axis)				
X	Y										
2H 2H		12.4	12.9	12.4	13.1	13.3	12.4	12.9	12.4	13.1	13.3
3H		12.1	12.7	12.4	12.9	13.1	12.1	12.7	12.4	12.9	13.1
4H		12.0	12.6	12.4	12.9	13.1	12.0	12.6	12.4	12.9	13.1
6H		12.0	12.6	12.3	12.9	13.2	12.0	12.6	12.3	12.9	13.2
8H		12.0	12.5	12.3	12.9	13.2	12.0	12.5	12.3	12.9	13.2
12H		12.0	12.5	12.4	12.9	13.3	12.0	12.5	12.4	12.9	13.3
4H 2H		12.0	12.6	12.4	12.8	13.1	12.0	12.6	12.4	12.8	13.1
3H		11.9	12.4	12.2	12.7	13.2	11.9	12.4	12.2	12.7	13.2
4H		11.8	12.2	12.2	12.7	13.2	11.8	12.2	12.2	12.7	13.2
6H		11.8	12.3	12.3	12.6	13.0	11.8	12.3	12.3	12.6	13.0
8H		11.8	12.3	12.3	12.6	13.0	11.8	12.3	12.3	12.6	13.0
12H		11.8	12.2	12.3	12.6	13.1	11.8	12.2	12.3	12.6	13.1
8H 4H		11.7	12.1	12.2	12.5	12.8	11.7	12.1	12.2	12.5	12.8
6H		11.7	12.0	12.2	12.5	13.0	11.7	12.0	12.2	12.5	13.0
8H		11.8	12.1	12.3	12.6	13.2	11.8	12.1	12.3	12.6	13.2
12H		12.0	12.2	12.6	12.7	13.3	12.0	12.2	12.6	12.7	13.3
12H 4H		11.6	12.0	12.1	12.4	12.8	11.6	12.0	12.1	12.4	12.8
6H		11.7	12.0	12.2	12.5	13.1	11.7	12.0	12.2	12.5	13.1
8H		11.8	12.0	12.4	12.5	13.1	11.8	12.0	12.4	12.5	13.1

Variations with the observer position for the luminaire spacings. S:

S = 1.0H	6.1 / -5.4	6.1 / -5.4
S = 1.5H	8.9 / -5.5	8.9 / -5.5
S = 2.0H	10.9 / -5.7	10.9 / -5.7

Coefficients of Utilization

Ceiling reflectance	80			70			50			30			10			0		
Wall reflectance	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
Floor reflectance	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	0
RCR	(RCR: Room Cavity Ratio)																	
Room Values are expressed as percentage of Lumen delivered to the task surface																		
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	114	112	110	108	112	110	108	106	106	104	103	102	101	100	99	98	97	95
2	110	105	102	99	107	104	101	98	101	98	96	98	96	94	95	93	92	90
3	105	100	95	92	103	98	94	91	96	93	90	93	91	88	91	89	87	86
4	101	95	90	86	99	93	89	86	91	88	85	89	86	84	88	85	83	81
5	97	90	85	81	95	89	84	81	87	83	80	86	82	79	84	81	79	78
6	93	86	80	77	92	85	80	77	83	79	76	82	78	76	81	78	75	74
7	89	82	77	73	88	81	76	73	80	76	72	79	75	72	78	74	72	71
8	86	78	73	69	85	77	73	69	76	72	69	76	72	69	75	71	69	67
9	83	75	70	66	82	74	69	66	73	69	66	73	69	66	72	68	66	64
10	80	72	67	63	79	71	66	63	70	66	63	70	66	63	69	65	63	62