

## Compliance Statement Subject to PGS37-1

Manufacture`s Name: PYLON TECHNOLOGIES, CO., LTD.

Manufacture`s Address: No.300 Miaoqiao Road, Pudong, Shanghai, 201315, China

Declares that:

According to the latest PGS 37-1 installation guidance, subject to sections related to IEC 62933-5-2 , Pylontech has achieved the unit level thermal runaway testing of Powercube -M5A180 and L417-BAT follow "UL 9540A: 2019 (Fourth Edition) Test Method for Evaluating Thermal Runaway Fire Propagation in Battery Energy Storage Systems" test criteria. Which can be considered of equivalent compliance into Pylontech A1000-OMNI, A2000-OMNI, A300-HY and L260-OMNI models of integrated solution. The product safety design has been guaranteed at certain level.

For the rest part of installation requirement guidance of PGS 37-1, it`s subject to the local installer to respect and follow, for more information pls feel free to contact Pylontech.

Person responsible for making this declaration

Signature:



Authority: Marketing Director

Date: 25th April 2025