



CERT

DVGW type examination certificate

DVGW-Baumusterprüfzertifikat

DW-8511BM0411

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of water supply <i>Produkte der Wasserversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Pegler Yorkshire Group Ltd St. Catherines Avenue, GB- Doncaster; South Yorkshire, DN4 8DF
Distributor <i>Vertreiber</i>	VSH Fittings BV Oude Amersfoortseweg 99, NL-1212 AA Hilversum
Product Category <i>Produktart</i>	installation systems and system joints: pipe joint for pipes in drinking water installation systems (8511)
Product Description <i>Produktbezeichnung</i>	compression joint made of copper respectively red brass, type M-MM, for pipes made of copper the guideline DVGW GW 392, not pressed leaky
Model <i>Modell</i>	VSH XPress fittings
Test Reports <i>Prüfberichte</i>	mechanical test: 120001607-15 from 30.06.2015 (MPM) mechanical test: 120001607-09 from 01.12.2009 (MPM) type testing: 12001086 from 06.07.2001 (MPM)
Test Basis <i>Prüfgrundlagen</i>	DVGW W 534 (01.05.2004) UBA METALLE (19.01.2016) UBA ELASTOM (22.12.2011) DVGW W 270 (01.11.2007)
Date of Expiry / File No. <i>Ablaufdatum / Aktenzeichen</i>	06.07.2020 / 17-0004-WNU



70028-04-A-DE

27.04.2017 GI A-1/2 
Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 for certification of products for energy and water supply industry.

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte Stelle für die Zertifizierung von Produkten der Energie- und Wasserversorgung.



DVGW CERT GmbH
Zertifizierungsstelle
Josef-Wirmer-Str. 1-3
53123 Bonn
Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993
www.dvgw-cert.com
info@dvgw-cert.com

Type Typ	Technical Data Technische Daten	Remarks Bemerkungen
VSH XPress fittings	diameter: 12,0 mm	
VSH XPress fittings	diameter: 15,0 mm	
VSH XPress fittings	diameter: 18,0 mm	
VSH XPress fittings	diameter: 22,0 mm	
VSH XPress fittings	diameter: 28,0 mm	
VSH XPress fittings	diameter: 35,0 mm	
VSH XPress fittings	diameter: 42,0 mm	
VSH XPress fittings	diameter: 54,0 mm	
VSH XPress fittings	diameter: 64,0 mm	
VSH XPress fittings	diameter: 76,1 mm	
VSH XPress fittings	diameter: 88,9 mm	
VSH XPress fittings	diameter: 108,0 mm	

certified Components

zertifizierte Bauteile / Werkstoffe

Registr. No. Registr.-Nr.	Component Bauteil (Produktart)	Model/Type Modell/Typ	Manufacturer Hersteller
NW-5253BP5648	sealing material for drinking water installations	EP 1/1/5/EP 1/1/5	Superior Seals Limited

Hints of Utilization / Remarks

Verwendungshinweise / Bemerkungen

The type-testing was carry out with pipes made of copper according to guideline DVGW GW 392.

dimensions 12,0 mm up to 22,0 mm with soft copper pipes

dimensions 12,0 mm up to 28,0 mm with half-hard copper pipes

dimensions 22,0 mm up to 108,0 mm with hard copper pipes