#### **OVE AUSTRIAN ELECTROTECHNICAL ASSOCIATION**

Eschenbachgasse 9, 1010 Wien, Austria ZVR: 327279890 | DVR: 1055887

**OVE - Testing & Certification** 

Kahlenberger Str. 2A, 1190 Wien, Austria

Phone: +43 1 370 58 06

www.ove.at



Page 1 of 3

# **ÖVE-CERTIFICATE**

including the entitlement to use the Austrian Safety Mark



Certificate No.: 9460-015-04 Valid from: 2016 10 07

until: 2018 10 07

The Austrian Electrotechnical Association (OVE) hereby grants the right to the company mentioned below to label the listed products with the Austrian Safety Mark.

Company:

NIKO N.V.

Industriepark-West 40 9100 Sint-Niklaas

Belgium

Product:

Two pole socket outlet with side earthing contacts

The products submitted by the applicant were type tested in accordance with the requirements of the technical standards and specifications listed in this certificate. OVE certifies the conformity of the listed products and those products manufactured strictly identical to the submitted ones (ISO/IEC 17067, Conformity Assessment Scheme Type 5).

The manufacturing process and the products are subject to ongoing surveillance based on harmonized European procedures. This certificate has been issued under the presumption and conditional on the fact that the applicant holds all necessary legal rights with regard to the product, presented for the testing and certification.

Results of testing are shown in file No(s).: 2723-1568/10

Österreichischer Verband für Elektrotechnik
Head of Testing & Certification

Digitally signed by W. Martin Email=w.martin@ove.at

Dipl.-Ing. W. Martin

## **OVE - Testing & Certification**

Vienna, 2016 08 30

Accredited by the Federal Ministry of Science, Research and Economy as Certification Body for products within the scope as given in the official decree and published under www.en.bmwfw.gv.at/accreditation





Certificate No.: 9460-015-04 Date: 2016 08 30

Page 2 of 3

#### Manufacturer:

NIKO N.V. Industriepark-West 40 9100 Sint-Niklaas Belgium

#### Factory location(s):

NIKO N.V. Industriepark-West 40 9100 Sint-Niklaas Belgium

### Tested and certified according to:

ÖVE/ÖNORM IEC 60884-1:2005-09-01 ÖVE/ÖNORM E 8684-1:2010-03-01

socket-outlet insert with screwless terminals and shutter

Product: Two pole socket outlet with side earthing contacts

Type designation:
Rating:

-3.3+7\*\*-368\*\*
NIKO
Rated voltage: AC 250 V
Rated current: 16 A
IP55



Certificate No.: 9460-015-04 Date: 2016 08 30

Page 3 of 3

# Typelist:

#### Socket:

-3.3+7\*\*-368\*\* 2P with side earthing, screwless-type terminals and with shutters

#### Boxes:

