



Ref. Certif. No.

FR_721332

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Socket-outlet for fixed-electrical installations

Name and address of the applicant

LEGRAND FRANCE
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX
FRANCE

Name and address of the manufacturer

LEGRAND FRANCE
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX
FRANCE

Name and address of the factory

Note: When more than one factory, please report on page 2

☒ Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

Series : VALENA NEXT
References : See Annex

Additional information (if necessary may also be reported on page 2)

Supersedes CBTC FR_707094/A1 dated 04/10/2021. Removal of product references

☐ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60884-1:2022

As shown in the Test Report Ref. No. which forms part of this Certificate

23079173-803278

This CB Test Certificate is issued by the National Certification Body



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 28/03/2025

Signature: 
Certification Officer



ANNEX

Name and address of the factories:**LEGRAND FRANCE**

128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX
FRANCE

LEGRAND MAGYARORSZAG VILLAMOSSAGI RENDSZEREK ZRT

IPARTELEPI UT 14 PF 10
6600 SZENTES
HUNGARY

CARDONAPLAST SAU

POL IND LA CORT C/FORNS 4-5
08261 CARDONA
SPAIN

ENVERA EMPLEO, SLU

C/ TRASPADERNE, 9
28042 MADRID
SPAIN



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE

33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE

www.lcie.fr

Date: 28/03/2025

Signature: **JULIEN GAUTHIER**

ANNEX

References, ratings and main characteristics:

Mechanisms

Type reference	References White	References Aluminium	References Dark	Function	Characteristics	Type of terminals	Specificity
PFA1	7 415 20	7 416 20	7 417 20	2P+E	16A 250V~	slt	
	7 415 30	7 416 30	7 417 30	2P+E	16A 250V~	slt	mobile face of entry plug
PFA2	7 415 21	7 416 21	7 417 21	2P	16A 250V~	slt	
PFAD1	7 415 22	7 416 22	7 417 22	2 x 2P+E	16A 250V~	slt	
	7 415 32	7 416 32	7 417 32	2 x 2P+E	16A 250V~	slt	mobile face of entry plug
PFAT1	7 415 23	7 416 23	7 417 23	3 x 2P+E	16A 250V~	slt	
	7 415 33	7 416 33	7 417 33	3 x 2P+E	16A 250V~	slt	mobile face of entry plug

slt : screwless terminals

"All the commercial references listed above may be supplemented with a prefix of type LG-, BT-, ... (to indicate the brand) and/or suffix of type 0, 1, 2, 3, 4, FI, EX, ... In this case, the products are technically the same."

Accessories

References	Designation
7 415 80	White Blank
7 416 80	Aluminium Blank
7 417 80	Dark Blank

Cover-plate

	White	White Chrome	White Pink Gold	Aluminium	Aluminium chrome	Dark
1 gang	7 411 01	7 411 11	7 411 21	7 411 31	7 411 41	7 411 51
2 gang	7 411 02	7 411 12	7 411 22	7 411 32	7 411 42	7 411 52
3 gang	7 411 03	7 411 13	7 411 23	7 411 33	7 411 43	7 411 53
4 gang	7 411 04	7 411 14	7 411 24	7 411 34	7 411 44	7 411 54
5 gang	7 411 05	7 411 15	7 411 25	7 411 35	7 411 45	7 411 55
2 gang entraxe 57	7 411 08	7 411 18	7 411 28	7 411 38	7 411 48	7 411 58
3 gang entraxe 57	7 411 09	7 411 19	7 411 29	7 411 39	7 411 49	7 411 59



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 28/03/2025

Signature: **Julien GAUTHIER**

Certification Officer



ANNEX

Standard sheet	V / I CEE7
Rated current (A)	16A
Rated voltage (V)	250V~
Degree of protection	IP20
Provision for earthing	without earthing contact with earthing contact
method of connecting the cable	rewirable
Type of terminals	screwless (rigid and flexible)
Degree of protection against electric shock	normal protection
Existence of shutters	with shutters
Method of application - mounting	flush-type
Method of installation	design A



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 28/03/2025

Signature: 

Julien GAUTHIER
 Certification Officer