

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Fuse switch disconnecter
Name and address of the applicant	ABB Oy Muottitie 2A FI-65320 VAASA, Finland
Name and address of the manufacturer	ABB Oy Muottitie 2A FI-65320 VAASA, Finland
Name and address of the factory <i>Note: When more than one factory, please report on page 2</i>	ABB Bulgaria EOOD – Rakovski branch BULGARIA, 4142 Village of Stryama, Region of Plovdiv, Municipality of Rakovski, Rakovski Industrial Zone, 14 Industrial Road 1, nr,14-18
Ratings and principal characteristics	Uimp: 8kV; Ui: 1000V; Ith: 250A, 200A(800VAC); AC-21B: Ue/Ie: 690V/250A; AC-22B: Ue/Ie: 500V/250A; AC-23B: Ue/Ie: 400V/250A; AC-22B: Ue/Ie: 800V/200A; Iq: 100kA; 50/60Hz; IP30(front); 3P
Trademark (if any)	ABB
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	
Additional information (if necessary may also be reported on page 2)	ZLBM1, ZHBM1 Original CB certificate No. is CN47238, dated 2019-07-01. This modification is to add another monitoring communication unit and to change the address of the factory.
A sample of the product was tested and found to be in conformity with	IEC 60947-1:2007 (5th Edition) + AMD1:2010 + AMD2:2014; IEC 60947-3:2008(3rd Edition) + AMD 1:2012 + AMD 2:2015
As shown in the Test Report Ref. No. which forms part of this Certificate	00901-CB2019CQC-085959-M1

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: <http://www.cqc.com.cn>



Date:

Apr.26,2020

Signature:

Lu Mei

CB 0056755