



Ref. Certif. No.

DE1-49961IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEMESYSTEME CEI D'ACCEPTATION MUTUELLE DE
CERTIFICATS D'ESSAIS DES EQUIPEMENTS
ELECTRIQUES (IECEE) METHODE OC**CB TEST CERTIFICATE CERTIFICAT D'ESSAI OC**Product
Produit

Switch-disconnector

Name and address of the applicant
Nom et adresse du demandeurABB Switzerland Ltd CMC Low Voltage Products
Fulachstrasse 150, 8201 SCHAFFHAUSEN
SWITZERLANDName and address of the manufacturer
Nom et adresse du fabricantABB Switzerland Ltd CMC Low Voltage Products
Fulachstrasse 150, 8201 SCHAFFHAUSEN
SWITZERLANDName and address of the factory
Nom et adresse de l'usineABB Switzerland Ltd CMC Low Voltage Products
Fulachstrasse 150, 8201 SCHAFFHAUSEN
SWITZERLAND

Note: When more than one factory, please report on page 2
Note: Lorsque il y a plus d'une usine, veuillez utiliser la 2^{ème} page

Ratings and principal characteristics
Valeurs nominales et caractéristiques principales☐ Additional Information on page 2Utilization category: DC-21A
Rated voltage: 1000 V d.c. (two poles in series)
Rated current: 32 A, 63 A, 100 ATrademark (if any)
Marque de fabrique (si elle existe)Type of Manufacturer's Testing Laboratories used
Type de programme du laboratoire d'essais constructeurModel / Type Ref.
Ref. De type

S802PV-M32-H, S802PV-M63-H, S802PV-M100-H

Additional information (if necessary may also be
reported on page 2)
Les informations complémentaires (si nécessaire,
peuvent être indiqués sur la 2^{ème} page)

Icw: 1500 A / 1 s
Icm: 500 A☐ Additional Information on page 2**PUBLICATION****EDITION**

A sample of the product was tested and found
to be in conformity with
Un échantillon de ce produit a été essayé et a été
considéré conforme à la

IEC 60947-1(ed.5);am1
IEC 60947-3(ed.3)

As shown in the Test Report Ref. No. which forms part
of this Certificate
Comme indiqué dans le Rapport d'essais numéro de
référence qui constitue partie de ce Certificat

423200-4402-0010/162798

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme **National de Certification**

VDE Prüf- und Zertifizierungsinstitut GmbH
VDE Testing and Certification Institute
Zertifizierungsstelle / Certification

Date: 2012-04-10

Signature:

M. Bausch