

产品认证证书

II型自愿认证

证书编号: CQC2013010302632074

发证日期: 2020年08月28日

有效期至: 2032年06月17日

委托人名称 ABB Switzerland Ltd, Low Voltage Products
及注册地址 Fulachstrasse 150, CH-8201 Schaffhausen, Switzerland

制造商名称 ABB Switzerland Ltd, Low Voltage Products
及注册地址 Fulachstrasse 150, CH-8201 Schaffhausen, Switzerland

生产企业名称 ABB Switzerland Ltd, Low Voltage Products
及生产地址 Fulachstrasse 150, CH-8201 Schaffhausen, Switzerland

产品名称和系列、规格、型号 隔离开关
S802PV-M32-H,S802PV-M63-H,S802PV-M100-H;详见附页

产品标准和技术要求 GB/T 14048.3-2017

认证模式 产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站(www.cnca.gov.cn)查验证书信息



授权签字人

签发

郑泉

谢肇煦



中国质量认证中心



<http://www.cqc.com.cn>

中国·北京·南四环西路188号9区 100070

电话: +86 10 83886666

C(2) 0157299

CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2013010302632074

Valid from: Aug.28,2020

Valid until: Jun.17,2032

NAME AND REGISTERED ADDRESS OF THE APPLICANT ABB Switzerland Ltd, Low Voltage Products
Fulachstrasse 150, CH-8201 Schaffhausen, Switzerland

NAME AND REGISTERED ADDRESS OF THE MANUFACTURER ABB Switzerland Ltd, Low Voltage Products
Fulachstrasse 150, CH-8201 Schaffhausen, Switzerland

NAME AND LOCATION OF THE FACTORY ABB Switzerland Ltd, Low Voltage Products
Fulachstrasse 150, CH-8201 Schaffhausen, Switzerland

PRODUCT NAME, MODEL AND SPECIFICATION Switch-disconnector
S802PV-M32-H,S802PV-M63-H,S802PV-M100-H;See the appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS GB/T 14048.3-2017

TYPE OF CERTIFICATION SCHEMES Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

郑士泉

SIGNATURE

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE



<http://www.cqc.com.cn>

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

Tel: +86 10 83886666

C(2) 0157299

产品认证证书

II型自愿认证

附录

证书编号: CQC2013010302632074

第 1 页 共 2 页

纸 号: 157299

S802PV-M32-H, S802PV-M63-H, S802PV-M100-H

U_{imp} : 8kV;

U_i : 1500V;

I_{th} : 100A;

U_e : DC1000V (2P 外形);

I_e : 32A, 63A, 100A;


I_{cm} : 500A;

I_{cw} : 1500A/1s;

使用类别: DC-21A;

IP20

直流接线示意图:



注: 此附录与证书同时使用时有效。



中国质量认证中心



产品认证证书

II型自愿认证

附 录

证书编号: CQC2013010302632074

第 2 页 共 2 页

纸 号: 157299

型号解释:

Full type 型号		S802PV-M32-H							
		S80	2	PV	-	M	32	-	H
		1	2	1		3	4		5
Position	Product 产品	√	√	√		√	√	√	√
位置	package label 包装标签	√	√	√	√	√	√	√	√

- 1—— Basic Type 基本型号
- 2—— Number of Product Pole 保护极数:2-2P
- 3—— M 隔离开关
- 4—— Rated Current 额定电流: 32=32A, 63=63A, 100=100A.
- 5—— H 高电压型 2P 1000V DC

注: 此附录与证书同时使用时有效。



中国质量认证中心

