

GLV 035-03

APsystems

DS3, DS3-H, DS3-L, DS3-L-SPE

**C10/26 - DECLARATION OF CONFORMITY for power-generating units  
GLV ed2.1.2 (12/2019)**

for the application of annex D "Technical basic requirements regarding the power-generation units" of the Synergrid prescription C10/11 ed2.1 (01/09/2019)



The undersigned,

Manufacturer:

ALTENERGY POWER SYSTEM INC.

Represented by:

Guofeng Jiang

Address:

No. 1, Yatai Road, Nanhu District, Jiaxing

Country:

China

email:

guofeng.jiang@apsystems.cn

Telephone:

0573-82583529

**the following conditions:**

1. The power-generating unit complies with the relevant requirements set out in annex D "Technical basic requirements regarding the power-generation units" of the Synergrid prescription C10/11 ed2.1 (01/09/2019).
2. In order to substantiate this, a separate technical file has been submitted at least for each separate product series of the 'C10/26 list of power-generating units' of this homologation application. Each technical file shall be drawn up on the basis of a checklist Annex D, duly and correctly completed by the manufacturer, accompanied by all the required proof of conformity.
  - 2.1 For technical requirements for which the required proof of conformity (column J in checklist annex D) is a declaration of honour by the manufacturer, the manufacturer declares by signing and dating this declaration of conformity the correctness of the information (conform / not conform / not applicable) provided by him or her in columns K, L and M of this checklist.
  - 2.2. For technical requirements for which the required proof of conformity (column J in checklist Annex D) is a test report or a certificate, the necessary test reports and/or certificates are available \* in the technical file:
    - Certificates have been issued by an EN 45011 (or ISO 17065:2012) certification body accredited for these materials.
    - Test reports have been established by an ISO 17025:2005 or ISO 17065:2012 laboratory accredited for these tests.



Done at:  
On:

Jiaxing, China  
August 20, 2021

Homologated by Synergrid on: 30/08/2021  
Stamp Synergrid & signature:

(stamp manufacturer & signature)

Guofeng Jiang

SYNERGRID a.s.b.l.-v.z.w.  
Galerie Ravensteingalerij 4/2  
BE-1060 Bruxelles/Brussel  
V.A./B.T.W : BE 0402.958.091

Guofeng Jiang  
30/08/2021


\* Transition period till 01/05/2020 (see exceptions in chapter 3 of C10/11 ed 2.1 (01/09/2019)): If at the time of submission of this homologation application it is not yet possible to submit all the necessary certificates and/or test reports (exception 3), or that the units do not yet have all the required characteristics (exceptions 1 and 2), a temporary homologation may be granted. All necessary certificates and/or test reports must be in the possession of Synergrid at the latest on 30/04/2020 in order to obtain a final homologation. if



11	Additional characteristics	In these columns optional additional characteristics of the units are indicated, following the information in checklist annex D and the corresponding technical file. Put an "X" at each relevant additional characteristic. Note: Only units < 1 MW that are "type B ready" may be applied in an installation $\geq$ 1 MW (installation "type B" according to the European Network Code RFC). A unit < 1 MW is only "type B ready" if it complies with all optional properties ticked in column I of the checklist Annex D.
12	Limitations	These columns specify limitations of the units to their application in certain types of installations, in accordance with the information in the checklist in annex D and the corresponding technical file. Put an "X" to each relevant limitation.
13	Application	Indicate the applications for which the unit is suitable. Include an "X" with each application for which the unit can be used.
14	Synergrid approval date Temporary homologation (expires on 01/05, 2020)	Date on which the submitted homologation file was approved by Synergrid for a limited period of time. - A temporary homologation is granted if the applicant invokes exceptions in chapter 3 of C10/11 ed2.1 (01/09/2019) and has not yet submitted all the test reports required for a definitive homologation with his homologation application (exception 3), or if the units do not yet have all the required properties (exceptions 1 and 2). - The expiry date for a temporary homologation is 01/05 2020 - see conditions in chapter 3 of C10/11 ed.2.1 (01/09 2019).
15	Synergrid approval date Final homologation	Date on which the submitted homologation file was definitely approved by Synergrid. - A final approval will be granted as soon as Synergrid has a fully compliant homologation dossier. - A final homologation only remains valid under the following conditions: - No changes that have an influence on the initial approval are made to (the production of) the units. - There is no new edition of prescription C10/11. - The validity date of the test reports in the technical file submitted for approval has not been exceeded. See also the general Synergrid procedure SI/01 for homologation of material, which is applicable. (1)

(1) - SI/01 technical specifications procedure for application for homologation and renewal of homologation of material.

**SYNERGRID a.s.b.l.-v.z.w.**  
**Galerie Rayensteingalerij 4/2**  
**BE-1000 Bruxelles/Brussel**  
**T.V.A./B.T.W : BE 0402.958.091**



**FINAL  
HOMOLOGATION**



*Gangfeng Jiang* 20/08/2021

