

CERTIFICATE

Issued to:
Applicant:
ABB B.V.
Frankeneng 15
6716 AA Ede, The Netherlands

Licensee:
ABB B.V.
Frankeneng 15
6716 AA Ede, The Netherlands

Product : Distribution board connecting box
Trade name(s) : ABB HAF
Type(s)/model(s) : PMK80

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 60670-1:2005, EN 60670-1:2005/A11:2018 and EN 60670-22:2006
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 900017

DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on 17 December 2018 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 71-105974

DEKRA Certification B.V.



B.T.M. Holtus
Managing Director



H.R.M. Barends
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: Distribution board connecting box
Trade name(s)	: ABB HAF
Type(s)/model(s)	: PMK80
Ratings	: 16A - 240/400 V~
Model	: Rectangular with 3 spouts on both sides, all suitable for conduit 16 mm and on 2 sides suitable for conduit 19/20 mm.
Nature of supply	: For casting into concrete.
Dimensions	: 174x55x76 mm
Material	: PPC in HAF blue

List of components

Component	Manufacturer/ Trade name	Type/Model	Approval mark ¹⁾
Connector	Wieland	GST 18 I 5FS2R	VDE
Connector	WAGO	WINSTA(R) MIDI 770- ..3/4/5	KEMA-KEUR

¹⁾ * indicates a component tested as part of the appliance

TESTS**Test requirements**

EN 60670-1:2005
EN 60670-1:2005/A11:2018
EN 60670-22:2006

Test result

The test results are laid down in DEKRA test file 222981800.

Conclusion

The examination proved that all requirements were met.

Factory location

ABB B.V.
Frankeneng 15
6716 AA Ede, The Netherlands