


	Lumen output(lm)	CCT (K)	Power(W)	Energy efficacy class	Driver	Options	kg
WL140V 14_24_40S/827_830_840 PSU WH	1400/2300/3600 1450/2400/4050 1500/2400/3900*	2700/3000/4000*	11/18/29*	E	PSU	NA	1.35
WL140V 14_24_40S/827_830_840 PSU MDU WH		2700/3000/4000*	12/19/30*	E	PSU	MDU	1.4
WL140V 14_24_40S/827_830_840 PSR MDU WH		2700/3000/4000*	12/19/30*	E	PSR	MDU	1.4
WL140V 40S/827_830_840 PSED WH	3600/4050/3900*	2700/3000/4000*	29	E	PSED	NA	1.4
WL140V 40S/827_830_840 WIA WH		2700/3000/4000*	29	E	WIA	NA	1.3

\*default setting






**ATTENTION**  
OBSERVE PRECAUTIONS  
FOR HANDLING  
ELECTROSTATIC  
SENSITIVE  
DEVICES

- For use in environments where an accumulation of conductive dust on the luminaire may be expected.
- For outdoor operation at a building, vertical wall-mounted only: all its cables shall run indoor, with a maximum distance of 10 meter.\*
- For outdoor operation the luminaire can only be used in the aisle or semi-shaded environment or the environment blocked by glass, and it is not recommended to use it directly exposed to direct sunlight!

**Inrush current**

	PSU	PSR	PSED	WIA
Electrical characteristics				
I <sub>max</sub> (A)	14	10	9	5
T <sub>ref</sub> (μs)	7	66	22	50
MCB Luminaires Max.				
B-10 A	20	25	20	18
B-13 A	25	32	25	20
B-16 A	32	42	32	24
C-10 A	33	42	33	24
C-13 A	43	58	43	31
C-16 A	54	65	54	40



### Power switch and Color temperature switch

**PSU  
PSU+MDU**

**WARNING**

OFF

WL140V 14\_24\_40S/827\_830\_840 PSU WH  
11W 18W 29W  
LO ME HI  
\* default setting

WL140V 14\_24\_40S/827\_830\_840 PSU MDU WH  
12W 19W 30W  
LO ME HI  
\* default setting

CCT  
\* 4000K 3000K 2700K  
\* default setting

**PSR+MDU:**  
WL140V 14\_24\_40S/827\_830\_840 PSR MDU WH

switch

Power switch

Po(w)	1	2
30W	ON	ON
19W	1	ON
12W	-	-

\* default setting

2700K 3000K 4000K  
\* default setting

**PSED:**  
WL140V 40S/827\_830\_840 PSED WH  
**WIA:**  
WL140V 40S/827\_830\_840 WIA WH

switch

4000K 3000K 2700K  
\* default setting

**4**

Max. 10 luminaires.


Min 1.00mm<sup>2</sup>  
Max 1.50mm<sup>2</sup> Ø6-Ø12mm

PSU PSU+MDU PSR PSED WIA		
1~10V	Yellow 1-10V + Green 1-10V - Blue (N) Brown (L)	
DALI	Black DA/N Red DA/LS Blue (N) Brown (L)	

CLICK


3mm 0.5Nm

Type	N	0	L	1	2	3
PSU	N		L			
PSU+MDU	N		L			
PSR+MDU	N		L	1-10V+	1-10V-	
PSED	N		L	DA/LS		DA/N
WIA	N		L			




## PSU Motion Detection Unit (MDU)

PSU MDU is suitable for all applications where individual luminaire sensing is sufficient. Sensor has on/off, dimming, timing and daylight sensing functionalities. Below tables explain how to set switches depending on your preferences.



HF Motion Sensor

Detection Area	Hold Time	Daylight Sensor	Stand-by Period	Stand-by DIM Level
1	2 3	4 5	6 7	8



1		
I	ON	100%
II	-	50%

**Detection area.** (default 100%) show patterns.

Detection area can be reduced to 50% by selecting the combination on the DIP switches to fit precise applications.

2 3			
I	ON	ON	5S
II	ON	-	1min
III	-	ON	5min
IV	-	-	10min

**Hold time.** (default 5 min.)

Refers to the time period where the luminaire remains at 100% illumination after no motion is detected.

4 5			
I	ON	ON	5Lux
II	ON	-	25Lux
III	-	ON	50Lux
IV	-	-	Disable*

**Daylight sensor.** (default 25 lux.)

The sensor can be set to switch on the luminaire below certain light levels (5/25/50 lux). When it is set to Disable mode, sensor will switch on the luminaire when motion is detected regardless the ambient light level.

6 7			
I	ON	ON	0S
II	ON	-	1min
III	-	ON	10min
IV	-	-	+∞

**Stand-by period.** (default 10 min.)

Time period of keeping dimmed levels before the luminaire is completely switched off when there is no motion. When it is set to '∞' mode, dimmed light level is maintained until motion is detected.

8		
I	ON	10%
II	-	25%

**Stand-by dimming level.** (default 25%)


Dimming % level when there is no motion (after the hold time) to save energy.

## Detection area (Radiation Pattern) PSU MDU


Below diagrams show the sensor coverage with different detection area settings, ceiling heights and moving speeds.

Light grey pattern shows 100% detection area selection and dark grey area shows 50% detection area selection.


Ceiling mounted height: 3m  
Sensitivity: 100%/50%




Ceiling mounted height: 6m  
Sensitivity: 100%/50%




Normal moving (Speed: 1m/s)




Normal moving (Speed: 1m/s)



Slow moving (Speed 0.3m/s)



Slow moving (Speed: 0.3m/s)




Wall mounting height: 2m  
Sensitivity: 100%/50%

Normal moving (Speed: 1m/s)


Slow moving (Speed 0.3m/s)

## PSR Motion Detection Unit (MDU)

PSR MDU is suitable for all applications where grouping functionality is required. Products communicate each other by receiving/transmitting signals.



HF Motion Sensor



### Dipswitch settings

#### Sensor functions support below applications:

1. Single use (individual sensing as same as PSR MDU )
2. Corridor (grouping luminaires up to 10 pieces and 50 meters for max. 31 floors)
3. Staircase (grouping luminaires up to 10 pieces and 25 meters for max. 31 floors)

### Dipswitch settings

ON	1	2	%
↑	on	on	100
↓	on	-	75
↓	-	on	50
↓	-	-	25

#### Detection area (default setting:1,2,ON)

can be reduced to 25% by selecting the combination on the DIP switches to fit precise applications.

ON	3	4	5	Time
↑	on	on	on	5 s
↓	on	on	-	30 s
↓	on	-	on	90 s
↓	on	-	-	3 min
↓	-	on	on	20 min
↓	-	on	-	30 min
↓	-	-	-	+∞

#### Hold time (default setting:3,ON,4,5,OFF)

Refers to the time period where the luminaire remains at 100% illumination after no motion is detected.

ON	6	7	8	Time
↑	on	on	on	0 s
↓	on	on	-	5 s
↓	on	-	on	5 min
↓	on	-	-	10 min
↓	-	on	on	30 min
↓	-	on	-	60 min
↓	-	-	-	+∞

#### Stand-by period (default setting:6,ON,7,8,OFF)

Time period of keeping dimmed levels before the luminaire is completely switched off when there is no motion. When it is set to '∞' mode, dimmed light level is maintained until motion is detected.

ON	9	10	11	12	Lux
↑	on	on	on	on	5
↓	-	on	on	on	15
↓	on	-	on	on	30
↓	-	-	on	on	50
↓	on	on	-	on	100
↓	on	on	on	-	150
↓	-	-	-	-	Disable

#### Daylight sensor (default setting:9,ON,10,OFF,11,12,ON)

The sensor can be set to switch on the luminaire below certain light levels (5-150 lux). When it is set to Disable mode, sensor will switch on the luminaire when motion is detected regardless the ambient light level.

ON	1	2	%
↑	on	on	10
↓	on	-	20
↓	-	on	30
↓	-	-	50

#### Stand-by dimming level (default setting:1,ON,2,OFF)

Dimming % level when there is no motion (after the hold time) to save energy.

ON	3	%
↑	on	100
↓	-	10~50

#### Brightness (default setting:3,ON)

level of the luminaire when it detects motion.

ON	1	RF	2	Mode	3	TX	4	RX
↑	ON	Open	ON	corridor	ON	A	ON	A
↓	-	Close	-	staircase	-	B	-	B

#### Mode switch:


RF switch is controlling the transmit of the signal. When it is closed, sensor can only receive signal but can't transmit. So, the luminaire supports only single use functionality (stand-alone sensor).

Mode determines the application whether it is corridor or staircase.

TX and RX are set to ON for the floors between 0-15 of the building. TX and RX are set to OFF for the floors between 16-31 floor of the building.

### Transmission Channels (16x2 combinations)


A0 - A1 - A2 - A3 - A4 - A5 - A6 - A7 - A8 - A9 - AA - AB - AC - AD - AE - AF  
BF - BE - BD - BC - BB - BA - B9 - B8 - B7 - B6 - B5 - B4 - B3 - B2 - B1 - B0




Tx-Transmission Nodes  
0-F(total 16)

Rx-T Receiver Nodes  
0-F(total 16)

# Radio Frequency (RF) wireless grouping: 1. Corridor




# Radio Frequency (RF) wireless grouping: 2. Corridor + Staircase



### Detection area (Radiation pattern)PSR MDU


#### 1. Ceiling mounting

Ceiling mounted height: 3m  
Sensitivity: 100%/75%/50%/25%




Normal moving (Speed:1m/s)

Ceiling mounted height: 6m  
Sensitivity: 100%/75%/50%/25%




Normal moving (Speed:1m/s)


Ceiling mounted height: 8m  
Sensitivity: 100%/75%/50%




Normal moving (Speed:1m/s)



Slow moving (Speed 0.3m/s)




Slow moving (Speed 0.3m/s)




Slow moving (Speed 0.3m/s)

#### 2. Wall mounting

Wall mounting height: 2m  
Sensitivity:  
100%/75%/50%/25%/10%



Normal moving (Speed: 1m/s)



Slow moving (Speed 0.3m/s)

### Initialization


The light will turn on 100% brightness in the initial energizing sensor, and turn off after 10 seconds. During initialization, no external motion sensing signal will be detected.

### Default settings


Detection Area: 100% / Hold Time: 5S , Stand-by period:0s, Daylight Sensor: Disable, Stand-by DIM level: 10% , RF Brightness: 10%-50% , RF:Open , Mode: Broadcast ,TX:A , RX:

### PSR MDU Note:

- 1: Work mode : Corridor & Staircase
- 2: TX: is for signal Transmitting, with 0-F 16 different channels. 1 DIP to set Group A or group B. Group A with 16 channels, Group B also with 16 groups, total can set 32 groups .
- 3: RX: is for signal Receiving, with 0-F 16 different channels. 1 DIP to set Group A or group B . Group A with 16 channels, Group B also with 16 groups ,total can set 32 groups.
- 4: When Master and Master set under corridor work mode, that means ,all sensors set the same channel,Any Master sensor is triggered, it will transmit the RF signal to all the lamps in the group
- 5: When Master and Master set under staircase work mode, that means ,when any master is triggered, it will send RF signal to 3 channels (the adjacent channel before and after the TX channel and the channel set by master itself. For example, when the master set the TX channel for "1", it will launch "0" "1" "2" three different channel signal, if other different RX channel set with "0" "1" "2", at this time will receive the corresponding channel signals, this kind of work mode is mainly applied to corridor application , note: TX "F" to launch the channel group A and B group "0" RX receives channels can connect network.
- 6: Master to Satellite only work as corridor mode, that means the satellite only receive the signal from master , not affect by the master work mode.
- 7: Satellite receive RF signal from Master, the "hold time" is determined by Master, keep the same with master's "hold time" .
- 8: Sensor will not transmit or receive RF signal during the Initialization time. only can transmit RF signal after the Initialization period.
- 9: Group A and group B of RX require the corresponding Master group A and group B of TX .
- 10: Indoor wireless distance without wall shielding 50 meters .
- 11: Indoor wireless distance with wall shielding 25 meters .
- 12: Work mode : Corridor application is shown in the following figure



- 13: Work mode : Staircase application is shown in the following figure



### Note:

- 1, The CoreLine wall-mounted needs to be installed side-by-side in the same direction. The distance between each of the luminaires should be kept at least 3m to avoid mutual interference.
2. Please pay attention to the installation environment:
  - 2.1. Avoid high-density objects such as: metal, glass, concrete walls, etc, with in the sensor detection area.
  - 2,2, Avoid moving signals within the sensor detection area such as: fan, DC motor, sewerpipe, air outlet, heavy rainfall, motion behind a thin wall etc , This is to avoid false triggers of the sensor,
  - 2.3. This sensor is outdoor wind and rain, and surrounding moving objects will cause false triggering
- 3, In order to reach the common sensor distance, the object move speed should be less than 1m/s, If an object moves with speed higher than 1m/s, the detection distance will decrease.
- 4, It is advised not to install a luminaire on a wooden surface, in case it must be installed on a wooden surface, and the wood thickness must be more than 15cm .
- 5, To avoid smaller detection range or abnormal operation, the CoreLine wall-mounted should not be installed in close distance to large areas of metal and glass (separation distance at least 1 m). Please reduce detection area setting or contact Signify to confirm the situation once the CoreLine wall-mounted works fails.

© 2021 Signify Holding.  
All rights reserved. This document contains information relating to the product portfolio of Signify which information may be subject to change. No representation or warranty as to the accuracy or completeness of the information included herein is given and any liability for any action in reliance thereon is disclaimed. The information presented in this document is not intended as any commercial offer and does not form part of any quotation or contract. Philips and the Philips Shield Emblem are registered trademarks of Koninklijke Philips N.V. All other trademarks are owned by Signify Holding or their respective owners.


Signify Holding,  
The Netherlands



# Optional


**12NC Description**  
 912401483603 EM300V ELB\_ELP3 kit HV 6.4V 2000mAh LFP  
 Emergency pack is not provided.

1x



## Products compatible with emergency lighting functionality.

12NC	Description	EOC	SKU
911401873687	WL140V 14_24_40S/827_830_840 PSU WH	872110330713299	108415703
911401873787	WL140V 14_24_40S/827_830_840 PSU MDU WH	872110330714999	108415704
911401873887	WL140V 14_24_40S/827_830_840 PSR MDU WH	872110330715699	108415705
911401873987	WL140V 40S/827_830_840 PSED WH	872110330716399	108415706
911401874087	WL140V 40S/827_830_840 WIA WH	872110330717099	108415707



Rated lumen output in emergency mode: min 300lm

Notes: After installing emergency pack, customers shall ensure that in application, the maximum ambient temperature shall be less than 30°C.



### Disassemble the lamp board

Rotate the knob to open as shown in the picture.

Remove the light board.

### Emergency package schematic diagram

### Accessory kit

2PCS-screws

### Fixed emergency battery pack

The arrow indicates that the hole indicated by EL KIT is fixed, pay attention to the symbol EL KIT.

### Wiring Connection Diagram

### Notes: For emergency details, please refer to the manual provided by the emergency module!

#### Fixed light board

Place the lamp board onto the lamp body

#### Rotate and fix the knob

Insert Indicator Light Bracket into the aluminum substrate hole

Insert the Indicator Light into the Board Bracket

Rotate and fix the knob as shown in the figure