



## PHOTOMETRIC LIGHT REPORT

# Wall lamp | cube 10x10x10cm | black | 6W | 2700K | dim

Article number: 149-144



Go to the  
webshop  
of Tronix  
Lighting



**TRONIX**



149-144 Wall lamp | cube 10x10x10cm | black | 6W | 2700K | dim

## Introduction

### Purpose of this Document

This document provides accurate and objective photometric data for Tronix Lighting item 149-144. All information is based on actual measurements taken from standard production units. No modifications were made to enhance performance results. In some cases, minor adjustments—such as temporary removal of covers, cables, or mounting features—were necessary for testing purposes. These did not influence product performance.

### Test Methodology

Testing was conducted using randomly selected, unopened samples from regular inventory. All tests comply with the LM-79-19 standard, the recognized method for photometric and electrical measurements of LED and OLED luminaires. This standard, an update of IES LM-79-2008, outlines environmental test conditions, stabilization procedures, measurement methods, and approved instruments. It uses absolute photometry, meaning results directly reflect the performance of the tested product, without comparison to rated lamp standards.

### Product 149-144 was tested using:

- A photogoniometer to measure luminous intensity distribution at various angles
- An integrating sphere to determine total luminous flux and colour characteristics

### Compliance & Certification

Item 149-144 meets the requirements of the following EU directives. Tronix Lighting certifies that all relevant tests were executed in accordance with the applicable standards, and the CE mark is applied accordingly:

- General Product Safety – Directive 2023/988/EC
- Low Voltage Directive (LVD) – Directive 2014/35/EU
- Electromagnetic Compatibility (EMC) – Directive 2004/108/EC
- Ecodesign – Directive 2009/125/EC
- RoHS 3 – Directive 2011/65/EU + Amendment 2015/863/EU

### Recycling & Sustainability

Tronix Lighting is affiliated with national recycling systems for electrical and electronic waste. The luminaire is over 90% recyclable when disposed of as electronic waste at end of life. In addition, Tronix Lighting participates in national packaging recycling schemes, ensuring full compliance with both the WEEE and packaging directives.



149-144 Wall lamp | cube 10x10x10cm | black | 6W | 2700K | dim

### Laboratory and equipment

|                                      |  |
|--------------------------------------|--|
| Laboratory owner and location        | Tronix Lighting BV. Uden. The Netherlands  |
| Gonio spectrometer system and type   | Viso Systems Type C. horizontal  |
| Spectrometer manufacturer and model  | (Gonio) Ocean Optics STS VIS<br>(Sphere) Admesy HERA VIS 380–780nm                           |
| Flicker meter manufacturer and model | Viso Systems LabFlicker  |
| Oscilloscope manufacturer and model  | Tektronix MDO3024 oscilloscope (4 Channels. 200 MHz)   |
| Power meter manufacturer and model   | Vitretek PA900 Precision Multi-Channel Harmonic Power Analyzer                               |
| Power source manufacturer and model  | (DC) Keithley Source Measure Unit SMU-2420 3A DC Source Meter<br>(AC) Chroma 61601 AC Source |
| Datalogger Manufacturer and Model    | Omega 8-Channel Thermocouple Thermometer/Data Logger   |

### Measurement conditions gonio spectrometer

|   |  |
|---|--|
| Number of C-planes and Resolution           | 2 planes – 180°                        |
| γ (gamma)-Resolution                        | 1°                                     |
| Test Distance                               | 1.14 m                                 |
| Room Temperature and Humidity               | 22°C +/- 10% – RH 50% +/- 20%          |
| Input Power. Power and Displacement Factors | 6.2 W – PF 0.95 – DPF 0.97             |
| Frequency of Input Power                    | 50 Hz                                  |
| Warm-up Time and Variation                  | Lamp stabilized in 15 min 2 sec --1.9% |

### Tested light source

|                             |  |
|-----------------------------|--|
| Manufacturer and Order Code | Tronix Lighting – 149-144                              |
| Product Description         | Wall lamp   cube 10x10x10cm   black   6W   2700K   dim |

### Main Light Measurement Results

|                                       |   |
|---------------------------------------|---|
| Output – Total Lumen (Up% / Down%)    | 252 lm – 49.36% / 50.64%                  |
| Efficiency                            | 40 lm/W                                   |
| Energy efficiency class               | G   |
| Peak Intensity and Beam Angle         | 62.1 cd – 360°                            |
| Correlated Colour Temperature         | CCT = 2835 K                              |
| Colour Shift. CIE duv                 | Duv 0.0012                                |
| Colour Rendering Index                | CRI 83.4                                  |
| Colour Rendering TM30-18              | R <sub>f</sub> 86.7 – R <sub>g</sub> 95.1 |
| Television Lighting Consistency Index | TLCI = 70                                 |
| Flicker                               | SVM 0 – PstLM 0.02                        |



149-144 Wall lamp | cube 10x10x10cm | black | 6W | 2700K | dim


Electrical measurement details

**Input Power**

|  |         |
|--|---------|
| RMS Input voltage feed. $V_{RMS}$        | 230 V   |
| RMS Input current feed. $I_{RMS}$        | 0.029 A |
| Total input power                        | 6.2 W   |
| Frequency of input power                 | 50 Hz   |
| Power factor                             | 0.95    |
| Displacement power factor                | 0.97    |
| Total harmonic distortion of the current | 20.95%  |
| Total harmonic distortion of the voltage | 2.73%   |

**Input Power Curve**

Voltage - Current



**Efficiency**

Radiated power efficiency: 12.4%




Lumen efficiency: 40 lm/W



**Harmonics**

|               |       |
|---------------|-------|
| 3rd Harmonic  | 17.1% |
| 5th Harmonic  | 8.53% |
| 7th Harmonic  | 5.11% |
| 9th Harmonic  | 2.21% |
| 11th Harmonic | 2.24% |

**Current Harmonics %**



Stabilization Details

**Warm-up Conditions**

|                      |        |
|----------------------|--------|
| Stable period        | 15 min |
| Stable change max    | 2.0%   |
| Minimum warm-up time | 15 min |

**Colour temperature change during warm-up**

|           |        |
|-----------|--------|
| CCT start | 2835 K |
| CCT shift | +1 K   |
| CCT end   | 2835 K |

**Warm-up Results**

|                   |                                 |
|-------------------|---------------------------------|
| Total warmup time | Lamp stabilized in 15 min 2 sec |
| Warmup variation  | -1.9%                           |

**Output intensity change during warm-up**

|               |        |
|---------------|--------|
| Output start  | 256 lm |
| Output change | -4 lm  |
| Output end    | 252 lm |




149-144 Wall lamp | cube 10x10x10cm | black | 6W | 2700K | dim

Colour measurement details


Total lumen output 252 lm  
 Correlated Colour Temperature 2835 K  
 Colour coordinates CIE 1931 (x;y) = (0.451;0.412)  
 Colour deviation from BBL Duv = 0.0012

TM30-18 Colour Fidelity Index R<sub>f</sub> 86.7  
 TM30-18 Colour Gamut Index R<sub>g</sub> 95.1  
 Colour Rendering Index (Ra) CRI 83.4  
 Colour Rendering Index. (red component) R9 = 7.4


Colour Quality Scale CQS = 83.4  
 Television Lighting Consistency Index TLCI = 70



Relative spectral power distribution



TM30 details




TM30 Colour vectors per hue bin




TM30 Colour distortion


| Hue Bin | R <sub>f</sub> | Shifts (%) |      |
|---------|----------------|------------|------|
|         |                | Chroma     | Hue  |
| C1      | 80             | -11%       | 0%   |
| C2      | 82             | -8%        | 6%   |
| C3      | 81             | -3%        | 9%   |
| C4      | 92             | 0%         | 5%   |
| C5      | 95             | 2%         | 3%   |
| C6      | 94             | 1%         | -2%  |
| C7      | 88             | -4%        | -6%  |
| C8      | 94             | -3%        | 0%   |
| C9      | 90             | -5%        | 3%   |
| C10     | 87             | -4%        | 7%   |
| C11     | 86             | 0%         | 10%  |
| C12     | 87             | 5%         | 0%   |
| C13     | 87             | 4%         | -9%  |
| C14     | 81             | 3%         | -16% |
| C15     | 84             | -4%        | -9%  |
| C16     | 77             | -10%       | -14% |



TM30-18 R<sub>f</sub>-values per reference colour




TM30-18 R<sub>f</sub>-values per hue bin




TM30 Chroma shift

Colour Quality details



Colour Rendering Index



Colour Quality Scale



149-144 Wall lamp | cube 10x10x10cm | black | 6W | 2700K | dim

Flicker / temporal light artefacts details

**Measurement conditions**

|                         |  |
|-------------------------|--|
| Flicker meter type      | Viso Systems LabFlicker  |
| Flicker/TLA sample rate | 20000 samples/s  |
| Measurement time        | 5x 180 seconds (15 minutes) for PstLM. 1.2 sec for all other indices |

**Flicker indices according to Illuminating Engineering Society (IES)**


|                   |         |
|-------------------|---------|
| Flicker frequency | 99.5 Hz |
| Percent flicker   | 0.16 %  |
| Flicker index     | 0       |

**TLA indices (according IEC TR 61547-1. EN 61000-3-3 and EN 61000-4-15)**

An LED luminaire is considered flicker-free if the SVM value is  $\leq 0.4$  and if the PstLM value is  $\leq 1.0$

|                              |      |
|------------------------------|------|
| PstLM value (F < 80 Hz)      | 0.02 |
| SVM value (80 < F < 2000 Hz) | 0    |


**Flicker frame (one flicker period in time domain)**



**Flicker FFT (flicker curve in frequency domain)**



**IEEE 1789-2015 Lighting Flicker Risk Zones**




Document revision date: 1-7-2025 Measurement serial: VFR-250508-7247-SW



149-144 Wall lamp | cube 10x10x10cm | black | 6W | 2700K | dim

Beam angle

**Luminous Intensity diagram**



**Main Values**

|                      |                 |
|----------------------|-----------------|
| Output (total Lumen) | 252 lm          |
| Lumen Up/Down        | 49.36% / 50.64% |
| Peak Intensity       | 62.1 cd         |
| Beam Angle (50%)     | 360°            |
| Beam Angle (90%)     | 360°            |
| Beam Angle (10%)     | 360°            |

**Cut-off Angle**

|              |      |
|--------------|------|
| Average 2.5% | 360° |
|--------------|------|

**Field Angle**

|             |      |
|-------------|------|
| Average 10% | 360° |
|-------------|------|


**Intensity Ratio**

|              |       |
|--------------|-------|
| In 120° cone | 48.0% |
| In 90° cone  | 42.4% |

**C planes**

- C000-C180
- C090-C270

**Linear distribution diagram - Intensity (candela) vs γ-angle**




Document revision date: 1-7-2025 Measurement serial: VFR-250508-7247-SW



149-144 Wall lamp | cube 10x10x10cm | black | 6W | 2700K | dim

Beam Details



\*Measured at center of beam

Beam intensities from 1 – 20 m

| 1   | 2   | 3   | 4    | 5    | 6    | 7   | 8    | 9    | 10   | 11   | 12   | 13   | 14   | 15   | 16   | 17   | 18   | 19   | 20   | m  |     |
|-----|-----|-----|------|------|------|-----|------|------|------|------|------|------|------|------|------|------|------|------|------|----|-----|
| 3.3 | 6.6 | 9.8 | 13.1 | 16.4 | 19.7 | 23  | 26.2 | 29.5 | 32.8 | 36.1 | 39.4 | 42.7 | 45.9 | 49.2 | 52.5 | 55.8 | 59.1 | 62.3 | 65.6 | ft |     |
| 61  | 15  | 7   | 4    | 2    | 2    | 1   | 1    | 1    | 1    | 1    | 0    | 0    | 0    | 0    | 0    | 0    | 0    | 0    | 0    | 0  | lux |
| 5.7 | 1.4 | 0.6 | 0.4  | 0.2  | 0.2  | 0.1 | 0.1  | 0.1  | 0.1  | 0    | 0    | 0    | 0    | 0    | 0    | 0    | 0    | 0    | 0    | 0  | fc  |

Intensities in 0° c-plane

| 0°   | 9°   | 18°  | 27°  | 36°  | 45°  | 54° | 63° | 72° | 81° | 90° | 99° | 108° | 117° | 126° | 135° | 144° | 153° | 162° | 171° | γ        |
|------|------|------|------|------|------|-----|-----|-----|-----|-----|-----|------|------|------|------|------|------|------|------|----------|
| 61.4 | 62.0 | 61.6 | 60.2 | 56.8 | 48.3 | 7.7 | 4.5 | 2.2 | 1.4 | 0.1 | 1.8 | 2.8  | 4.8  | 7.6  | 31.5 | 56.4 | 59.5 | 61.1 | 61.7 | cd       |
| 100% | 101% | 100% | 98%  | 92%  | 79%  | 13% | 7%  | 4%  | 2%  | 0%  | 3%  | 5%   | 8%   | 12%  | 51%  | 92%  | 97%  | 100% | 100% | of 0°val |

Intensities in 90° c-plane

| 0°   | 9°   | 18°  | 27°  | 36°  | 45°  | 54° | 63° | 72° | 81° | 90° | 99° | 108° | 117° | 126° | 135° | 144° | 153° | 162° | 171° | γ        |
|------|------|------|------|------|------|-----|-----|-----|-----|-----|-----|------|------|------|------|------|------|------|------|----------|
| 61.4 | 62.0 | 61.6 | 60.2 | 56.8 | 48.3 | 7.7 | 4.5 | 2.2 | 1.4 | 0.1 | 1.8 | 2.8  | 4.8  | 7.6  | 31.5 | 56.4 | 59.5 | 61.1 | 61.7 | cd       |
| 100% | 101% | 100% | 98%  | 92%  | 79%  | 13% | 7%  | 4%  | 2%  | 0%  | 3%  | 5%   | 8%   | 12%  | 51%  | 92%  | 97%  | 100% | 100% | of 0°val |

Intensities in 180° c-plane

| 0°   | 9°   | 18°  | 27°  | 36°  | 45°  | 54° | 63° | 72° | 81° | 90° | 99° | 108° | 117° | 126° | 135° | 144° | 153° | 162° | 171° | γ        |
|------|------|------|------|------|------|-----|-----|-----|-----|-----|-----|------|------|------|------|------|------|------|------|----------|
| 61.4 | 62.0 | 61.6 | 60.2 | 56.8 | 48.3 | 7.7 | 4.5 | 2.2 | 1.4 | 0.1 | 1.8 | 2.8  | 4.8  | 7.6  | 31.5 | 56.4 | 59.5 | 61.1 | 61.7 | cd       |
| 100% | 101% | 100% | 98%  | 92%  | 79%  | 13% | 7%  | 4%  | 2%  | 0%  | 3%  | 5%   | 8%   | 12%  | 51%  | 92%  | 97%  | 100% | 100% | of 0°val |

Intensities in 270° c-plane

| 0°   | 9°   | 18°  | 27°  | 36°  | 45°  | 54° | 63° | 72° | 81° | 90° | 99° | 108° | 117° | 126° | 135° | 144° | 153° | 162° | 171° | γ        |
|------|------|------|------|------|------|-----|-----|-----|-----|-----|-----|------|------|------|------|------|------|------|------|----------|
| 61.4 | 62.0 | 61.6 | 60.2 | 56.8 | 48.3 | 7.7 | 4.5 | 2.2 | 1.4 | 0.1 | 1.8 | 2.8  | 4.8  | 7.6  | 31.5 | 56.4 | 59.5 | 61.1 | 61.7 | cd       |
| 100% | 101% | 100% | 98%  | 92%  | 79%  | 13% | 7%  | 4%  | 2%  | 0%  | 3%  | 5%   | 8%   | 12%  | 51%  | 92%  | 97%  | 100% | 100% | of 0°val |

Document revision date: 1-7-2025 Measurement serial: VFR-250508-7247-SW



149-144 Wall lamp | cube 10x10x10cm | black | 6W | 2700K | dim

Light Planning – UGR table

Uncorrected, comprehensive UGR table according to CIE 117-1995

| Reflectances                        |   | 70   | 70   | 50   | 50   | 30   | 70   | 70   | 50   | 50   | 30   |
|-------------------------------------|---|--|------|------|------|------|--|------|------|------|------|
| ρ Ceiling                           |   | 70   | 70   | 50   | 50   | 30   | 70   | 70   | 50   | 50   | 30   |
| ρ Walls                             |   | 50   | 30   | 50   | 30   | 30   | 50   | 30   | 50   | 30   | 30   |
| ρ Floor                             |   | 20   | 20   | 20   | 20   | 20   | 20   | 20   | 20   | 20   | 20   |
| Room size                           |   | Viewed Crosswise                                   |      |      |      |      | Viewed Endwise                                   |      |      |      |      |
| H = mounting height above eye level |   | (Viewing direction orthogonal to lamp length axis) |      |      |      |      | (Viewing direction parallel to lamp length axis) |      |      |      |      |
| X                                   | Y |  |      |      |      |      |  |      |      |      |      |
| 2H 2H                               |   | 11.3   | 12.0 | 12.2 | 12.8 | 13.9 | 11.3   | 12.0 | 12.2 | 12.8 | 13.9 |
| 3H                                  |   | 11.2   | 11.9 | 12.2 | 12.7 | 13.8 | 11.2   | 11.9 | 12.2 | 12.7 | 13.8 |
| 4H                                  |   | 11.2   | 11.8 | 12.2 | 12.7 | 13.8 | 11.2   | 11.8 | 12.2 | 12.7 | 13.8 |
| 6H                                  |   | 11.3   | 11.8 | 12.2 | 12.7 | 13.8 | 11.3   | 11.8 | 12.2 | 12.7 | 13.8 |
| 8H                                  |   | 11.3   | 11.9 | 12.2 | 12.8 | 13.9 | 11.3   | 11.9 | 12.2 | 12.8 | 13.9 |
| 12H                                 |   | 11.3   | 12.0 | 12.2 | 12.8 | 13.9 | 11.3   | 12.0 | 12.2 | 12.8 | 13.9 |
| 4H 2H                               |   | 11.0   | 11.6 | 12.0 | 12.5 | 13.6 | 11.0   | 11.6 | 12.0 | 12.5 | 13.6 |
| 3H                                  |   | 11.1   | 11.8 | 12.0 | 12.6 | 13.7 | 11.1   | 11.8 | 12.0 | 12.6 | 13.7 |
| 4H                                  |   | 11.1   | 12.0 | 12.1 | 12.6 | 13.7 | 11.1   | 12.0 | 12.1 | 12.6 | 13.7 |
| 6H                                  |   | 11.2   | 11.7 | 12.2 | 12.6 | 13.7 | 11.2   | 11.7 | 12.2 | 12.6 | 13.7 |
| 8H                                  |   | 11.3   | 11.7 | 12.3 | 12.6 | 13.7 | 11.3   | 11.7 | 12.3 | 12.6 | 13.7 |
| 12H                                 |   | 11.3   | 11.6 | 12.3 | 12.6 | 13.7 | 11.3   | 11.6 | 12.3 | 12.6 | 13.7 |
| 8H 4H                               |   | 11.0   | 11.4 | 12.0 | 12.3 | 13.4 | 11.0   | 11.4 | 12.0 | 12.3 | 13.4 |
| 6H                                  |   | 11.2   | 11.5 | 12.2 | 12.5 | 13.6 | 11.2   | 11.5 | 12.2 | 12.5 | 13.6 |
| 8H                                  |   | 11.4   | 11.6 | 12.4 | 12.6 | 13.8 | 11.4   | 11.6 | 12.4 | 12.6 | 13.8 |
| 12H                                 |   | 11.5   | 11.6 | 12.5 | 12.7 | 13.8 | 11.5   | 11.6 | 12.5 | 12.7 | 13.8 |
| 12H 4H                              |   | 11.0   | 11.2 | 11.9 | 12.2 | 13.3 | 11.0   | 11.2 | 11.9 | 12.2 | 13.3 |
| 6H                                  |   | 11.2   | 11.4 | 12.2 | 12.5 | 13.7 | 11.2   | 11.4 | 12.2 | 12.5 | 13.7 |
| 8H                                  |   | 11.4   | 11.6 | 12.4 | 12.6 | 13.7 | 11.4   | 11.6 | 12.4 | 12.6 | 13.7 |

Variations with the observer position for the luminaire spacings. S:

|          |            |            |
|----------|------------|------------|
| S = 1.0H | 2.1 / -2.3 | 2.1 / -2.3 |
| S = 1.5H | 4.1 / -2.8 | 4.1 / -2.8 |
| S = 2.0H | 5.8 / -3.2 | 5.8 / -3.2 |

Coefficients of Utilization

| Ceiling reflectance | 80   | 70  |     |     | 50 |    |    | 30 |    |    | 10 |    |    | 0  |    |    |    |    |
|---------------------|--|-----|-----|-----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|
| Wall reflectance    | 70   | 50  | 30  | 10  | 70 | 50 | 30 | 10 | 50 | 30 | 10 | 50 | 30 | 10 | 0  |    |    |    |
| Floor reflectance   | 20   | 20  | 20  | 20  | 20 | 20 | 20 | 20 | 20 | 20 | 20 | 20 | 20 | 20 | 0  |    |    |    |
| RCR                 | (RCR: Room Cavity Ratio)   |     |     |     |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
|                     | Room Values are expressed as percentage of Lumen delivered to the task surface |     |     |     |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| 0                   | 107  | 107 | 107 | 107 | 99 | 99 | 99 | 99 | 84 | 84 | 84 | 70 | 70 | 70 | 57 | 57 | 57 | 51 |
| 1                   | 99   | 95  | 92  | 89  | 92 | 88 | 86 | 83 | 75 | 73 | 71 | 63 | 62 | 61 | 52 | 51 | 51 | 45 |
| 2                   | 92   | 85  | 80  | 75  | 85 | 79 | 74 | 70 | 68 | 64 | 61 | 57 | 55 | 53 | 48 | 46 | 45 | 40 |
| 3                   | 84   | 76  | 69  | 64  | 78 | 71 | 65 | 61 | 61 | 57 | 53 | 52 | 49 | 46 | 44 | 42 | 40 | 36 |
| 4                   | 78   | 68  | 61  | 56  | 72 | 64 | 57 | 53 | 55 | 50 | 47 | 47 | 44 | 41 | 40 | 37 | 35 | 32 |
| 5                   | 72   | 61  | 54  | 49  | 67 | 57 | 51 | 46 | 50 | 45 | 41 | 43 | 39 | 36 | 37 | 34 | 32 | 29 |
| 6                   | 67   | 56  | 48  | 43  | 62 | 52 | 45 | 41 | 45 | 40 | 37 | 39 | 35 | 32 | 34 | 31 | 29 | 26 |
| 7                   | 62   | 51  | 43  | 38  | 57 | 47 | 41 | 36 | 42 | 36 | 33 | 36 | 32 | 29 | 31 | 28 | 26 | 23 |
| 8                   | 58   | 46  | 39  | 34  | 53 | 43 | 37 | 32 | 38 | 33 | 29 | 33 | 29 | 26 | 29 | 26 | 23 | 21 |
| 9                   | 54   | 42  | 35  | 30  | 50 | 40 | 33 | 29 | 35 | 30 | 26 | 31 | 27 | 24 | 26 | 23 | 21 | 19 |
| 10                  | 50   | 39  | 32  | 27  | 47 | 37 | 30 | 26 | 32 | 27 | 24 | 28 | 24 | 22 | 25 | 22 | 19 | 18 |