

# LICENCE

No. 19775 - Issue No 3

Issued to: Applicant: ABB S.p.A. Via Vittor Pisani, 16 20124 MILANO Italy

Licensee: ABB S.p.A. Via Vittor Pisani, 16 20124 MILANO Italy

Product : socket-outlets (2-pole)

Trade name(s) : ABB

Type(s)/model(s) : M1174

The product and any acceptable variation thereto is specified in the annex to this licence and the documents therein referred to.

SGS CEBEC hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard specified in annex
- an inspection of the production location
- a certification agreement with the number 1076

SGS CEBEC hereby grants the right to use the CEBEC certification mark

The CEBEC certification mark may be applied to the product as specified in
this licence for the duration of the CEBEC certification agreement and under the
conditions of the CEBEC certification agreement.

This licence is issued on

18/02/2021

ir. C. Lana,

**Certification Manager** 

© Only integral publication of this certificate, including the annex, is allowed This certificate is only valid combined with the publication on the following web address: www.sgs.com/ee







SGS Belgium NV-Division SGS CEBEC Business Riverside Park Bld Internationalelaan 55 Build. K B-1070 Brussels Tel.+32(0)2 556 00 20 Fax.+32(0)2 556 00 36 This certificate is issued by the company under its General Conditions for Certification Services accessible at <a href="http://www.sgs.com/terms\_and\_conditions.htm">http://www.sgs.com/terms\_and\_conditions.htm</a>. Attention is drawn to the limitations of liability defined therein and in the Test Report herein mentioned which findings are reflected in this Certificate. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.



#### SPECIFICATION OF THE CERTIFIED PRODUCT

### **Product data**

Product : socket-outlets (2-pole)

Trade name(s) : ABB

Type(s)/Model(s) : M1174

rated current (In) : 16 A

rated voltage (Un) : 250 V

nature of supply : AC

earthing : with earthing pin

existence of shutters : with shutters

design : screw terminals

standard sheet : V of NBN C 61-112-1

description : for build-in purposes, snap-on mounting rail

certification mark : complies with the requirements

markings : are shown on the body

#### **TESTS**

#### **Test requirements**

NBN C 61-112-1 based on IEC 60884-1:2002 + A1:2006

#### **Test results**

The test results are laid down in certification file ref. 613535/03

#### **Remarks**

This certificate is based on the CEBEC test report Nr.613535.01

ANNEX TO CEBEC LICENCE No. 19775 - Issue No 3 Page 2 of 3



## Conclusion

The examination proved that all certification requirements were met.

Reviewed by, project leader : Luigi Zanutto - 18/02/2021

Certification Manager

2021-02-18