


24P-1604: Radiator connection nickel-plated 300mm copper pipe 16x15cu



Commercial information

This brass press elbow connection for radiator is nickel-plated and also includes a nickel-plated copper tube of 300mm.

Basic unit dimensions

Height	92 mm
Length	310 mm
Width	22 mm
Net weight	0.177 kg

Certificates

ATG, DVGW Wasser, ETA, KIWA, ÖVGW Wasser, WRAS, KOMO, STF, ÖN EN 21003-2/-3, GOST-R, ITC, TSU, QB (CSTBat), AFNOR, ACS, PZH, DNV-GL, EMI

Applications

Potable water, Heating, Compressed air, Cooling, Sanitary

Solutions

Building installations, Industry, Utility, Shipbuilding

Technical characteristics

Material connection 1	Brass	Bend radius	16 Millimetre
Material quality connection 1	CuZn40Pb2 (CW617N)	Outer pipe diameter connection 1	16 Millimetre
Surface protection connection 1	Nickel-plated	Length	310 Millimetre
Material connection 2	Copper	Length of connection 1	84 Millimetre
Material quality connection 2	CuZn40Pb2 (CW617N)	Working length connection 1	84 Millimetre
Surface protection connection 2	Nickel-plated	Length of connection 2	300 Millimetre
Shape	Bend	Working length connection 2	300 Millimetre
Reducing	✘	Wrench width union nut	0 Millimetre
Eccentric	✘	Medium temperature (continuous)	-10 70 Degrees celsius
System specific	✓	Max. operating pressure at 20 °C	16 Bar
Connection 1	Press sleeve	Standard Dimension Ratio (SDR)	0
Contour code connection 1	TH		
Nominal diameter connection 2	1/2 inch (15)		
Connection 2	Soldered end		
Main colour fitting	Grey		
Material sealing	Ethylene-propylene diene monomer rubber (EPDM)		
With buffer stud	✘		
High tensile strength	✘		
With thermal insulation	✘		
Ring stiffness class	Other		
With sealing rings/gaskets	✓		
Capped	✘		
With drain valve	✘		
With de-aerator	✘		
FM quality mark	✘		
LPCB quality mark	✘		
ULC quality mark	✘		
UL quality mark	✘		
DIN-CERTCO certificate	✘		
VdS quality mark	✘		
With approval for TÜV	✘		
DVGW quality mark for gas	✘		
DVGW quality mark for water	✘		
KIWA certified	✓		
Gastec QA mark	✘		
KOMO certified	✘		
Type approval according to BBR/EKS	✘		