

Compliance Document

No. D 083373 0074 Rev. 01

Holder of Certificate: **JIANGSU GOODWE POWER SUPPLY TECHNOLOGY CO., LTD.**


No. 90 Zijin Road
New District
215011 Suzhou
PEOPLE'S REPUBLIC OF CHINA

Product: **Converter**
Grid-Tied PV Inverter

This Compliance document confirms the compliance with the listed standards on a voluntary basis. It refers only to the sample submitted for testing and certification and does not certify the quality or safety of the serial products. For details see: www.tuvsud.com/ps-cert

Test report no.: 704092105202-01

Date, 2021-09-30



(Zhengdong Ma)

Compliance Document

No. D 083373 0074 Rev. 01

Model(s): GW225K-HT, GW250K-HT,
GW225KN-HT, GW250KN-HT.

Parameters:

Model	GW225K-HT	GW250K-HT
Max. Input Voltage	1500Vd.c.	1500Vd.c.
Rated Input Voltage	500-1500V	500-1500V
Max. Input Current	12x30A	12x30A
Isc PV	12x50A	12x50A
Rated Output Voltage	3L/PE~ 800Va.c.	3L/PE~ 800Va.c.
Rated Output Frequency	50/60 Hz	50/60 Hz
Max. Output Current	a.c. 178.7A	a.c. 180.5A
Rated Output Power	225 kW	250 kW
Max. Apparent Power	247.5 kVA	250 kVA
Safety Class	I	I
Overvoltage Category	III(AC), II(DC)	III(AC), II(DC)
Enclosure	IP66	IP66
Operating ambient temperature range	-30°C ...+60°C	-30°C ...+60°C

Compliance Document

No. D 083373 0074 Rev. 01

Model	GW225KN-HT	GW250KN-HT
Max. Input Voltage	1500Vd.c.	1500Vd.c.
Rated Input Voltage	500-1500V	500-1500V
Max. Input Current	6x60A	6x60A
Isc PV	6x90A	6x90A
Rated Output Voltage	3L/PE~ 800Va.c.	3L/PE~ 800Va.c.
Rated Output Frequency	50/60 Hz	50/60 Hz
Max. Output Current	a.c. 178.7A	a.c. 180.5A
Rated Output Power	225 kW	250 kW
Max. Apparent Power	247.5 kVA	250 kVA
Safety Class	I	I
Overvoltage Category	III(AC), II(DC)	III(AC), II(DC)
Enclosure	IP66	IP66
Operating ambient temperature range	-30°C ...+60°C	-30°C ...+60°C

**Tested
according to:**

EN 50549-2:2019/AC:2019