



Product Service

# CERTIFICATE

No. B 044254 0060 Rev. 00

**Holder of Certificate:** **ABB Stotz-Kontakt GmbH**

Eppelheimer Str. 82  
69123 Heidelberg  
GERMANY

**Certification Mark:**



**Product:**

**Power supplies  
( AC-DC Din Rail Mountable Power Supplies )**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the Testing, Certification, Validation and Verification Regulations of TÜV SÜD Group have to be complied. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 6121025000601

**Valid until:** 2029-12-18

**Date,** 2025-01-20

( Ralph Lai )



# CERTIFICATE

No. B 044254 0060 Rev. 00

**Model(s):** CP-D 24/2.5

**Brand Name:** ABB



**Parameters:**

Rated inputs:	100-240 Vac, 47-63 Hz, 1500 mA
Rated outputs:	24 Vdc, 2.5 A, 60 W
Protection class:	II
Max. ambient temperature:	55 °C

**Remarks:**

1. When installing, all requirements of below mentioned test standards must be fulfilled.
2. The equipment is evaluated for operating in altitude up to 5,000 m above the sea level.

**Tested according to:** EN IEC 62368-1:2020/A11:2020