





GLV <i>081-10</i>	GINLONG	Solis	
C10/26 - DECLARATION OF CONFORMITY for power-generating units GLV ed2.1.2 (12/2019)			
for the application of annex D "Technical basic requirements regarding the power-generation units" of the Synergrid prescription C10/11 ed2.1 (01/09/2019)			

The undersigned,	Manufacturer:	Ginlong Technologies Co., Ltd.	Represented by:	Pan Ruyi
	Address:	No. 57 Jintong Road, Binhai Industril Park Xiangshan, Ningbo, Zhejiang, 31572, China	Country:	China.
			email:	<u>ruyi.pan@ginlong.com</u>
			Telephone:	57465802188

Hereby declares that each production unit completed in the list in tab 'list of power-generating units' of this homologation application complies with the following conditions:

- The power-generating unit complies with the relevant requirements set out in annex D "Technical basic requirements regarding the power-generation units" of the Synergrid prescription C10/11 ed2.1 (01/09/2019).
- In order to substantiate this, a separate technical file has been submitted at least for each separate product series of the 'C10/26 list of power-generating units' of this homologation application. Each technical file shall be drawn up on the basis of a checklist Annex D, duly and correctly completed by the manufacturer, accompanied by all the required proof of conformity.
 - For technical requirements for which the required proof of conformity (column J in checklist annex D) is a declaration of honour by the manufacturer, the manufacturer declares by signing and dating this declaration of conformity the correctness of the information (conform / not conform / not applicable) provided by him or her in columns K, L and M of this checklist.
 - For technical requirements for which the required proof of conformity (column J in checklist Annex D) is a test report or a certificate, the necessary test reports and/or certificates are available * in the technical file:
 - Certificates have been issued by an EN 45011 (or ISO 17065:2012) certification body accredited for these materials.
 - Test reports have been established by an ISO 17025:2005 or ISO 17065:2012 laboratory accredited for these tests.
 - A list of the document references or the certificates of conformity referred to in the checklist Annex D is also available in the technical file.



Done at:	Ningbo	Homologated by Synergrid on:	<i>14/10/22</i>
On:	2022/11/7	Stamp Synergrid & signature:	<i>[Signature]</i>
(stamp manufacturer & signature)		SYNERGRID a.s.b.l.-v.z.w. Galerie Ravenstein 4/2 BE-1000 Bruxelles/Brussel V.A./B.F.W : BE 0402 858 001 	

* Transition period till 01/05/2020 (see exceptions in chapter 3 of C10/11 ed 2.1 (01/09/2019)):
 If at the time of submission of this homologation application it is not yet possible to submit all the necessary certificates and/or test reports (exception 3), or that the units do not yet have all the required characteristics (exceptions 1 and 2), a **temporary homologation** may be granted. All necessary certificates and/or test reports must be in the possession of Synergrid at the latest on 30/04/2020 in order to obtain a final homologation. if this is not the case, the temporary C10/26 homologation will be withdrawn.

POWER-GENERATING UNITS TO BE HOMOLOGATED FOR LIST C10/26 ACCORDING TO THE REQUIREMENTS OF ANNEX D OF THE TECHNICAL PRESCRIPTION C10/11 ed2.1 (01/09/2019)



2. C10/26 list with power-generating units in accordance with annex D of C10/11 ed2.1 (01/09/2019)

GLV081-10	GINLONG	Solis
-----------	---------	-------

checklist ed 2.1.2 (12/2019)

1	2	3	4	5	6		7		8	9	10	11					12					13		14		15													
					Name and reference of the power control system		P _{ac,r} rated (active) power (W)	S _{max} maximum apparent power (VA)				1-phase or 3-phase	D.3 inverter automatic separation system	ADDITIONAL CHARACTERISTICS				LIMITATIONS				APPLICATION					Synergrid approval date												
					power control system type EnFuRi	other power control system								D.1	D.2	0	D.1	D.2	D.3	D.4	D.5	D.6	D.7	D.8	D.9	D.10	D.11	D.12	D.13	D.14	D.15	Temporary homologation (expires on 01/09/2020)	Final homologation						
														TRIG type B ready* = suitable for use in installation ≥ 11kW	power response to underfrequency additional operating frequency range (51.5 Hz - 52.5 Hz)	active power reduction (PU)	compliant power control system provided (e.g. EnFuRi)	only homologated for connection to HV-network	only homologated for small power-generating installations	only homologated as a backup power system according to §2.1.1	only homologated for use in module < 800W	only homologated for connection to HV-network	Solar energy	Wind energy	CHP (combined heat & power)	Energy storage	Backup power system	Other											
GLV081-10-0001	Solis	S5-GR3P(3-20)K	S5-GR3P3K	V34			3.000	3.300	3-phase	x	x	x		x																									
GLV081-10-0002	Solis	S5-GR3P(3-20)K	S5-GR3P4K	V34			4.000	4.400	3-phase	x	x	x		x																									
GLV081-10-0003	Solis	S5-GR3P(3-20)K	S5-GR3P5K	V34			5.000	5.500	3-phase	x	x	x		x																									
GLV081-10-0004	Solis	S5-GR3P(3-20)K	S5-GR3P6K	V34			6.000	6.600	3-phase	x	x	x		x																									
GLV081-10-0005	Solis	S5-GR3P(3-20)K	S5-GR3P8K	V34			8.000	8.800	3-phase	x	x	x		x																									
GLV081-10-0006	Solis	S5-GR3P(3-20)K	S5-GR3P9K	V34			9.000	9.900	3-phase	x	x	x		x																									
GLV081-10-0007	Solis	S5-GR3P(3-20)K	S5-GR3P10K	V34			10.000	11.000	3-phase	x	x	x		x																									
GLV081-10-0007	Solis	S5-GR3P(3-20)K	S5-GR3P12K	V34			12.000	13.200	3-phase	x	x	x		x																									
GLV081-10-0008	Solis	S5-GR3P(3-20)K	S5-GR3P12K	V34			13.000	14.300	3-phase	x	x	x		x																									
GLV081-10-0009	Solis	S5-GR3P(3-20)K	S5-GR3P13K	V34			15.000	16.500	3-phase	x	x	x		x																									
GLV081-10-0010	Solis	S5-GR3P(3-20)K	S5-GR3P15K	V34			17.000	18.700	3-phase	x	x	x		x																									
GLV081-10-0011	Solis	S5-GR3P(3-20)K	S5-GR3P17K	V34			20.000	22.000	3-phase	x	x	x		x																									
GLV081-10-0012	Solis	S5-GR3P(3-20)K	S5-GR3P20K	V34			5.000	5.500	3-phase	x	x	x		x																									
GLV081-10-0013	Solis	S5-GR3P(5-10)K-LV	S5-GR3P5K-LV	V32			6.000	6.600	3-phase	x	x	x		x																									
GLV081-10-0014	Solis	S5-GR3P(5-10)K-LV	S5-GR3P6K-LV	V32			8.000	8.800	3-phase	x	x	x		x																									
GLV081-10-0015	Solis	S5-GR3P(3-20)K	S5-GR3P8K-BE	V34					3-phase																														

SYNERGRID a.s.b.l.-v.z.w.
 Galerie Ravensteingalerij 4/2
 BE-1000 Bruxelles/Brussel
 T.V.A./B.T.W.: BE 402 958 091

锦浪科技股份有限公司
 GINLONG TECHNOLOGIES CO.,LTD.