

产品认证证书

II型自愿认证

证书编号: CQC20012271919

发证日期: 2021年06月04日

有效期至: 2025年10月30日

委托人名称 ABB Electrification Sweden AB Motor Starting & Safety
及注册地址 Motorgrand 20, 72161 Vasteras, Sweden

制造商名称 ABB Electrification Sweden AB Motor Starting & Safety
及注册地址 Motorgrand 20, 72161 Vasteras, Sweden

生产企业名称 ABB Electrification Sweden AB Motor Starting & Safety
及生产地址 Motorgrand 20, 72161 Vasteras, Sweden

产品名称和系列、规格、型号 直流接触器
GF875-20-**-**, GF1050-20-**-**, GF1325-20-**-**, 参数及型号解释详见附件

产品标准和技术要求 GB/T 14048.4-2020

认证模式 产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站 (www.cnca.gov.cn) 查验证书信息



授权签字人

签发

陈昕

陆楠



中国质量认证中心



<http://www.cqc.com.cn>

中国·北京·南四环西路188号9区 100070

电话: +86 10 83886666

C(2) 0055503

CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC20012271919

Valid from: Jun.04,2021

Valid until: Oct.30,2025

NAME AND REGISTERED ADDRESS OF THE APPLICANT ABB Electrification Sweden AB Motor Starting & Safety
Motorgrand 20, 72161 Vasteras, Sweden

NAME AND REGISTERED ADDRESS OF THE MANUFACTURER ABB Electrification Sweden AB Motor Starting & Safety
Motorgrand 20, 72161 Vasteras, Sweden

NAME AND LOCATION OF THE FACTORY ABB Electrification Sweden AB Motor Starting & Safety
Motorgrand 20, 72161 Vasteras, Sweden

PRODUCT NAME, MODEL AND SPECIFICATION DC Contactor
GF875-20-**-**, GF1050-20-**-**, GF1325-20-**-**;See the Appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS GB/T 14048.4-2020

TYPE OF CERTIFICATION SCHEMES Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

陈昕

SIGNATURE

陆楠



CHINA QUALITY CERTIFICATION CENTRE



<http://www.cqc.com.cn>

Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P.R. China

Tel: +86 10 83886666

C(2) 0055503

产品认证证书

II型自愿认证

证书编号: CQC20012271919

第1页 共2页

本证书及附件应同时使用, 信息查验说明见证书页

纸号: 55503

GF875-20-**-**, GF1050-20-**-**, GF1325-20-**-**; 型号解释详见附件;

Ui: 1500V;

Uimp: 8kV;

Ith: 875A, 1050A, 1325A;

DC-1: Ue/Ie: 1500V/210A;

DC-PV3: Ue/Ie: 1500V/875A (GF875-20-**-**), 1500V/1050A (GF1050-20-**-**);

DC-PV3: Ue/Isc1: 1500V/210A;

极数: 2P;

Us: Code 51: 24-60V 50/60Hz, DC,

Code 53: 100-250V 50/60Hz, DC;

配用辅助触头: (外置)

侧面装辅助触点 CAL20 零个/一个/二个, 每个包含常开和常闭触点各一对;

CQC 证书编号: CQC2019010304241562

Ith: 16A;

Ui: 690V;

AC-15: 127V/6A, 220-240V/4A, 280-440V/3A, 500-690V/2A;

DC-13: 24V/3A, 48V/1.5A, 72V/1A, 125V/0.55A, 250V/0.3A;

1NO1NC, 2NO2NC



中国质量认证中心



产品认证证书

II型自愿认证

证书编号: CQC20012271919

本证书及附件应同时使用, 信息查验说明见证书页

第 2 页 共 2 页

纸号: 55503

型号解释:

Example: GF875-20-11-53				
1 (GF875)	2 (20)	3 (11)	4 (53)	

1 = Name of series and size of contactor 接触器系列名称及大小

GF875 = Basic model 基本型号

GF1050 = Basic model 基本型号

GF1325 = Basic model 基本型号

2: Number of main contacts

20 = 2 NO- and 0 NC-contacts 2 常开

3: Number of NO and NC auxiliary contacts 辅助触头(CAL20-11)

00 = without auxiliary contact 无辅助触头

11 = 1 NO- and 1 NC-contacts (side mounted 侧装 CAL20-11)

22 = 2 NO- and 2 NC-contacts (side mounted, 侧装 2 pieces CAL20-11)

4: Control supply voltage code 线圈代号

51: $U_s = 24-60V$ 50/60Hz d.c.

53: $U_s = 100-250V$ 50/60Hz d.c.



中国质量认证中心

