



Ref. Certif. No.

SE-96221

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Contactor

Name and address of the applicant

ABB AB, Control Products,
Motorgränd 20,
721 61 Västerås,
SWEDEN

Name and address of the manufacturer

Same as applicant

Name and address of the factory

Note: When more than one factory, please report on page 2

Same as applicant

Ratings and principal characteristics

DC-1: Ue=1500 V DC, Ie=210 A
Ith=1325A
Ui= 1500 V DC, Uimp= 8kV

Trademark (if any)

ABB

Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

GF1325-20

Additional information (if necessary may also be reported on page 2)

See also page 2

A sample of the product was tested and found to be in conformity with

IEC 60947-4-1:2018

As shown in the Test Report Ref. No. which forms part of this Certificate

1905129VAS-002

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Box 1103
SE-164 22 Kista, Sweden
Int +46 8 750 00 00

Date: 21 November 2019

intertek

Signature:

Henrik Wikström

Additional information (if necessary)

Rated impulse withstand voltage Uimp: 8kV (main) / 6kV (control)
EMC environment A.

Type key GF1325

GF1325	20	22	53
I	II	III	IV

I - Basic Cat No.

GF1325

II - Number of mains contacts

20 - 2 NO, 0 NC

III - Number of auxiliary contacts CAL20-11, CAL20-11B

00 - 0 NO, 0 NC

11 - 1 NO, 1 NC

22 - 2 NO, 2 NC

IV - Power supply

51 - Power supply 24-60V 50/60Hz d.c.

52 - Power supply 48-130V 50/60Hz d.c.

53 - Power supply 100-250V 50/60Hz d.c.

54 - Power supply 250-500V 50/60Hz d.c.

Date: 21 November 2019

Signature:

