

IEC**IECEE**
CB
SCHEME

Ref. Certif. No.

CN48358

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Contactors

Name and address of the applicant

ABB Xinhui Low Voltage Switchgear Co.,Ltd.
Jinguzhou Industrial Development Zone, Xinhui District,
Jiangmen City, Guangdong Province, P.R.China

Name and address of the manufacturer

ABB Xinhui Low Voltage Switchgear Co.,Ltd.
Jinguzhou Industrial Development Zone, Xinhui District,
Jiangmen City, Guangdong Province, P.R.China

Name and address of the factory

ABB Xinhui Low Voltage Switchgear Co.,Ltd.
Jinguzhou Industrial Development Zone, Xinhui District,
Jiangmen, Guangdong Province, P.R.China*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

See the Appendix

Trademark (if any)

ABB

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

AS09, AS12, AS16, ASL09, ASL12, ASL16

Additional information (if necessary may also be reported on page 2)

IEC 60947-4-1:2018

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2019CQC-088084

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Oct.21,2019

Signature:

Lu Mei

CB 0054322

AS09, AS12, AS16, ASL09, ASL12, ASL16

Uimp:6kV;

Ui: 690V;

AS09, ASL09:

Ith: 22A(Screw Type Connection),20A(Spring Type Connection);

AC-3:Ue/Ie:220/230/240/9A,400-415V/9A,440V/8A,500V/8A,690V/5A;

AC-4:Ue/Ie:230V/7.2A,400-415V/7.2A,500V/5.6A,690V/4A;

AC-1:Ue/Ie:690V/22A(Screw Type Connection),690V/20A(Spring Type Connection);

AC-8a:Ue/Ie:400V/12A;

AS12, ASL12:

Ith: 25A(Screw Type Connection),22A(Spring Type Connection);

AC-3:Ue/Ie:220/230/240/12A,400-415V/12A,440V/11A,500V/11A,690V/7A;

AC-4:Ue/Ie:230V/9.6A,400-415V/9A,500V/8A,690V/5.6A;

AC-1:Ue/Ie:690V/24A(Screw Type Connection),690V/22A(Spring Type Connection);

AC-8a:Ue/Ie:400V/16A;

AS16, ASL16:

Ith: 25A(Screw Type Connection),22A(Spring Type Connection);

AC-3:Ue/Ie:220/230/240/15.7A,400-415V/15.7A,440V/13.6A,500V/12.5A,690V/9A;

AC-4:Ue/Ie:230V/12.6A,400-415V/12.4A,500V/10A,690V/7.2A;

AC-1:Ue/Ie:690V/24A(Screw Type Connection),690V/22A(Spring Type Connection);

AC-8a:Ue/Ie:400V/22A;

Us:AC:24V,42V,48V,110V,115V,220V,230V,240V,400V,415V(50/60Hz),

120V,277V(60Hz),380V(50Hz),

DC:12V,24V,48V,60V,110V,125V,220V,240V;

IP20;

3P;

Auxiliary contact:(AS,ASL)

Ith:10A;

AC-15:Ue/Ie: 24-127V/6A, 220-240V/4A, 380-440V/3A, 500-690V/2A;

DC-13:Ue/Ie: 24V/6A, 48V/2.8A, 72V/1A, 110V/0.55A, 125V/0.55A, 220-250V/0.3A;

AS-30-10,ASL30-10:1NO,

Page 1 of 2

Additional information (if necessary)

Date: Oct.21,2019

Signature:



Lu Mei


AS-30-01,ASL30-01:1NC,
AS-30-32,ASL30-32:3NO2NC

Page 2 of 2

Additional information (if necessary)

Date: Oct.21,2019

Signature:



Lu Mei