

GLV 073-12	HUAWEI	SUN2000
<b>C10/26 - DECLARATION OF CONFORMITY for power-generating units</b> <b>GLV ed2.1.2 (12/2019)</b>		
<b>for the application of annex D "Technical basic requirements regarding the power-generation units" of the Synergrid prescription C10/11 ed2.1 (01/09/2019)</b>		




The undersigned,	Manufacturer:	Huawei Technologies (Netherlands) B.V	Represented by:	Mustafa Temur
	Address:	Herikerbergweg 36, 1101CM Amsterdam Zuid-Oost, The Netherlands	Country:	Belgium
			email:	<a href="mailto:mustafa.temur1@huawei.com">mustafa.temur1@huawei.com</a>
			Telephone:	0032 475826664

**Hereby declares that each production unit completed in the list in tab 'list of power-generating units' of this homologation application complies with the following conditions:**

- The power-generating unit complies with the relevant requirements set out in annex D "Technical basic requirements regarding the power-generation units" of the Synergrid prescription C10/11 ed2.1 (01/09/2019).
- In order to substantiate this, a separate technical file has been submitted at least for each separate product series of the 'C10/26 list of power-generating units' of this homologation application. Each technical file shall be drawn up on the basis of a checklist Annex D, duly and correctly completed by the manufacturer, accompanied by all the required proof of conformity.
  - For technical requirements for which the required proof of conformity (column J in checklist annex D) is a declaration of honour by the manufacturer, the manufacturer declares by signing and dating this declaration of conformity the correctness of the information (conform / not conform / not applicable) provided by him or her in columns K, L and M of this checklist.
  - For technical requirements for which the required proof of conformity (column J in checklist Annex D) is a test report or a certificate, the necessary test reports and certificates are available \* in the technical file:
    - Certificates have been issued by an EN 45011 (or ISO 17065:2012) certification body accredited for these materials.
    - Test reports have been established by an ISO 17025:2005 or ISO 17065:2012 laboratory accredited for these tests.
    - A list of the document references or the certificates of conformity referred to in the checklist Annex D is also available in the technical file.

**REAL HOMOLOGATION**  
 The manufacturer declares by signing and dating this declaration of conformity the correctness of the information provided by him or her in columns K, L and M of this checklist.

Done at: Amsterdam	(location)	
On: 11-01-2021	(date)	
(stamp manufacturer & signature)		 

1 Homologated by Synergrid on: 14/04/21  
 Stamp Synergrid & signature:

\* Transition period till 01/05/2020 (see exceptions in chapter 3 of C10/11 ed 2.1 (01/09/2019)):



11	Additional characteristics	In these columns optional additional characteristics of the units are indicated, following the information in checklist annex D and the corresponding technical file. Put an "x" at each relevant additional characteristic. Note: Only units < 1 MW that are "type B ready" may be applied in an installation ≥ 1 MW (installation "type B" according to the European Network Code RfG). A unit < 1 MW is only "type B ready" if it complies with all optional properties ticked in column I of the checklist Annex D.
12	Limitations	These columns specify limitations of the units to their application in certain types of installations, in accordance with the information in the checklist in annex D and the corresponding technical file. Put an "x" to each relevant limitation.
13	Application	Indicate the applications for which the unit is suitable. Include an "x" with each application for which the unit can be used.
14	Synergrid approval date Temporary homologation (expires on 01/05/2020)	Date on which the submitted homologation file was approved by Synergrid for a limited period of time. - A temporary homologation is granted if the applicant invokes exceptions in chapter 3 of C10/11 ed2.1 (01/09/2019) and has not yet submitted all the test reports required for a definitive homologation with his homologation application (exception 3), or if the units do not yet have all the required properties (exceptions 1 and 2). - The expiry date for a temporary homologation is 01/05/2020 - see conditions in chapter 3 of C10/11 ed.2.1 (01/09/2019).
15	Synergrid approval date Final homologation	Date on which the submitted homologation file was definitively approved by Synergrid. - A final approval will be granted as soon as Synergrid has a fully compliant homologation dossier. - A final homologation only remains valid under the following conditions: - No changes that have an influence on the initial approval are made to (the production of) the units. - There is no new edition of prescription C10/11. - The validity date of the test reports in the technical file submitted for approval has not been exceeded. See also the general Synergrid procedure S1/01 for homologation of material, which is applicable. (1)

(1) - S1/01 Technical specification: procedure for application for homologation and renewal of homologation of materials

FINAL  
HOMOLOGATION

Haveli Technologies (Netherlands) B.V.  
 Leem van Westersloot 50  
 2283 DJ Pijnak  
 1105 MN Amsterdam  
 Tel: +31 (0)20 691 2259  
 www.haveli.nl  
 0000 0000 0000 0000