



Declaration

We,

ABB France - Low Voltage Products - Pôle Foudre Soulé & Hélita
1 avenue des Victimes du 11 juin 1944 - BP 303
65 203 Bagnères-de-Bigorre
France

Hereby certify that the combination of

two Surge Protective Device **OVR T2 40-440 P (TS) QS** in **serial**, on L-PE

is technically equivalent to a Surge Protective Device rated

In 20 kA

I_{max} 40 kA

U_c 880 Vac

U_p 3600 V

Signed for and on behalf of

ABB France – LPED FRFRA
Pôle Foudre Soulé & Hélita

Bagnères-de-Bigorre, December 11th, 2017

Name: Ester Navarro

Function: Product Manager for SPDs