

**IEC****IECEE**

® TM

Ref. Certif. No.

CN64637

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Capacitor Contactor

Name and address of the applicant

ABB Xinhui Low Voltage Switchgear Co.,Ltd.  
Jinguzhou Industrial Development Zone, Xinhui District,  
Jiangmen City, Guangdong Province, P.R.China

Name and address of the manufacturer

ABB Xinhui Low Voltage Switchgear Co.,Ltd.  
Jinguzhou Industrial Development Zone, Xinhui District,  
Jiangmen City, Guangdong Province, P.R.China

Name and address of the factory

ABB India Limited  
No.88/3 to 88/6, Basavanahalli Kasaba Hobli, Nelamangala  
Taluk, Bangalore – 562123, INDIA*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

See the Appendix

Trademark / Brand (if any)

ABB

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

UA95-30-\*-\*;UA110-30-\*-\*;UA95-30-\*-\*RA;UA110-30-\*-\*R  
A;

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60947-4-1:2018;IEC 60947-1:2007;IEC  
60947-1:2007/AMD1:2010;IEC 60947-1:2007/AMD2:2014

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2023CQC-106354

This CB Test Certificate is issued by the National Certification Body

**CHINA QUALITY CERTIFICATION CENTRE**

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Jan.22,2024

Signature:

Xie ZhaoXu

**CB 0075081**

UA95-30-\*,UA110-30-\*,UA95-30-\*RA,UA110-30-\*RA

Ui: 1000V;

Uimp:8kV;

UA95-30-\*

Ith: 145A;

AC-6b: Ue/Ie: 230V-240V/87.9A, 400-415V/93.8A, 440V/85.3A, 500-550V/80.8A, 690V/66.9A;

UA110-30-\*

Ith: 160A;

AC-6b: Ue/Ie: 230V-240V/100.4A, 400-415V/108.3A, 440V/98.4A, 500-550V/92.4A, 690V/75.3A;

UA95-30-\*RA

Ith: 145A;

AC-6b: Ue/Ie: 230V-240V/100.4A, 400-415V/101.0A, 440V/98.4A, 500-550V/98.2A, 690V/100.4A;

UA110-30-\*RA

Ith: 160A;

AC-6b: Ue/Ie: 230V-240V/113.0A, 400-415V/115.5A, 440V/111.5A, 500-550V/109.7A, 690V/108.8A;

Us: 24V 50Hz/24V 60Hz; 48V 50Hz/48V 60Hz; 110V 50Hz/110-120V 60Hz; 105V 50Hz/110-127V 60Hz;

190V 50Hz/220V 60Hz; 220-230V 50Hz/230-240V 60Hz; 230-240V 50Hz/240-260V 60Hz;

230-240V 50Hz/277V 60Hz; 380-400V 50Hz/400-415V 60Hz; 400-415V 50Hz/415-440V 60Hz;

Poles: 3P;

Frequency: 50/60Hz;

IP Code: IP10 (except terminal);

Auxiliary contact: (addition)

CAL18(CQC certification No:CQC23107399059)

1NO1NC,2NO2NC;

Ith: 16A;

Ue/Ie: AC-15: 24-127V/6A, 220-240V/4A, 380-440V/3A, 500-690V/2A;

DC-13: 24V/6A, 48V/2.8A, 72V/1A, 125V/0.55A, 250V/0.3A;

Additional information (if necessary)

Date: Jan.22,2024

Signature:



Xie ZhaoXu