

OVE AUSTRIAN ELECTROTECHNICAL ASSOCIATION

Eschenbachgasse 9, 1010 Wien, Austria
ZVR: 327279890 | DVR: 1055887

OVE - Testing & Certification

Kahlenberger Str. 2A, 1190 Wien, Austria
Phone: +43 1 370 58 06
www.ove.at



ÖVE-CERTIFICATE

including the entitlement to use the Austrian Safety Mark



Certificate No.: **9460-013-03**

Valid from: 2016 06 30
until: 2018 06 30

The Austrian Electrotechnical Association (OVE) hereby grants the right to the company mentioned below to label the listed products with the Austrian Safety Mark.

Company: **NIKO N.V.**
Industriepark-West 40
9100 Sint-Niklaas
Belgium

Product: **Two pole socket outlet with side earthing contacts**

The products submitted by the applicant were type tested in accordance with the requirements of the technical standards and specifications listed in this certificate. OVE certifies the conformity of the listed products and those products manufactured strictly identical to the submitted ones (ISO/IEC 17067, Conformity Assessment Scheme Type 5).

The manufacturing process and the products are subject to ongoing surveillance based on harmonized European procedures. This certificate has been issued under the presumption and conditional on the fact that the applicant holds all necessary legal rights with regard to the product, presented for the testing and certification.

Results of testing are shown in file No(s): **2696-1562/10**

Österreichischer Verband für Elektrotechnik
Head of Testing & Certification

Digitally signed by W. Martin
Email=w.martin@ove.at

Dipl.-Ing. W. Martin

Vienna, 2016 04 11



OVE - Testing & Certification

Accredited by the Federal Ministry of Science, Research and Economy as Certification Body for products within the scope as given in the official decree and published under www.en.bmwf.gv.at/accreditation





Manufacturer:

NIKO N.V.
Industriepark-West 40
9100 Sint-Niklaas
Belgium

Factory location(s):

NIKO N.V.
Industriepark-West 40
9100 Sint-Niklaas
Belgium

Tested and certified according to:

ÖVE/ÖNORM IEC 60884-1:2005-09-01
ÖVE/ÖNORM E 8684-1:2010-03-01

Product: Two pole socket outlet with side earthing contacts

Type designation:
Rating:

Trademark:

| | |
|--|------|
| Series HYDRO IP 55 | NIKO |
| -31+7*-368 Rated voltage: AC 250 V Rated current: 16 A socket-outlet insert with screw terminals and shutter | NIKO |
| 7**-84101 surface mounting box for 1 function with 1 M20 entry | NIKO |
| 7**-84111 surface mounting box for 1 function with 2x1 M20 entry | NIKO |
| 7**-84102 surface mounting box for 1 function with 1x2 M20 entries | NIKO |
| 7**-84112 surface mounting box for 1 function with 1x2 M20 entries + 1 M20 entry | NIKO |
| 7**-84201 vertical surface mounting box for 2 functions with 1 M20 entry | NIKO |
| 7**-84211 vertical surface mounting box for 2 functions with 2x1 M20 entry | NIKO |

OVE - Testing & Certification

Accredited by the Federal Ministry of Science, Research and Economy as Certification Body for products within the scope as given in the official decree and published under www.en.bmwfw.gv.at/accreditation





| | |
|--|------|
| 7**-84202 | NIKO |
| vertical surface mounting box for 2 functions with 1x2 M20 entries | |
| 7**-84212 | NIKO |
| vertical surface mounting box for 2 functions with 1x2 M20 entries + 1 M20 entry | |
| 7**-84801 | NIKO |
| horizontal surface mounting box for 2 functions with 1 M20 entry | |
| 7**-84802 | NIKO |
| horizontal surface mounting box for 2 functions with 1x2 M20 entries | |
| 7**-73000 | NIKO |
| flush mounting box for 1 function | |

OVE - Testing & Certification

Accredited by the Federal Ministry of Science, Research and Economy as Certification Body for products within the scope as given in the official decree and published under www.en.bmfwf.gv.at/accreditation

