



SGS

EU Type Examination Certificate Number: **0120/SGS0468**

Zhejiang Reallin Electron Co., Ltd

No.8 Shuangyang Rd
Renhe Town
Yuhang District
Hangzhou
China

Instrument Identification:
D3001

Three Phase, Import / Export, Electricity Meter

Instrument Traceable Number
0120/SGS0468

has been assessed and certified as meeting the requirements of

EU Directive 2014/32/EU on Measuring Instruments Annex II, Module B

It is certified that the manufacturer's technical design and specimen for the above instrument has been examined and, based on the evidence submitted, it is considered that the instrument conforms to the requirements of Annex V of EU Directive 2014/32/EU

This certificate must be used in conjunction with a certificate covering the product verification as required in Annex II, Module D or Annex II, Module F

This certificate is valid for 10 years from 15th October 2020 until 14th October 2030
Issue 2

Certification is based on report number(s)
SHES200601189201 dated 14th October 2020, SHES200601189201/iss 2 dated 13th November 2020
EMA282502/1/TR50579 dated 1st October 2020
EMA282502/1

Authorised Signature

SGS United Kingdom Limited, Notified Body 0120
Unit 202B Worle Parkway, Weston-super-Mare, BS22 6WA, UK
t +44 (0)1934 522917 f +44 (0)1934 522137 www.sgs.com

Contact Address
SGS United Kingdom Limited, Units 12A & 12B, South Industrial Estate, Bowburn, Durham, DH6 5AD, UK
t +44 (0)191 377 2000 f +44 (0)191 377 2020 www.sgs.com



This document is issued, on the Client's behalf, by the Company under its General Conditions of Service printed overleaf. The Client's attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.


DJ_CST_ME_002 Rev 2

Any other holder of this document is advised that the information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Clients instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents.

EU Type Examination Cert.

SGSPAPER
20295188






	EU-Type Examination Certificate Number:	
	0120/SGS0468	
	Issue Number: 2	Dated: 24 th November 2020

1. Technical Data



Manufacturer	Zhejiang Reallin Electron Co., Ltd
Meter Type	D3001
Voltage Rating (U_n)	3*230/400V
Current Rating ($I_{min} - I_{ref} (I_{max})$)	0.25-5(65)A
Frequency (F_n)	50Hz or 60Hz(IEC Only)
Active Accuracy Class (kWh)	A or B (kWh)
Type of circuit	3P4W
Temperature Range	-30°C to +70°C
Software/ Firmware Version No	1.02
CRC Checksum	C_7C12
Identification Location	LCD
Bill Of Materials Number	D3001 BOM List V1.1
IP Rating	Meter to be installed in a suitable IP rated cabinet
Insulation Protective Class	Class II
LED Pulse Constant	1000imp/kWh
Impulse Voltage Rating	7kV
AC Voltage Rating	4kV
Main Cover Sealing Type	Tamper Proof Sealing Tape
Integrity of meter	Inaccessible without breaking seals
Intended Location of the Meter	Indoor
Type of Register	LCD
Location of Manufacturers Address	Associated Documents


2. Photograph of Meter and Sealing Plan



	EU-Type Examination Certificate Number:	
	0120/SGS0468	
	Issue Number: 2	Dated: 24 th November 2020

3. Examples of Nameplates



	EU-Type Examination Certificate Number:	
	0120/SGS0468	
	Issue Number: 2	Dated: 24 th November 2020

4. Calculation of the composite error/ MPE

During the type approval examination the influence factors for temperature, frequency and voltage are determined per load point. The table below represents the sum of the square values per load, determined via the following formula:-

$$\delta e(T, U, f) = \sqrt{(\delta e^2(T, I, \cos\phi) + \delta e^2(U, I, \cos\phi) + \delta e^2(f, I, \cos\phi))}$$

where

- $\delta e(T, I, \cos\phi)$ = Additional error due to variation of the temperature at the same load
- $\delta e(U, I, \cos\phi)$ = Additional error due to variation of the voltage at the same load
- $\delta e(f, I, \cos\phi)$ = Additional error due to variation of the frequency at the same load




EU-Type Examination Certificate Number:

0120/SGS0468

Issue Number: 2

Dated: 24th November 2020

		Influence Factors for Temperature. Frequency & Voltage							
Current	PF Cos	-40°C	-25°C	-10°C	5°C	30°C	40°C	55°C	70°C
I _{min}	1.0	0.76	0.52	0.31	0.16	0.10	0.13	0.20	0.30
I _{tr}	1.0	0.74	0.50	0.29	0.15	0.06	0.09	0.18	0.28
10I _{tr}	1.0	0.67	0.50	0.30	0.16	0.03	0.02	0.16	0.28
I _{max}	1.0	0.58	0.44	0.28	0.18	0.06	0.19	0.05	0.18
I _{tr}	0.5ind	0.73	0.52	0.32	0.19	0.12	0.13	0.19	0.30
10I _{tr}	0.5ind	0.70	0.46	0.28	0.14	0.06	0.09	0.18	0.31
I _{max}	0.5ind	0.59	0.48	0.33	0.24	0.14	0.07	0.03	0.03
I _{tr}	0.8cap	0.73	0.53	0.33	0.17	0.08	0.11	0.15	0.29
10I _{tr}	0.8cap	0.73	0.50	0.30	0.17	0.05	0.10	0.17	0.28
I _{max}	0.8cap	0.53	0.46	0.32	0.20	0.09	0.04	0.04	0.09
L1									
I _{tr}	1.0	0.73	0.50	0.31	0.13	0.11	0.19	0.27	0.38
10I _{tr}	1.0	0.72	0.51	0.30	0.15	0.13	0.22	0.28	0.39
I _{max}	1.0	0.57	0.44	0.29	0.17	0.07	0.13	0.22	0.26
I _{tr}	0.5ind	0.84	0.58	0.43	0.30	0.20	0.24	0.19	0.15
10I _{tr}	0.5ind	0.86	0.64	0.47	0.34	0.22	0.21	0.21	0.19
I _{max}	0.5ind	0.67	0.59	0.50	0.37	0.31	0.21	0.27	0.26
L2									
I _{tr}	1.0	1.06	0.69	0.42	0.26	0.18	0.18	0.20	0.21
10I _{tr}	1.0	1.05	0.67	0.39	0.23	0.16	0.18	0.18	0.17
I _{max}	1.0	0.71	0.51	0.31	0.18	0.17	0.24	0.27	0.43
I _{tr}	0.5ind	0.97	0.68	0.44	0.34	0.33	0.35	0.33	0.32
10I _{tr}	0.5ind	0.92	0.58	0.29	0.19	0.17	0.12	0.17	0.07
I _{max}	0.5ind	0.62	0.51	0.29	0.18	0.21	0.22	0.28	0.26
L3									
I _{tr}	1.0	0.44	0.33	0.21	0.11	0.14	0.25	0.44	0.68
10I _{tr}	1.0	0.55	0.32	0.21	0.11	0.10	0.25	0.41	0.66
I _{max}	1.0	0.22	0.26	0.18	0.09	0.09	0.18	0.34	0.54
I _{tr}	0.5ind	0.34	0.30	0.17	0.13	0.36	0.55	0.74	0.92
10I _{tr}	0.5ind	0.33	0.27	0.11	0.10	0.39	0.54	0.73	0.92
I _{max}	0.5ind	0.14	0.19	0.06	0.10	0.31	0.46	0.69	0.81


	EU-Type Examination Certificate Number:	
	0120/SGS0468	
	Issue Number: 2	Dated: 24 th November 2020

5. Annex of Variants

Product Variant Identification Details:

Type Designation	Description of meter
D3001	3*230/400V, 0.25-5(65)A, Active Import / Export kWh

Modifications to the meter(s) described according to approval No.**0120/SGS0468** must be notified to the issuing body to confirm the meter(s) continuing compliance to the relevant pattern approval standard(s).

	EU-Type Examination Certificate Number:	
	0120/SGS0468	
	Issue Number: 2	Dated: 24 th November 2020

6. Document Revision History

Issue	Date	Comments
1	15/10/2020	Initial Issue
2	24/11/2020	Improved ESD protection, 60Hz frequency added for IEC range.

This document is issued by the Company subject to its General Conditions for Certification Services, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx>.

Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Unless otherwise stated the results shown in this test report refer only to the sample(s) tested *and such sample(s) are retained for 28 days only.*

END OF CERTIFICATE