

TANÚSÍTVÁNY

Certificate



Tanúsítvány szám Certificate No.
HN 69291752

Oldal Page
0001

Jegyzőkönyv szám Test Report No.
CN230FRD 002

Kiadás dátuma Date of Issue
2026-02-14

Tanúsítvány Tulajdonos Certificate Holder
ESYLUX GmbH & Co. KG
An der Strusbek 40
22926 Ahrensburg
Germany

Gyártóhely Manufacturing Plant
IBV Hungária Kft.
Csanyi út 71.
6100 Kiskunfélegyháza
Hungary

Vizsgálati Jel Test Mark



Tanúsítás alapjául szolgáló előírások Tested according to
EN IEC 60598-1:2021+A11
EN 60598-2-22:2022

Tanúsított Termék (Termék azonosítás)
Certified Product (Product Identification)

Emergency Illumination Device (Emergency Light)

Type designation: OLIVIA-2 MPL 1200 OP 5300 840 IP66 3h 5x2.5,
OLIVIA-2 MPL 1200 OP 5300 840 IP66 3h 5x2.5 DALI-2,
OLIVIA-2 MPL 1500 OP 6300 840 IP66 3h 5x2.5,
OLIVIA-2 MPL 1500 OP 6300 840 IP66 3h 5x2.5 DALI-2

Trade Mark: ESYLUX

An der Strusbek 40
22926 Ahrensburg/Germany

Ratings: AC 220-240V, 50/60Hz; ta: 35°C; Class I; IP66;
Time of duration: 180 minutes; CCT: 2700-4000K

See details in the Annex of this certificate.

A tanúsítvány a fenti termék típusra vonatkozik. A tanúsítvány a TÜV Rheinland InterCert Kft. Vizsgálati, Ellenőrzési és Tanúsítási Szabályzatán alapszik. A tanúsított termék megfelel a fenti vizsgálati előírásoknak, a sorozatgyártása ellenőrzött. A fenti ENEC jel használatának joga engedélyezett a tanúsított terméken. Ezt az Engedélyt egy ENEC egyezményt aláíró testület adta ki. This certificate refers to the above mentioned product type. The certificate is based on the Testing, Inspection and Certification Regulation of TÜV Rheinland InterCert Kft. The certified product fulfils the above listed requirements and its manufacturing is subject to surveillance. The right to use the above ENEC mark is permitted on the certified product. This Licence has been established by a body which is a signatory to the ENEC Agreement.

TÜV Rheinland InterCert Kft., MEEI Division – Product Certification
H-1143 Budapest, Gizella út 51-57., Hungary
www.tuv.com

Tanúsító Szervezet
Certification Body

Eileen Feng

Validity of certificate can be checked on www.CERTIPEDIA.com

Annex to certificate No. HN 69291752 0001

Page 1/1

Model list:

Item	Model	Rated power (W)	LED quantities (pcs)	Weight (kg)	Dimension of product (mm) (LxWxH)	LED driver	Emergency kit	Battery	Rated luminous flux (lm)	Intensity (cd)
1	OLIVIA-2 MPL 1200 OP 5300 840 IP66 3h 5x2.5	36	126	2	1174x10 2x90	Xitanium 65W 200- 350mA 185V DS 230V EL	MJLED3 H4532- 100200	3 Cell, 3.2V, 4.5Ah, 14.4Wh, LiFePO4	5300	147
2	OLIVIA-2 MPL 1200 OP 5300 840 IP66 3h 5x2.5 DALI- 2	36	126	2	1174x10 2x90	LL35HE- DA-80- 400	EMCU TDS 220V/3W /3h/3Li	3 Cell, 3.2V, 4.5Ah, 14.4Wh, LiFePO4	5300	147
3	OLIVIA-2 MPL 1500 OP 6300 840 IP66 3h 5x2.5	42	156	2.3	1454x10 2x90	Xitanium 65W 200- 350mA 185V DS 230V EL	MJLED3 H4532- 100200	3 Cell, 3.2V, 4.5Ah, 14.4Wh, LiFePO4	6300	150
4	OLIVIA-2 MPL 1500 OP 6300 840 IP66 3h 5x2.5 DALI- 2	42	156	2.3	1454x10 2x90	LL50HE- DA-80- 550	EMCU TDS 220V/3W /3h/3Li	3 Cell, 3.2V, 4.5Ah, 14.4Wh, LiFePO4	6300	150

Certification Body


Eileen Feng

Date of issue:

Budapest, 2026-02-14