



Ref. Certif. No.

FR\_722637

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Socket-outlet for fixed-electrical installations  
Socket-outlets for fixed installations

Name and address of the applicant

LEGRAND MAGYARORSZAG VILLAMOSSAGI RENDSZEREK ZRT.  
IPARTELEPI UT 14, 6600 SZENTES - HUNGARY

Name and address of the manufacturer

LEGRAND MAGYARORSZAG VILLAMOSSAGI RENDSZEREK ZRT.  
IPARTELEPI UT 14, 6600 SZENTES - HUNGARY

Name and address of the factory

Note: When more than one factory, please report on page 2

Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

MOSAIC range  
See Annex

Additional information (if necessary may also be reported on page 2)

Supersedes CBTC FR\_706409/M1 dated 26/09/2022.  
Update further to the evolution of the standard(s)  
Addition of factory

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60884-1:2022

As shown in the Test Report Ref. No. which forms part of this Certificate

ARFH-ESH-P25030945

This CB Test Certificate is issued by the National Certification Body



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE  
33 avenue du Général Leclerc  
92260 Fontenay-aux-Roses, FRANCE  
[www.lcie.fr](http://www.lcie.fr)

Date: 25/11/2025

Signature



## ANNEX

**Name and address of the factories:**

**LEGRAND MAGYARORSZAG VILLAMOSSAGI RENDSZEREK ZRT.**  
IPARTELEPI UT 14, 6600 SZENTES - HUNGARY

**LEGRAND FRANCE**  
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY  
87045 LIMOGES CEDEX - FRANCE



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE  
33 avenue du Général Leclerc  
92260 Fontenay-aux-Roses, FRANCE  
[www.lcie.fr](http://www.lcie.fr)

Date: 25/11/2025

Signature:



LABORATOIRE CENTRAL DES  
INDUSTRIES ELECTRIQUES  
S.A.S au capital de 15.745.984 €  
N° de RCS 3174  
33 avenue du Général Leclerc  
92260 FONTENAY AUX ROSES

**Julien GAUTHIER**  
Certification Officer

## ANNEX

### References, ratings and main characteristics:

Reference	Range*	Description	Color of enclosure	with cover plate	with support frame
0 775 05	MOSAIC	2P+E 13A British Standard unswitched 1 gang	White	6 780 11	6 780 00
6 781 48	MOSAIC	2P+E 13A British Standard unswitched 1 gang Antimicrobial	White	6 780 26	6 780 00
6 781 98	MOSAIC	2P+E 13A British Standard unswitched 1 gang	Alu	6 780 31	6 780 00
6 782 40	MOSAIC	2P+E 13A British Standard unswitched 1 gang	Red cover with white cover plate	6 780 11	6 780 00
6 782 41	MOSAIC	2P+E 13A British Standard unswitched 1 gang	Green cover with white cover plate	6 780 11	6 780 00
6 782 42	MOSAIC	2P+E 13A British Standard unswitched 1 gang	Orange cover with white cover plate	6 780 11	6 780 00

\* The "range" denotes applicant's categorization.

### CLASSIFICATION

standard Sheet:	standard sheet of BS 1363-2
rated current (A)	13A
rated load (W)	-
rated voltage (V)	250V
household voltage (V)	-
degree of protection	IP20
provision for earthing	with earthing contact
method of connecting the cable	rewirable
type of terminals	screw-type
type of connections	-
colour	See the table above
<b>socket-outlets</b>	
multiple socket-outlets	
number of socket-outlets	13A : 1
degree of protection against electric shock	normal protection
existence of shutters	with shutters
method of application - mounting	flush-type
method of installation	design A



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE  
 33 avenue du Général Leclerc  
 92260 Fontenay-aux-Roses, FRANCE  
[www.lcie.fr](http://www.lcie.fr)

Date: 25/11/2025

Signature

