CERTIFICATE

Issued to:
Applicant:
Niko N.V.
Industriepark West 40
9100 Sint-Niklaas, Belgium

Licensee:
Niko N.V.
Industriepark West 40
9100 Sint-Niklaas, Belgium

Product	:	Push-buttons, Serie A, B, C, D, E, F and G
Trade name(s)	:	NIKO
Type(s)/model(s)	:	170-700**/***-61105/-, 170-700**/***-61901/-, 170-700**r/***-61105/-, 170-700**r/***-61901/-, 170-730**/***-61105/-, 170-730**/***-61901/-, 170-730**r/***-61105/-, 170-730**r/***-61901/-, 170-7400*/Z/-, 170-859**/***-65914/-, 170-859**r/***-65914/-, 170-959**/***-65918/- and 170-959**r/***-65918/-

The product and any acceptable variation thereof as specified in the Annex to this certificate and the documents referred to therein.

DEKRA hereby declares that the above-mentioned product has been certified based on:
- a type test according to EN 60669-1:2018
- an inspection of the factory location according to CENELEC Operational Document CIG 421
- a DEKRA certification agreement with the number 6069948

DEKRA hereby grants the right to use the DEKRA Mark.

The DEKRA Mark may be applied to the product as specified in this certificate for the duration and under the conditions of the DEKRA Mark certification agreement.

This certificate is issued on 9 April 2026 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 71-174367

DEKRA Certification B.V.

B.T.M. Holtus
Managing Director

Henk Schendstok
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL

PRODUCTS
RvA C 001

71-174367

DEKRA Mark is the new KEMA-KEUR
The DEKRA Mark certificate for this product is to all intents and purposes equivalent to a KEMA-KEUR certificate, the other certification mark used by DEKRA and should be valued and used as such. DEKRA Mark is gradually replacing KEMA-KEUR.
For more information please check: Introducing DEKRA Mark

SPECIFICATION OF THE CERTIFIED PRODUCT

Product data

Product	:	Push-buttons, Serie A, B, C, D, E, F and G
Trade name(s)	:	NIKO
Type(s)/model(s)	:	170-700**/***-61105/-, 170-700**/***-61901/-, 170-700**r/***-61105/-, 170-700**r/***-61901/-, 170-730**/***-61105/-, 170-730**/***-61901/-, 170-730**r/***-61105/-, 170-730**r/***-61901/-, 170-7400*/Z/-, 170-859**/***-65914/-, 170-859**r/***-65914/-, 170-959**/***-65918/- and 170-959**r/***-65918/-
Method of mounting	:	flush-type, screw- or claw-fixing
Markings	:	-tradename, series-indication and electrical ratings on the base -tradename and suffix for the cover on this part

Product data – type 170-700/***-61105/-**

Pattern no.	:	1
Rated current	:	10 A
Rated voltage	:	250 V~
Terminals	:	screw terminals

Product data – type 170-700/***-61901/-**

Pattern no.	:	1
Rated current	:	10 A
Rated voltage	:	250 V~
Terminals	:	screw terminals
Design	:	hotel card

Product data – type 170-700r/***-61105/-**

Pattern no.	:	1
Rated current	:	10 A
Rated voltage	:	250 V~
Terminals	:	screwless terminals

Product data – type 170-700r/***-61901/-**

Pattern no.	:	1
Rated current	:	10 A
Rated voltage	:	250 V~
Terminals	:	screwless terminals
Design	:	hotel card

Product data – type 170-730/***-61105/-**

Pattern no.	:	6
Rated current	:	10 A
Rated voltage	:	250 V~
Terminals	:	screw terminals

Product data – type 170-730/***-61901/-**

Pattern no.	:	6
Rated current	:	10 A
Rated voltage	:	250 V~
Terminals	:	screw terminals
Design	:	hotel card

Product data – type 170-730r/***-61105/-**

Pattern no.	:	6
Rated current	:	10 A
Rated voltage	:	250 V~
Terminals	:	screwless terminals

Product data – type 170-730r/***-61901/-**

Pattern no.	:	6
Rated current	:	10 A
Rated voltage	:	250 V~
Terminals	:	screwless terminals
Design	:	hotel card

Product data – type 170-7400*/Z/-

Pattern no.	:	1
Rated current	:	6 A
Rated voltage	:	250 V~
Terminals	:	screw terminals

Product data – type 170-859/***-65914/-**

Pattern no.	:	4
Rated current	:	10 A
Rated voltage	:	250 V~
Terminals	:	screw terminals

Product data – type 170-859r/***-65914/-**

Pattern no.	:	4
Rated current	:	10 A
Rated voltage	:	250 V~
Terminals	:	screwless terminals

Product data – type 170-959/***-65918/-**

Pattern no.	:	4
Rated current	:	10 A
Rated voltage	:	250 V~
Terminals	:	screw terminals

Product data – type 170-959r/***-65918/-**

Pattern no.	:	4
Rated current	:	10 A
Rated voltage	:	250 V~
Terminals	:	screwless terminals

TESTS

Test requirements
EN 60669-1:2018

Test result
The test results are documented in DEKRA test file 224284900.

Additional information
These installation switches are intended to be used with the cover plates of the series A, B, C, D E, F or G.

These covers have been constructed as follows:

Serie A
Duoshell (bottom shell: PC/ASA / top shell: zamac, PC/ASA)

Serie B
Monoshell (PC-ASA)

Serie C
Duoshell (bottom shell: PC/ASA / top shell: inox, metal, forbo, plexi, aluminium, brass, PU+PA, PU)

Serie D
Duoshell (bottom shell: PC/ASA / top shell: bamboo, aluminium)

Serie E
Monoshell (PC/ASA)

Serie F
Housings for surface mounting ((PC-ASA)

Serie G
(PF, optional top shell: PU, resin+sand)

Remark:
This certificate is also based on the SGS CEBEC CB Test Certificate BE-8233

This certificate replaces certificate 2131478.02 which we herewith declare invalid and

Conclusion
The examination has confirmed that all requirements were met.

Factory location
Niko N.V.
Industriepark West 40
9100 Sint-Niklaas, Belgium