

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Switch-disconnector
Name and address of the applicant	ABB Switzerland Ltd Low Voltage Products Fulachstrasse 150, 8201 SCHAFFHAUSEN SWITZERLAND
Name and address of the manufacturer	ABB Switzerland Ltd Low Voltage Products Fulachstrasse 150, 8201 SCHAFFHAUSEN SWITZERLAND
Name and address of the factory	ABB Switzerland Ltd Low Voltage Products Fulachstrasse 150, 8201 SCHAFFHAUSEN SWITZERLAND
<i>Note: When more than one factory, please report on page 2</i>	
Ratings and principal characteristics	<input type="checkbox"/> Additional Information on page 2 800V d.c. (2 pole); 1200V d.c. (3 pole); 1500V d.c.(4 pole) 32A; 63A; 125A DC-21A; DC-PV2
Trademark (if any)	
Customer's Testing Facility (CTF) Stage used	CTF stage 2
Model / Type Ref.	S80.PV-SD...
Additional information (if necessary may also be reported on page 2)	Icw: 1,5 kA Icm: 0,5 kA <input type="checkbox"/> Additional Information on page 2
A sample of the product was tested and found to be in conformity with	IEC 60947-1:2007; IEC 60947-1:2007/AMD1:2010 IEC 60947-1:2007/AMD2:2014 IEC 60947-3:2008; IEC 60947-3:2008/AMD1:2012 IEC 60947-3:2008/AMD2:2015
As shown in the Test Report Ref. No. which forms part of this Certificate	225589-CC2-1

This CB Test Certificate is issued by the National Certification Body

VDE Prüf- und Zertifizierungsinstitut GmbH
VDE Testing and Certification Institute
Zertifizierung Produkte / Certification Products

Date: 2017-02-06

Signature: 
J. Richter