

CERTIFICATE

KEMA No.: 2104560.02



Issued to:
Applicant:

Kabelbedrijven Draka Nederland B.V.
Hamerstraat 2-4
1021 JV Amsterdam
The Netherlands

Manufacturer/Licensee:

Kabelbedrijven Draka Nederland B.V.
Hamerstraat 2-4
1021 JV Amsterdam
The Netherlands

Product : cables for public lighting, only for outdoor use
Trade name : DRAKA
Type : EO-YMeKaszh

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

KEMA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard KEMA 162-4:2007;
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 900407


KEMA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on: March 23, 2007 and expires upon withdrawal of one of the above mentioned standards.

KEMA Quality B.V.


P. Nabuurs
Managing director


H.R.M. Barends
Certification Manager

ACCREDITED BY
THE DUTCH COUNCIL
FOR ACCREDITATION



© Integral publication of this certificate is allowed

SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

product	:	cables for public lighting, only for outdoor use
trade name	:	DRAKA
type	:	EO-YMeKasz
rated voltage	:	0,6/1kV
conductors	:	Class 1 or Class 2 for the cross-sections up to and including 10 mm ² . Class 2 for the cross-sections from 10 mm ² and up.
insulation material	:	XLPE compound
innersheath material	:	PE compound
oversheath material	:	PE compound
tested cable	:	4x6 + as 6 mm ²
certified cables	:	2-5x1,5-25 mm ²

TESTS**Test requirements**

KEMA 162-1:2007

KEMA 162-2:2007

KEMA 162-4:2007

Test result

The test results are laid down in KEMA test file 2104560.02.

Remarks

This KEMA-KEUR certificate is based on and supersedes KEMA-KEUR certificate no. 2073452.02, dated May 6, 2004.

Conclusion

The examination proved that all test requirements were met.

Tested by : The tests were performed by the manufacturer under the conditions of the agreement concerning the manufacturers right to conduct type tests for the KEMA-KEUR or KEMA-KEUR-HAR certification system under supervision of KEMA (Supervised Manufacturers Testing)

Supervised by : A.A. Mackenbach

Checked by : H.R.M. Barends

**Factory-Locations**

Kabelbedrijven Draka Nederland B.V.
Industrieterrein De Flammert
5854 NA Nieuw-Bergen, The Netherlands

Kabelbedrijven Draka Nederland B.V.
Hamerstraat 2-4
1021 JV Amsterdam, The Netherlands

Kabelbedrijven Draka Nederland B.V.
Abel Tasmanstraat 1
7821 AN Emmen, The Netherlands