

DVGW certificate of conformity hygiene

DVGW-Konformitätsbestätigung Hygiene

HW-1011DP0530

Registration Number
Registriernummer

Confirmation of Conformity system 1+ with audit testing
Konformitätsbestätigung System 1+ mit Fremdüberwachung

Owner of certificate Simplex Armaturen & Systeme GmbH
Zertifikatinhaber Isnyer Straße 28, D-88260 Argenbühl

Manufacturer Simplex Armaturen & Systeme GmbH
Hersteller Isnyer Straße 28, D-88260 Argenbühl

Product Category Hygienic suitability according to system 1+: Assembled product, product
Produktart group P1 (1011)

Product description Compression fitting for drinking water installation
Produktbezeichnung

Material/Model Simplex Klemmverschraubung Set A3
Werkstoff/Modell

Test reports Certification report: dated 04.11.2024 (ZGW)
Prüfberichte Report of initial inspection: 62103-24-0225-WHE dated 25.06.2024 (SKZ)

Test basis DVGW CERT ZP 1000 (20.04.2022)
Prüfgrundlagen UBA BWGL-Metalle (10.06.2024)

Date of Expiry / File No. 04.11.2029 / 24-0225-WHE
Ablaufdatum / Aktenzeichen

This is to confirm that, based on the DVGW CERT ZP 1000 certification programme, the product information made available, including the recipe specifications and the above-mentioned assessment report, the above-mentioned product/component meets the requirements of, and complies with, the assessment basis/guideline of the German Federal Environmental Agency mentioned under Test Specifications for the temperature range listed on the reverse.

05.11.2024 Pek A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

Type Typ	Technical Data Technische Daten	Remarks Bemerkungen
Klemmverschraubung A3	Temperature range: up to 85 °C	

The assessment reports listed under Test Reports are an integral part of the confirmation of conformity.
The confirmation of conformity is valid from date of issue and remains valid as long as the requirements listed under "Notes" are met.

Notes

The confirmation of conformity was issued on the condition that the raw materials used to manufacture the product or rather their composition and/or components, including the latter's manufacturer and supplier chain have been disclosed in full and no other substances are contained in the product. The validity of this document expires in the event of modifications to the composition of the product or to the processing conditions that were not coordinated with the certification body and in the event of non-compliance with the conformity requirements as well as in the event of termination of the 1+ system monitoring programme of certification body and manufacturer.

The results of our tests and the assessments apply to the test items examined and the statutory regulations valid at the time of testing. Without our express written approval, this document may only be published or reproduced in complete and unaltered form.

This confirmation of conformity is only valid in conjunction with a corresponding entry in the Internet directory of DVGW CERT GmbH (<http://www.dvgw-cert.com>). The confirmation of conformity remains the property of DVGW CERT GmbH and must be returned to DVGW CERT GmbH upon request.

Hints of Utilization / Remarks

Verwendungshinweise / Bemerkungen

Type KV A3

