

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHJECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, Troja, 182 00 Praha 8

CERTIFICATE

No.: 1240522

Product: Industrial Luminaire SEA

Type: DP-SA-109-HE-SS-840-BB-A,
DP-SA-209-HE-SS-840-BB-A,
DP-SA-309-HE-SS-840-BB-A,
DP-SA-409-HE-SS-840-BB-A

Rating: 230 V, 50 Hz, LED 11,5 W, 20,5 W, 29 W, 38 W, IP68, ta 50 °C, Class I luminaire

Ordering firm: doublepower!! s.r.o.
Bílková 856/18, 110 00 Praha 1 - Staré Město, Czech Republic

Manufacturer: doublepower!! s.r.o.
Bílková 856/18, 110 00 Praha 1 - Staré Město, Czech Republic

Factories: doublepower!! s. r. o.
Dubská 1011, 272 03 Kladno, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 240363-01/02 of: 27.05.2024, 021636-01/01 of: 18.12.2020,
021632-01/01-M1 of: 30.09.2024

A sample of the product was found to be in conformity with:

ČSN EN IEC 60598-2-1 ed. 2:2021, ČSN EN IEC 60598-1 ed. 7:2021 + A11:2022,
ČSN EN IEC 55015 ed. 5:2020 (EN IEC 55015:2019), ČSN EN IEC 61547 ed. 3:2023 (EN IEC 61547:2023),
ČSN EN IEC 61000-3-2 ed. 5:2019+A1:2021 (EN IEC 61000-3-2:2019+A1:2021),
ČSN EN 61000-3-3 ed. 3:2014+A1:2019+A2:2022 (EN 61000-3-3:2013+A1:2019+A2:2021)

Other data:

The validity of the certificate is limited to: 06.11.2027

07.11.2024

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



240363-01