

CERTIFICATE

Issued to:
Applicant:
Niko N.V.
Industriepark West 40
9100 Sint-Niklaas, Belgium

Licensee:
Niko N.V.
Industriepark West 40
9100 Sint-Niklaas, Belgium

Product : combination of push-button switches
Trade name(s) : NIKO
Type(s)/model(s) : 7**-35000+-350, 7**-35000+-351, 7**-35005+-350 and 7**-35005+-351

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 60669-1:2018
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 900367


DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on 7 May 2020 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 71-113290

DEKRA Certification B.V.



B.T.M. Holtus
Managing Director



M. Triulzi
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: combination of push-button switches
Trade name(s)	: NIKO
Type(s)/model(s)	: 7**-35000+-350, 7**-35000+-351, 7**-35005+-350 and 7**-35005+-351
Rated current	: 10 A
Rated voltage	: 250 V~
Pattern no.	: 6+6
Method of mounting	: surface type
Cover	: housing of thermoplastic material
Degraa of protection	: IP55, IK07
Programm	: HYDRO
Markings	: -tradenname, series-indication and electrical ratings on the base -tradenname and suffix for the housing on thos part

Product data – type 7-35000+-350**

Terminals : screw terminals

Product data – type 7-35000+-351**

Terminals : screw terminals

Product data – type 7-35005+-350**

Terminals : screwless terminals

Product data – type 7-35005+-351**

Terminals : screwless terminals

TESTS**Test requirements**

EN 60669-1:2018

Test result

The test results are laid down in DEKRA test file 224284900.

Additional information

This certificate is also based on the SGS CEBEC CB Test Certificates BE-8229 and BE-8231.

The products in this certificate mentioned types should be used in combination with the housings as mentioned in our KEMA-KEUR certificate 71-113236

This certificate replaces our certificates 2135290.05 and 2140888.05 which are herewith declare invalid

Conclusion

The examination proved that all requirements were met.

Factory location

Niko N.V.
Industriepark West 40
9100 Sint-Niklaas, Belgium