Data Sheet | Item Number: 2273-244

PUSH WIRE® splicing connector; for solid conductors; Alu-Plus contact paste; max. 2.5 mm²; 4-conductor; transparent housing; red cover; Surrounding air temperature: max 60°C (T60); 2,50 mm²; transparent




https://www.wago.com/2273-244





 $\hbox{Color:} \ \square \ \hbox{transparent}$



Dimensions in mm

Advantages:

- Convenient wiring via extremely compact design
- Push-in termination of up to eight solid conductors
- Cross section range: 0.5 ... 2.5 mm² (18 ... 14 AWG)
- Any combination of conductor sizes is possible
- PUSH WIRE® connection terminates solid ("s") copper conductors

Notes	
Safety management note	NOTICE: Observe installation and safety instructions!
	 Only to be used by electricians! Do not work under voltage/load! Use only for proper use! Observe national regulations/standards/guidelines! Observe technical specifications for the products! Observe the number of permissible potentials! Do not use damaged/dirty components! Observe conductor types, cross-sections and strip lengths! Insert conductor until it hits the product's backstop! Use original accessories! To be sold only with installation instructions!
	·
Safety Information	in grounded power lines



Electrical data			
Ratings per	I	EC/EN 6099	8
Overvoltage category	III	III	II
Pollution degree	3	2	2
Nominal voltage	-	-	450 V
Rated surge voltage	-	-	4 kV
Rated current	-	-	24 A

WAGO spring clamp terminal I suitable for soil aluminum co up to 4 mm²/12 MVG if WAGO Contact Paste 249-130 is us mination. "Alu-Plus" Contact Paste Adva • Automatically destroys the during clamping. • Prevents fresh oxidation at t ping point. • Prevents electrolytic corros ween aluminum and copper or (in the same terminal block). • Provides long-term protectic corrosion. For spring clamp connections WIRE® connection technology commends that the aluminum tor first be cleaned and then by inserted into the clamping u with "Alu-Plus" contact paste. It is also possible to apply WAP Plus" additionally on the whole of the aluminum conductor be nation. Please note that the nominal c must be adapted to the reductivity of the aluminum conductor be nation.				
Connectable conductor materials Connectable conductor materials (note) Connectable conductor materials (note) Connectable conductor materials (note) Terminating Aluminum Terminating Aluminum Cond WAGO spring clamp terminal suitable for solid aluminum coup to 4 mm²/12 AWG if WAGO Contact Paste 249-130 is us mination. "Alu-Plus" Contact Paste Adve. Automatically destroys the during clamping. Prevents fresh oxidation at the ping point. Prevents electrolytic corros ween aluminum and copper or (in the same terminal block). Provides long-term protectic corrosion. For spring clamp connections WIRE® connection technology commends that the aluminum tor first be cleaned and then by inserted into the clamping u with "Alu-Plus" contact paste. It is also possible to apply WAP Plus" additionally on the whole of the aluminum conductor be nation. Please note that the nominal clamping u with "Alu-Plus" contact paste. Solid conductor Solid conductor O.5 2.5 mm² - 22 A Solid conductor O.5 2.5 mm² - 20 16 AWG Strip length 11 mm / 0.43 inches	ta			
Actuation type Connectable conductor materials Copper Aluminum Connectable conductor materials (note) Terminating Aluminum Cond up to 4 mm²/12 AWG Spring clamp terminalt suitable for solid aluminum co up to 4 mm²/12 AWG if WAGO Contact Paste 249-130 is us mination. "Alu-Plus" Contact Paste Adve • Automatically destroys the during clamping. • Prevents fresh oxidation at the ping point. • Prevents electrolytic corros ween aluminum and copper con (in the same terminal block). • Provides long-term protectic corrosion. For spring clamp connections WIRE® connection technology commends that the aluminum tor first be cleaned and then by inserted into the clamping up with "Alu-Plus" contact paste. It is also possible to apply WA Plus" additionally on the whole of the aluminum conductor be nation. Please note that the nominal must be adapted to the reductivity of the aluminum conductor be nation. Please note that the nominal must be adapted to the reductivity of the aluminum conductor be nation. Solid conductor O.5 2.5 mm² - 20 A. Solid conductor O.5 2.5 mm² - 20 16 AWG. Strip length 11 mm / 0.43 inches		4	Connection 1	
Connectable conductor materials Copper Aluminum Connectable conductor materials (note) Terminating Aluminum Cond WAGO spring clamp terminal suitable for solid aluminum coup to 4 mm² 12 AWG if WAGO Contact Paste 249-130 is us mination. *Alu-Plus* Contact Paste Adve. • Automatically destroys the during clamping. • Prevents fresh oxidation at tping point. • Prevents electrolytic corros ween aluminum and copper condition in the same terminal block). • Provides long-term protectic corrosion. For spring clamp connections WIRE* connection technology commends that the aluminum tor first be cleaned and then by inserted into the clamping unit "Alu-Plus" contact paste. It is also possible to apply WA Plus" additionally on the whole of the aluminum conductor be nation. Please note that the nominal must be adapted to the reductivity of the aluminum conductor be nation. Please note that the nominal must be adapted to the reductivity of the aluminum conductor be nation. Solid conductor 5.5 mm² = 16 A 4 mm² = 22 A Solid conductor 5.52.5 mm² / 20 16 AWG Strip length 11 mm / 0.43 inches		1	Connection technology	PUSH WIRE®
Aluminum Connectable conductor materials (note) Terminating Aluminum Cond WAGO spring clamp terminal is suitable for solid aluminum coup to 4 mm²/12 AWG if WAGO Contact Paste 249-130 is us mination. "Alu-Plus" Contact Paste Adve • Automatically destroys the during clamping. • Prevents fresh oxidation at tiping point. • Prevents electrolytic corros ween aluminum and copper come aluminum and copper councer (in the same terminal block). • Provides long-term protectic corrosion. For spring clamp connections WIRE® connection technology commends that the aluminum tor first be cleaned and then by inserted into the clamping uwith "Alu-Plus" contact paste. It is also possible to apply WAPlus" additionally on the whole of the aluminum conductor be nation. Please note that the nominal comust be adapted to the reductivity of the aluminum conductor be nation. Please note that the nominal comust be adapted to the reductivity of the aluminum conductor be nation. Solid conductor O.5 2.5 mm² = 16 A 4 mm² = 22 A Solid conductor O.5 2.5 mm² / 20 16 AWG			Actuation type	Push-in
WAGO spring clamp terminal suitable for solid aluminum coup to 4 mm²/12 AWG if WAGO Contact Paste 249-130 is us mination. "Alu-Plus" Contact Paste Adve • Automatically destroys the of during clamping. • Prevents fresh oxidation at the ping point. • Prevents electrolytic corros ween aluminum and copper of (in the same terminal block). • Provides long-term protectic corrosion. For spring clamp connections WIRE® connection technology commends that the aluminum tor first be cleaned and then by inserted into the clamping unith "Alu-Plus" contact paste. It is also possible to apply WAP Plus" additionally on the whol of the aluminum conductor be nation. Please note that the nominal of the aluminum conductor be nation. Please note that the nominal of the aluminum conductor be nation. Please note that the nominal of the aluminum conductor be nation. Solid conductor O.5			Connectable conductor materials	• •
during clamping. Prevents fresh oxidation at t ping point. Prevents electrolytic corros ween aluminum and copper or (in the same terminal block). Provides long-term protectic corrosion. For spring clamp connections WIRE® connection technology commends that the aluminum tor first be cleaned and then ly inserted into the clamping u with "Alu-Plus" contact paste. It is also possible to apply WAP Plus" additionally on the whole of the aluminum conductor be nation. Please note that the nominal of must be adapted to the reductivity of the aluminum conductor be nation. Please note that the nominal of must be adapted to the reductivity of the aluminum conductor 2.5 mm² = 16 A 4 mm² = 22 A Solid conductor O.52.5 mm² / 20 16 AWG			Connectable conductor materials (note)	WAGO spring clamp terminal blocks ar suitable for solid aluminum conductors up to 4 mm²/12 AWG if WAGO "Alu-Plu Contact Paste 249-130 is used for te
WIRE® connection technology commends that the aluminur tor first be cleaned and then ly inserted into the clamping u with "Alu-Plus" contact paste. It is also possible to apply WAP Plus" additionally on the whole of the aluminum conductor be nation. Please note that the nominal of must be adapted to the reductivity of the aluminum conductivity of the aluminum				 Prevents fresh oxidation at the clamping point. Prevents electrolytic corrosion between aluminum and copper conductor (in the same terminal block). Provides long-term protection agains
Plus" additionally on the whole of the aluminum conductor be nation. Please note that the nominal of must be adapted to the reductivity of the aluminum conductivity of the aluminum conductor and the conductivity of the aluminum condu			For spring clamp connections with PUS WIRE® connection technology, WAGO r commends that the aluminum conductor first be cleaned and then immediately inserted into the clamping unit filled with "Alu-Plus" contact paste.	
must be adapted to the reductivity of the aluminum conductivity of the al				It is also possible to apply WAGO "Alu- Plus" additionally on the whole surface of the aluminum conductor before term nation.
Strip length 11 mm / 0.43 inches				
			Solid conductor	0.5 2.5 mm² / 20 16 AWG
Wiring direction Side-entry wiring			Strip length	11 mm / 0.43 inches
			Wiring direction	Side-entry wiring

Physical data	
Width	18 mm / 0.709 inches
Height	5.8 mm / 0.228 inches
Depth	16.7 mm / 0.657 inches

Data Sheet | Item Number: 2273-244

https://www.wago.com/2273-244



Information on material specifications can be found here
transparent
red
Illa
Polycarbonate (PC)
V2
Chrome-nickel spring steel (CrNi)
Electrolytic copper (E _{Cu})
Tin
0.034 MJ
1.3 g

Environmental requirements	
Ambient temperature (operation)	+60 °C
Continuous operating temperature	105 ℃
Temperature marking per EN 60998	T60

Commercial data	
Product Group	7 (Push Wire Conn.)
ETIM 8.0	EC000446
ETIM 7.0	EC000446
PU (SPU)	1000 (100) pcs
Country of origin	DE
GTIN	4050821032007
Customs tariff number	85369010000

Environmental Product Compliance	
RoHS Compliance Status	Compliant,No Exemption

Approva	Is / Cer	tificates
---------	----------	-----------

General approvals



Approval	Standard	Certificate Name
VDE VDE Prüf- und Zertifizie- rungsinstitut	EN 60998	40029794

Declarations of conformity and manufacturer's declarations

Approval	Standard	Certificate Name
EU-Declaration of Confor- mity WAGO GmbH & Co. KG	-	-
UK-Declaration of Conformity WAGO GmbH & Co. KG	-	-

Approvals for marine applications







Approval	Standard	Certificate Name
ABS American Bureau of Ship- ping	-	15-HG1419918-PDA
DNV GL Det Norske Veritas, Ger- manischer Lloyd	EN 60998	TAE000015T

Approvals for marine applications

LR EN 60998 LR22207029TA Lloyds Register

Data Sheet | Item Number: 2273-244

https://www.wago.com/2273-244



Downloads

Environmental Product Compliance

Compliance Search

Environmental Product Compliance 2273-244



CAD/CAE-Data

CAD data

2D/3D Models 2273-244



1 Compatible Products

1.1 Optional Accessories

1.1.1 Mounting adapter

1.1.1.1 Mounting accessories



Item No.: 2273-500

Mounting carrier; for single- and doublerow con.; 2273 Series; for DIN-35 rail mounting/screw mounting; orange

Installation Notes

Conductor termination



Strip solid conductor to 11 mm/0.43 inch





The transparent housing shows if conductors are fully inserted; within the colored base, a clear port shows if the conductor's strip length is correct. Conductors are correctly stripped if the clear port shows no bare conductor on the unprinted connector side. Picture shows center conductor with exceeded



Termination: Insert the stripped solid conductor until it hits the backstop.



Removal: Hold conductor to be removed and twist alternately left and right while pulling the connector.

Testing

(see marking).



Testing via test port opposite to conductor entry.



Page 5/5 Version 11.07.2024