


GLV 081-05

GINLONG

Solis

**C10/26 - DECLARATION OF CONFORMITY for power-generating units  
GLV ed2.1.2 (12/2019)**

**for the application of annex D "Technical basic requirements regarding the power-generation units" of the Synergrid prescription C10/11 ed2.1 (01/09/2019)**



The undersigned,	Manufacturer: Address:	Ningbo Ginlong Technologies Co., Ltd. No. 57 Jintong Road, Binhai Industrial Park Xiangshan, Ningbo, Zhejiang, 31572, China	Represented by: Country: email: Telephone:	Pan Ruyi China. ruyi.pan@ginlong.com (+86) 574 65802138
------------------	---------------------------	---	---	--

Hereby declares that each production unit completed in the list in tab 'list of power-generating units' of this homologation application complies with the following conditions:


1. The power-generating unit complies with the relevant requirements set out in annex D "Technical basic requirements regarding the power-generation units" of the Synergrid prescription C10/11 ed2.1 (01/09/2019).

2. In order to substantiate this, a separate technical file has been submitted at least for each separate product series of the 'C10/26 list of power-generating units' of this homologation application. Each technical file shall be drawn up on the basis of a checklist Annex D, duly and correctly completed by the manufacturer, accompanied by all the required proof of conformity.

2.1 For technical requirements for which the required proof of conformity (column J in checklist annex D) is a declaration of honour by the manufacturer, the manufacturer declares by signing and dating this declaration of conformity the correctness of the information (conform / not conform / not applicable) provided by him or her in columns K, L and M of this checklist.

2.2. For technical requirements for which the required proof of conformity (column J in checklist Annex D) is a test report or a certificate, the necessary test reports and/or certificates are available \* in the technical file:

- Certificates have been issued by an EN 45011 (or ISO 17065:2012) certification body accredited for these materials.
  - Test reports have been established by an ISO 17025:2005 or ISO 17065:2012 laboratory accredited for these tests.
- 2.3 A list of the document references or the certificates of conformity referred to in the checklist Annex D is also available in the technical file.



Done at:	Ningbo	Homologated by Synergrid on:	03/12/2020
On:	2020.11.16	Stamp Synergrid & signature:	
(stamp manufacturer & signature)	Pan Ruyi 宁波吉龙科技股份有限公司 NINGBO GINLONG TECHNOLOGIES CO., LTD.		

Galerie Ravensteingalerij 4/2

\* Transition period till 01/05/2020 (see exceptions in chapter 3 of C10/11 ed 2.1 (01/09/2019)):  
if at the time of submission of this homologation application it is not yet possible to submit all the necessary certificates and/or test reports, the units do not yet have all the required characteristics (exceptions 1 and 2), a temporary homologation may be granted. All necessary certificates and/or test reports must be submitted to Synergrid at the latest on 30/04/2020 in order to obtain a final homologation. If this is not the case, the temporary C10/26 homologation will be withdrawn.

POWER-GENERATING UNITS TO BE HOMOLOGATED FOR LIST C10/26 ACCORDING TO THE REQUIREMENTS OF ANNEX D OF THE TECHNICAL PRESCRIPTION C10/11 ed2.1 (01/09/2019)  
 2. C10/26 list with power-generating units in accordance with annex D of C10/11 ed2.1 (01/09/2019)  
 GLV 1-01 (ENLOND) Solis  
 checklist ed 2.1.2 (12/2019)

1	2	3	4	5	6		8	9	10	11				12				13				14	15				
					Name and reference of the power control system					POWER		ADDITIONAL CHARACTERISTICS				LIMITATIONS				APPLICATION							
SYNERGRID reference number (GLVxxx-yy-zzzz)	BRAND NAME	Name of the product SERIES	REFERENCE of the model / type of the unit	FIRMWARE VERSION	power control system type	Enfurlr	other power control system	P <sub>act</sub> (active) power (W)	S <sub>max</sub> maximum apparent power (VA)	1-phase or 3-phase	D.3	D.4.1	D.4.2	D.5.2	D.7.1	D.9.1	D.9.2	D.9.3	Other	Backup power system	Energy storage	CHP (combined heat & power)	Wind energy	Solar energy	Temporary homologation (expires on 01/05/2020)	Final homologation	
SOLIS		7S-110K-5G	80K-5G	1D				88000	88000	3-phase																	
SOLIS		7S-110K-5G	100K-5G	1D				110000	110000	3-phase																	
SOLIS		7S-110K-5G	110K-5G	1D				121000	121000	3-phase																	

SYNERGRID a.s. b.l.-v.z.w.  
 Galerie Rayenstingalerij 4/2  
 BE-1000 Brussels/Briussel  
 T.V.A./E.T.W : BE 0402.958.091

宁波德源新能源科技有限公司  
 NINGBO DEYUAN TECHNOLOGIES CO., LTD.

潘宇

FINAL HOMOLOGATION