

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Circuit breaker

Name and address of the applicant

ABB Switzerland Ltd
Low Voltage Products
Fulachstrasse 150, 8201 SCHAFFHAUSEN
SWITZERLAND

Name and address of the manufacturer

ABB Switzerland Ltd
Low Voltage Products
Fulachstrasse 150, 8201 SCHAFFHAUSEN
SWITZERLAND

Name and address of the factory

ABB Switzerland Ltd Low Voltage Products
Fulachstrasse 150, 8201 SCHAFFHAUSEN
SWITZERLAND*Note: When more than one factory, please report on page 2* Additional Information on page 2250 V d.c.; 500 V d.c.; 750 V d.c.; 1000 V d.c.;
In = 0,5 ... 125 A; Characteristic B; K; Icu = Ics = 50 kA

Ratings and principal characteristics

Trademark (if any)

ABB

Customer's Testing Facility (CTF) Stage used

CTF Stage 2

Model / Type Ref.

Series S800S-UC

Additional information (if necessary may also be reported on page 2)

Siehe Prüfbericht / see test report

 Additional Information on page 2IEC 60947-1:2007; IEC 60947-1:2007/AMD1:2010
IEC 60947-1:2007/AMD2:2014
IEC 60947-2:2016

As shown in the Test Report Ref. No. which forms part of this Certificate

252704-TL3-1

This CB Test Certificate is issued by the National Certification Body

VDE Prüf- und Zertifizierungsinstitut GmbH**VDE** Testing and Certification Institute

Zertifizierung Produkte / Certification Products

Date: 2019-01-15

Signature:


J. Richter