



中国国家强制性产品认证证书

证书编号: 2024010305656311

认证委托人名称及地址

ABB France
11 Rue d' Arsonval 69680, Chassieu, FRANCE

生产者名称及地址

ABB France
11 Rue d' Arsonval 69680, Chassieu, FRANCE

生产企业名称及地址

ABB 新会低压开关有限公司
广东省江门市新会区今古洲工业开发区

产品名称和系列、型号、规格

辅助触点

CA4-10、CA4-01、CAL4-11、CAL4-11RT、CA4-20、CA4-02、CA4-11
Ui:690V;Uimp:6kV;AC-15:Ue/Ie:AC24-127V/6A,AC220-240V/4A,AC400-440V/3A,AC500-690V/2
A;DC-13:Ue/Ie:DC24V/6A,DC48V/4A,DC72V/1A,DC110-125V/0.55A,DC220-250V/0.27A,DC400V
/0.15A,DC500V/0.13A,DC600V/0.1A;Ith:16A;外壳防护等级:IP20; 型号解释详见附页

产品标准和技术要求

GB/T 14048.5-2017

上述产品符合《强制性产品认证实施规则 低压电器 低压元器件》
(CNCA-C03-02:2024)的要求, 特发此证。

发证日期: 2024年07月11日 有效期至: 2029年07月10日

证书信息和有效性可扫描下方二维码或登录发证机构网站查验,
也可在认监委网站 (www.cnca.gov.cn) 查询。



签发:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司





中国国家强制性产品认证证书

证书编号：2024010305656311

证书附页：第 1 页 共 1 页

型号的解释：

CAL4 - 11 RT

接线方式: Connection type

空白=螺钉接线; Blank=Screw type connection

RT= 环形垫片螺钉接线; RT=Ring Tongue connection (仅适用于CAL*)

触点对数:

10: 1 对常开触点; One pair normal open

01: 1 对常闭触点; One pair normal close

20: 2 对常开触点; two pair normal open

02: 2 对常闭触点; two pair normal close

11: 1 对常开触点和 1 对常闭触点; One pair normal open and one pair normal close

辅助触点代号: CA4- 正面安装; Front mounting

CAL4-侧面安装; Side mounting

本页为证书附页，应与证书主页同时使用。



中国质量认证中心

CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO.: 2024010305656311

NAME AND ADDRESS OF THE APPLICANT

ABB France
11 Rue d'Arsonval 69680, Chassieu, FRANCE

NAME AND ADDRESS OF THE MANUFACTURER

ABB France
11 Rue d'Arsonval 69680, Chassieu, FRANCE

NAME AND LOCATION OF THE FACTORY

ABB Xinhui Low Voltage Switchgear Co.,Ltd.
Jinguzhou Industrial Development Zone, Xinhui District, Jiangmen City, Guangdong Province,
P.R.China

PRODUCT NAME,MODEL AND SPECIFICATION

Auxiliray Contact

CA4-10、CA4-01、CAL4-11、CAL4-11RT、CA4-20、CA4-02、CA4-11

Ui:690V;Uimp:6kV;AC-15:Ue/Ie:AC24-127V/6A,AC220-240V/4A,AC400-440V/3A,AC500-690V/2A;DC-13:Ue/Ie:DC2
4V/6A,DC48V/4A,DC72V/1A,DC110-125V/0.55A,DC220-250V/0.27A,DC400V/0.15A,DC500V/0.13A,DC600V/0.1A;It
h:16A;IP20 ; Please see attached page for model description

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.5-2017

This is to certify that the above mentioned product(s) complies with the requirements of
implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

Valid from: Jul.11,2024

Valid until: Jul.10,2029

The certificate information and validity could be checked by scanning the QR code below or logging in to
the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO. : 2024010305656311

Appendix: Page 1 of 1

CAL4 - 11 RT

接线方式: Connection type

空白=螺钉接线; Blank=Screw type connection

RT= 环形垫片螺钉接线; RT=Ring Tongue connection (仅适用于CAL*)

触点对数:

10: 1 对常开触点; One pair normal open

01: 1 对常闭触点; One pair normal close

20: 2 对常开触点; two pair normal open

02: 2 对常闭触点; two pair normal close

11: 1 对常开触点和 1 对常闭触点; One pair normal open and one pair normal close

辅助触点代号: CA4 - 正面安装; Front mounting

CAL4 - 侧面安装; Side mounting

This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心

CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.