

产品认证证书

II型自愿认证

证书编号: CQC2019010304193152

发证日期: 2021年03月19日

有效期至: 2024年06月13日

委托人名称 ABB Stotz-Kontakt GmbH
及注册地址 Eppelheimer Strasse 82 69123 Heidelberg Germany

制造商名称 ABB Stotz-Kontakt GmbH
及注册地址 Eppelheimer Strasse 82 69123 Heidelberg Germany

生产企业名称 ABB Bulgaria EOOD – Rakovski branch
及生产地址 BULGARIA, 4142 Village of Stryama, Region of Plovdiv, Municipality of Rakovski, Rakovski Industrial Zone, 14 Industrial Road 1, nr,14-18

产品名称和系列、规格、型号 辅助触头
MARN,MACN;Ui:750V;Uimp:4kV;AC-15:Ue/Ie:120V/6A,220/240V/6A,380/400V/3A,500V/2A,660/690V/1A;DC-13:Ue/Ie:24V/4A,48V/2A,125V/0.7A,250V/0.3A,440V/0.15A;Ith:16A;IP20;型号解释详见附件

产品标准和技术要求 GB/T 14048.5-2017

认证模式 产品型式试验+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站(www.cnca.gov.cn)查验证书信息



授权签字人: 主任:

陈昕 陆楠

中国质量认证中心



PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2019010304193152

Valid from: Mar.19,2021

Valid until: Jun.13,2024

NAME AND REGISTERED ADDRESS OF THE APPLICANT	ABB Stotz-Kontakt GmbH Eppelheimer Strasse 82 69123 Heidelberg Germany
NAME AND REGISTERED ADDRESS OF THE MANUFACTURER	ABB Stotz-Kontakt GmbH Eppelheimer Strasse 82 69123 Heidelberg Germany
NAME AND LOCATION OF THE FACTORY	ABB Bulgaria EOOD – Rakovski branch BULGARIA, 4142 Village of Stryama, Region of Plovdiv, Municipality of Rakovski, Rakovski Industrial Zone, 14 Industrial Road 1, nr,14-18
PRODUCT NAME, MODEL AND SPECIFICATION	Auxiliary Contact MARN,MACN;Ui:750V;Uimp:4kV;AC-15:Ue/Ie:120V/6A,220/240V/6A,380/400V/3A,500V/2A,660/690V/1A;DC-13:Ue/Ie:24V/4A,48V/2A,125V/0.7A,250V/0.3A,440V/0.15A;Ith:16A;IP20;See the Appendix
THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS	GB/T 14048.5-2017
TYPE OF CERTIFICATION SCHEMES	Type Testing of Product + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNED BY:

PRESIDENT:

CHINA QUALITY CERTIFICATION CENTRE



<http://www.cqc.com.cn>

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

Tel: +86 10 83886666

C(2) 0017300

产品认证证书

II型自愿认证

附 录

第 1 页 共 2 页

证书编号: CQC2019010304193152

纸 号: 17300

型号解释:

MA	C	N	4	22	A	T
Product series	Terminal Marking	Mounting	Number of Poles	Auxiliary Contact Configuration	Brand	Terminal Type

Product Series: MA = Auxiliary blocks for M series contactors and auxiliary contactors

Terminal Marking: R or C (R devices terminal numbering starts on 5, C devices start on 2)

Mounting: N = Frontal mounting

Number of Poles = 2, 4

Auxiliary contact configuration:

02 = 2 Normally closed

11 = 1 Normally open + 1 Normally Closed

20 = 2 Normally open (only for MARN-)

40 = 4 Normally open (only for MARN-)

31 = 3 Normally open + 1 Normally Closed

22 = 2 Normally open + 2 Normally Closed

13 = 1 Normally open + 3 Normally Closed

04 = 4 Normally Closed (only for MARN-)

Brand: A = ABB

Terminal Type: T = screw, R = ring

注: 此附录与证书同时使用时有效。



中国质量认证中心

产品认证证书

II型自愿认证

附 录

第 2 页 共 2 页

证书编号: CQC2019010304193152

纸 号: 17300

中文型号解释 Chinese Version

MA	R	L	1	22	A	T
迷你接触器和接触器式继电器产品线	适用产品线	安装位置	极数	触头组合	品牌	接线端子类型

迷你接触器和接触器式继电器产品线: MA

适用产品线: C=适用 MC 接触器产品线; R=适用 MCR 接触器式继电器产品线

安装位置: N=前置安装

极数: 2=2 极, 4=4 极

触头组合:

02=2 常闭

11=1 常开+1 常闭

20=2 常开 (仅 MARN-)

40=4 常开 (仅 MARN-)

31=3 常开 +1 常闭

22=2 常开+2 常闭

13=1 常开 +3 常闭

04=4 常闭 (仅 MARN-)

品牌: A=ABB

接线端子类型: T=螺纹端子; R=环形端子

注: 此附录与证书同时使用时有效。



中国质量认证中心